

Internal fixed lighting installations

1. 'A' Examination (User Check)

1.1. Lamps

Lamps in manned installations to be replaced on failure.

2. 'F' Examination

2.1. Location

- a) Check for satisfactory condition and security.
- b) Check identification – MIMS Equipment Number shown.
- c) Check control/functionality.
- d) Check that 'as fitted' equipment aligns with schematic drawing.

2.2. Fittings

- a) Clean.
- b) Check condition and alignment.

2.3. Lamps

Re-lamp tunnel lighting (Tungsten Fittings).

3. 'G' Examination

3.1. Lamps

Re-lamp Tunnel Lighting (Non-Tungsten Fitting).

4. 'I' Examination

4.1. BS7671 Periodic Electrical Inspection and Testing

- a) Carry out periodic 'electrical inspection/testing'.
- b) Attach labelling to main switchgear of installation to clearly display the 'date of next electrical inspection'. Previous inspection may reduce periodicity.

End

Internal fixed lighting installations

This page intentionally blank