

Ref:	NR/L3/ELP/29987/02
Issue:	4
Date:	05/09/2015
Compliance date:	11/01/2016

Level 3

Working On or About 25 kV A.C. Electrified Lines

Module 2 Assessment of Electrical Risks

(This module is one of a suite of modules forming Network Rail standard NR/L3/ELP/29987 'Working On or About 25 kV A.C. Electrified Lines')

This document is the property of Network Rail. It shall not be reproduced in whole or part nor disclosed to a third party without the written permission of Network Rail.

© Copyright 2015 Network Rail.

Uncontrolled copy once printed from its electronic source.

Published and Issued by Network Rail, 2nd Floor, One Eversholt Street, London NW1 2DN.



Ref:	NR/L3/ELP/29987/02
Issue:	4
Date:	05/09/2015
Compliance date:	11/01/2016

Contents

1 Purpose	3
2 Scope	3
3 Reduced Wire Height	3
3.1 Areas of Reduced Wire Height	3
Table 1 – Areas of reduced wire height	Error! Bookmark not defined.
3.2 Use of On-Track Plant in Areas of Reduced Wire Height	3
4 Assessment of Risk Before Attempting Work	4
4.1 General	4
4.2 Work More Than 2.75 metres (9 feet) from Live Equipment (See Appendix A)	4
4.3 Work Less Than 2.75 metres (9 feet) but More Than 600 millimetres (2 feet) from Live Equipment (See Appendix A)	4
Table 2 – Authorisers of risk assessments and safe systems of work	5
4.4 Work Less Than 600 millimetres (2 feet) from Live Equipment (See Appendix A)	5
Appendix A Diagram of Dimensions for Working Relative to Live Parts of the OLE, Live Pantographs and Other Roof-Mounted Electrical Equipment on Trains	6