PD CLC IEC/TR 62453-52-90:2019



BSI Standards Publication

Field device tool (FDT) interface specification

Part 52-90: Communication implementation for common language infrastructure - IEC 61784 CPF 9

bsi.

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

National foreword

This Published Document is the UK implementation of CLC IEC/TR 62453-52-90:2019. It is identical to IEC TR 62453-52-90:2017.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 580 95969 1

ICS 35.110; 35.100.05; 25.040.40

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 28 February 2019.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

TECHNICAL REPORT

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

CLC IEC/TR 62453-52-90

February 2019

ICS 25.040.40; 35.100.05; 35.110

English Version

Field device tool (FDT) interface specification - Part 52-90: Communication implementation for common language infrastructure - IEC 61784 CPF 9 (IEC/TR 62453-52-90:2017)

Spécification des interfaces des outils des dispositifs de terrain (FDT) – Partie 52-90: Mise en œuvre d'un profil de communication pour l'infrastructure commune de langage – CPF 9 de l'IEC 61784 (IEC/TR 62453-52-90:2017)

Field Device Tool (FDT)-Schnittstellenspezifikation - Teil 52-90: Kommunikationsimplementierung mit der allgemeinen Sprachinfrastruktur - Kommunikationsprofilfamilie (CPF) 9 nach IEC 61784 (IEC/TR 62453-52-90:2017)

This Technical Report was approved by CENELEC on 2019-01-14.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Documents Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

European foreword

This document (CLC IEC/TR 62453-52-90:2019) consists of the text of IEC/TR 62453-52-90:2017 prepared by SC 65E "Devices and integration in enterprise systems" of IEC/TC 65 "Industrial-process measurement, control and automation".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC/TR 62453-52-90:2017 was approved by CENELEC as a European Standard without any modification.

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 Where an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC 61784-1	2014	Industrial communication networks - Profiles - Part 1: Fieldbus profiles	EN 61784-1	2014
IEC 62453-1	2016	Field device tool (FDT) interface specification - Part 1: Overview and guidance	EN 62453-1	2017
IEC 62453-2	2016	Field device tool (FDT) interface specification - Part 2: Concepts and detailed description	EN 62453-2	2017
IEC TR 62453-42	2016	Field device tool (FDT) interface specification - Part 42: Object model integration profile - Common language infrastructure	-	-
IEC 62453-309	2016	Field device tool (FDT) interface specification – Part 309: Communication profile integration – IEC 61784 CPF 9	EN 62453-309	2017

Documents
Document Sharing Hub
Full document details: PD CLC IEC/TR 62453-52-90:2019

This page deliberately left blank

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

CONTENTS

FOREWORD 5
INTRODUCTION 7
1 Scope 8
2 Normative references 8
3 Terms, definitions, symbols, abbreviated terms and conventions 8
3.1 Terms and definitions 8
3.2 Symbols and abbreviated terms 9
3.3 Conventions 9
3.3.1 Datatype names and references to datatypes 9
3.3.2 Vocabulary for requirements 9
3.3.3 Use of UML 9
4 Bus category 9
5 Access to instance and device data 9
5.1 General 9
5.2 IO signals provided by DTM 9
5.3 Data interfaces 10
5.3.1 General 10
5.3.2 Mapping HART datatypes to FDT datatypes 10
5.3.3 SemanticInfo 11
5.3.4 Data exposure using IDeviceData and IInstanceData interfaces 12
6 Protocol specific behaviour 18
6.1 Support of burst mode 18
6.2 Device addressing 19
6.3 Support of scanning 19
6.4 Support of extended command numbers 19
6.5 Support for handling of communication failures and time-outs 19
6.6 Support for handling of Delayed Responses 20
6.7 Support for topologies with mixed HART protocols 20
6.8 Support for nested communication with multiple gateways 20
6.9 Support for topologies with WirelessHART 20
6.10 Transparent gateways 20
6.10.1 General 20
6.10.2 Scenario 1 – Manual topology creation 20
6.10.3 Scenario 2 – Topology scan and add 21
7 Protocol specific usage of general datatypes 21
8 Protocol specific common datatypes 21
8.1 HartDeviceAddress datatype 21
8.2 HartDeviceIpAddress datatype 22
8.3 HartDeviceWirelessAddress datatype 23
9 Network management datatypes 24
10 Communication datatypes 24
10.1 General 24
10.2 HartConnectRequest datatype 24
10.3 HartConnectResponse datatype 25
10.4 HartLongAddress datatype 26
10.5 HartDisconnectRequest datatype 26

AVA Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

10.6 HartDisconnectResponse datatype 27
10.7 HartTransactionRequest datatype 27
10.8 HartTransactionResponse datatype 28
10.9 HartStatus datatype 29
10.10 HartAbortMessage datatype 29
10.11 HartSubscribeRequest datatype 30
10.12 HartSubscribeResponse datatype 30
10.13 HartUnsubscribeRequest datatype 30
10.14 HartUnsubscribeResponse datatype 31
11 Datatypes for process data information 31
11.1 General 31
11.2 HartIOSignalInfo datatype 32
12 Device identification datatypes 33
12.1 General 33
12.2 HartDeviceScanInfo datatype 33
12.3 HartDeviceIdentInfo datatype 37
12.4 Mapping of information source 38
Bibliography 41

Figure 1 – Part 52-90 of the IEC 62453 series 7
Figure 2 – Structural information for device variables 16
Figure 3 – Structural information for dynamic variables 17
Figure 4 – Structural information for extended device status 18
Figure 5 – Device-initiated data transfer with burst mode 19
Figure 6 – HartDeviceAddress datatype 21
Figure 7 – HartDeviceIpAddress datatype 22
Figure 8 – HartDeviceWirelessAddress datatype 23
Figure 9 – HartNetworkData datatype 24
Figure 10 – HartConnectRequest datatype 25
Figure 11 – HartConnectResponse datatype 26
Figure 12 – HartDisconnectRequest datatype 27
Figure 13 – HartDisconnectResponse datatype 27
Figure 14 – HartTransactionRequest datatype 28
Figure 15 – HartTransactionResponse datatype 28
Figure 16 – HartAbortMessage datatype 29
Figure 17 – HartSubscribeRequest datatype 30
Figure 18 – HartSubscribeResponse datatype 30
Figure 19 – HartUnsubscribeRequest datatype 31
Figure 20 – HartUnsubscribeResponse datatype 31
Figure 21 – HartIOSignalInfo datatype 32
Figure 22 – HartDeviceScanInfo datatype 33
Figure 23 – HartDeviceIdentInfo datatype 37

Table 1 – Output signal info within IOSignalInfo / HartIOSignalInfo 10
Table 2 – Mapping of basic datatypes 11

AVA Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

Table 3 – SemanticInfo attributes description 12
Table 4 – Basic Variables exported in IDeviceData and IInstanceData interfaces 13
Table 5 – Basic Variables exported only in IDeviceData interface 15
Table 6 – Protocol specific usage of general datatypes 21
Table 7 – HartDeviceAddress datatype 22
Table 8 – HartDeviceIpAddress datatype 23
Table 9 – HartDeviceWirelessAddress datatype 24
Table 10 – HartNetworkData datatype 24
Table 11 – HartConnectRequest datatype 25
Table 12 – HartConnectResponse datatype 26
Table 13 – HartLongAddress datatype 26
Table 14 – HartDisconnectRequest datatype 27
Table 15 – HartDisconnectResponse datatype 27
Table 16 – HartTransactionRequest datatype 28
Table 17 – HartTransactionResponse datatype 29
Table 18 – HartStatus datatype 29
Table 19 – HartAbortMessage datatype 29
Table 20 – HartSubscribeRequest datatype 30
Table 21 – HartSubscribeResponse datatype 30
Table 22 – HartUnsubscribeRequest datatype 31
Table 23 – HartUnsubscribeResponse datatype 31
Table 24 – Usage of IOSignalInfo datatype 32
Table 25 – HartIOSignalInfo datatype 32
Table 26 – HartDeviceScanInfo datatype 33
Table 27 – Protocol specific mapping of scan information 35
Table 28 – HartDeviceIdentInfo datatype 37
Table 29 – Protocol specific mapping of identity information 39

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 52-90: Communication implementation for common language infrastructure – IEC 61784 CPF 9

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 62453-52-90, which is a technical report, has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

Each part of the IEC 62453-52-xy series is intended to be read in conjunction with its corresponding part in the IEC 62453-3xy series. This document corresponds to IEC 62453-309.

AVA Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
65E/440/DTR	65E/514/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of the IEC 62453 series, under the general title *Field device tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

INTRODUCTION

This part of IEC 62453 is an interface specification for developers of Field Device Tool (FDT) components for function control and data access within a client/server architecture. The specification is a result of an analysis and design process to develop standard interfaces to facilitate the development of servers and clients by multiple vendors that need to interoperate seamlessly.

With the integration of fieldbuses into control systems, there are a few other tasks which need to be performed. In addition to fieldbus- and device-specific tools, there is a need to integrate these tools into higher-level system-wide planning or engineering tools. In particular, for use in extensive and heterogeneous control systems, typically in the area of the process industry, the unambiguous definition of engineering interfaces that are easy to use for all those involved is of great importance.

A device-specific software component, called Device Type Manager (DTM), is supplied by the field device manufacturer with its device. The DTM is integrated into engineering tools via the FDT interfaces defined in this specification. The approach to integration is in general open for all kind of fieldbusses and thus meets the requirements for integrating different kinds of devices into heterogeneous control systems.

Figure 1 shows how this part of the IEC TR 62453-52-xy series is aligned in the structure of the IEC 62453 series.




Figure 1 – Part 52-90 of the IEC 62453 series

Documents
Document Sharing Hub
Full document details: PD CLC IEC/TR 62453-52-90:2019

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 52-90: Communication implementation for common language infrastructure – IEC 61784 CPF 9

1 Scope

This part of the IEC 62453-52-xy series, which is a Technical Report, provides information for integrating the HART®[1] technology into the CLI-based implementation of FDT interface specification (IEC TR 62453-42).

This part of IEC 62453 specifies implementation of communication and other services based on IEC 62453-309.

This document neither contains the FDT specification nor modifies it.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61784-1:2014, *Industrial communication networks – Profiles – Part 1: Fieldbus profiles*

IEC 62453-1:2016, *Field device tool (FDT) interface specification – Part 1: Overview and guidance*

IEC 62453-2:2016, *Field device tool (FDT) interface specification – Part 2: Concepts and detailed description*

IEC TR 62453-42:2016, *Field device tool (FDT) interface specification – Part 42: Object model integration profile – Common language infrastructure*

IEC 62453-309:2016, *Field device tool (FDT) interface specification – Part 309: Communication profile integration – IEC 61784 CPF 9*

3 Terms, definitions, symbols, abbreviated terms and conventions

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62453-1, IEC 62453-2, IEC TR 62453-42 and IEC 62453-309 apply.

---

[1] HART ® is the trade name of a product supplied by HART Communication Foundation. This information is given for convenience of users of this document and does not constitute an endorsement by IEC of the product named. Equivalent products may be used if they can be shown to lead to the same results.

AVA Documents Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.2 Symbols and abbreviated terms

For the purposes of this document, the symbols and abbreviations given in IEC 62453-1, IEC 62453-2, IEC 62453-309, and IEC TR 62453-42 apply.

3.3 Conventions

3.3.1 Datatype names and references to datatypes

The conventions for naming and referencing of datatypes are explained in IEC 62453-2:2016, Clause A.1.

3.3.2 Vocabulary for requirements

The following expressions are used when specifying requirements.

Usage of “shall” or “mandatory”	No exceptions allowed.
Usage of “should” or “recommended”	Strong recommendation. It may make sense in special exceptional cases to differ from the described behaviour.
Usage of “can” or “optional”	Function or behaviour may be provided, depending on defined conditions.

3.3.3 Use of UML

Figures in this document are using UML notation as defined in Annex A of IEC 62453-1:2016.

4 Bus category

IEC 61784 CPF 9 protocol is identified in the attribute busCategory of the BusCategory element by the identifiers, as specified in IEC 62453-309.

5 Access to instance and device data

5.1 General

Used at interfaces:

- IInstanceData
- IDeviceData

These interfaces shall provide access to at least all parameters defined in IEC 62453-309.

5.2 IO signals provided by DTM

A DTM shall provide IO signal information of the device using the IProcessData interface.

To provide all information required to access the output signal information the DTM shall provide the information shown in Table 1 within its HartIOSignalInfo.

Documents
Document Sharing Hub

Full document details: PD CLC IEC/TR 62453-52-90:2019

Table 1 – Output signal info within IOSignalInfo / HartIOSignalInfo

Attribute	Description
Name	Name of the IO signal
Range	Reference to the variables providing range information
Unit	Reference to an enumeration variable describing the unit information
DeviceVariableAssignment	Constant enumeration value that can take following values – unassigned: The IO signal is not assigned to dynamic variable and can only be accessed using the indexed approach (reading device variables). – PV: IO signal assigned to the PV dynamic variable – SV: IO signal assigned to the SV dynamic variable – TV: IO signal assigned to the TV dynamic variable – QV: IO signal assigned to the QV dynamic variable
DeviceVariableCode	Constant that specifies the device specific variable code (see [7][2] Table 34). Because of compatibility reasons to other FDT versions (e.g. IEC TR 62453-41), this variable could be set to the value 252 that stands for “unknown”.

5.3 Data interfaces

5.3.1 General

Within HART, several command sets are defined. As part of the command set definition, HART provides a precise naming convention that is documented within the sources of the standard EDD libraries. The data provided by the access data interfaces should be named according to the HART naming convention. For backward compatibility, the semantic IDs as defined in previous versions of FDT should also be provided by the DTM.

A DTM shall provide all device data that is related to the set of Universal Commands and should provide all device data related to Common Practice CommandsIf the device supports additional command sets, like device family profiles, those data should also be exported using the naming convention as defined in the HART EDD libraries and as shown in Figure 2 and Figure 3.

5.3.2 Mapping HART datatypes to FDT datatypes

For a better usability of data provided by the data access interfaces IDeviceData and IInstanceData, all data from the device shall be converted into datatypes that are common to FDT. The mapping of basic datatypes is defined in Table 2.

2 Figures in square brackets refer to the Bibliography.

Documents
Document Sharing Hub
Full document details: PD CLC IEC/TR 62453-52-90:2019