PD CLC/TR IEC 62453-62:2019

BSI Standards Publication

Field device tool (FDT) interface specification

Part 62: Field device tool (FDT) styleguide for common language infrastructure (IEC TR 62453-62:2017)

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

National foreword

This Published Document is the UK implementation of CLC/TR IEC 62453-62:2019. It is identical to IEC TR 62453-62:2017.

The UK participation in its preparation was entrusted to Technical Committee GEL/65/3, Industrial communications: process measurement and control, including fieldbus.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 02870 6

ICS 25.040.40; 35.100.05; 35.110

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 May 2019.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

TECHNICAL REPORT

RAPPORT TECHNIQUE

TECHNISCHER BERICHT

CLC/TR IEC 62453-62

April 2019

ICS 25.040.40; 35.100.05; 35.110

English Version

Field device tool (FDT) interface specification - Part 62: Field device tool (FDT) styleguide for common language infrastructure (IEC TR 62453-62:2017)

Spécification des interfaces des outils des dispositifs de terrain (FDT) - Partie 62: Guide stylistique de l'outil de dispositif de terrain (FDT) pour l'infrastructure commune de langage
(IEC TR 62453-62:2017)

Field Device Tool (FDT)-Schnittstellenspezifikation - Teil 62: Field device tool (FDT) Leitfaden für common language infrastructure
(IEC TR 62453-62:2017)

This Technical Report was approved by CENELEC on 2019-03-18.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

© 2019 CENELEC All rights of exploitation in any form and by any means reserved worldwide for CENELEC Members.

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

European foreword

This document (CLC/TR IEC 62453-62:2019) consists of the text of the IEC TR 62453-62:2017 prepared by 65E: "Devices and integration in enterprise systems", of IEC technical committee 65: "Industrial process measurement, control and automation".

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC shall not be held responsible for identifying any or all such patent rights.

Documents
Document Sharing Hub
Full document details: PD CLC/TR IEC 62453-62:2019

Annex ZA
(normative)

Normative references to international publications with their corresponding European publications

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

Publication	Year	Title	EN/HD	Year
IEC TR 62453-42	-	Field device tool (FDT) interface specification – Part 42: Object model integration profile – Common Language Infrastructure	-	-
IEC 62453-1	-	Field device tool (FDT) interface specification - Part 1: Overview and guidance	EN 62453-1	-
IEC 62453-2	-	Field device tool (FDT) interface specification - Part 2: Concepts and detailed description	EN 62453-2	-

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

This page deliberately left blank

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms, definitions, symbols, abbreviated terms and conventions 7
3.1 Terms and definitions 7
3.2 Symbols and abbreviated terms 8
3.3 Conventions 8
3.3.1 Data type names and references to data types 8
3.3.2 Vocabulary for requirements 8
3.3.3 Specific formatting 8
4 Fundamentals of designing DTM user interfaces 8
5 Benefits from the FDT user's point of view 9
6 DTM user interface 10
6.1 Objective 10
6.2 Appearance 10
6.2.1 General 10
6.2.2 DTM user interface categories 10
6.2.3 DTM user interface areas 13
6.3 General behaviour 20
6.3.1 General 20
6.3.2 WPF user interfaces 20
6.3.3 UI navigation 21
6.3.4 UI resize 21
6.3.5 Display of information 21
6.3.6 Use of modal user interfaces 22
7 Parameter handling 22
7.1 Representation within Application Area 22
7.2 Change of parameter values 22
7.2.1 Relation between parameters 22
7.2.2 Block mode 22
7.2.3 Direct Mode 22
7.2.4 Continuous Check and One Time Check 23
7.3 Representation of parameters 24
7.3.1 Parameter value and associated information 24
7.3.2 Parameter value modifications 25
8 Applications of a DTM 25
8.1 General 25
8.2 Application categories 26
8.2.1 Online application/data source: device 26
8.2.2 Offline application/data source: data set 26
8.2.3 Synchronized application/data source: data set and device 26
8.3 User role related default application 27
8.4 Main Operation 27
8.5 Typical workflow 27
8.5.1 General 27

AVA Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

8.5.2 Parameterize device offline ... 27
8.5.3 Parameterize device with online connection (synchronized) ... 29
8.5.4 Parameterize device with online connection (non synchronized) ... 30
9 DTM behaviour ... 31
9.1 Close of user interface ... 31
9.1.1 Close of user interface with modified parameter values ... 31
9.1.2 Synchronization on close of user interface ... 32
9.2 Data set ... 32
9.2.1 Parameter in multiple user interfaces ... 32
9.2.2 Locking mechanism ... 32
9.3 Error handling ... 33
9.4 Localization ... 33
9.5 Global report information ... 33
Annex A (normative) Dictionary of standard terms ... 34
Annex B (normative) Dictionary of standard phrases ... 37
Bibliography ... 42

Figure 1 – IEC 62453-62 in IEC 62453 (all parts) ... 6
Figure 2 – Areas of a Standard user interface ... 11
Figure 3 – Areas of an Advanced user interface ... 12
Figure 4 – Areas of a Wizard user interface ... 13
Figure 5 – Structure of the Identification Area ... 13
Figure 6 – State diagram: Continuous Check ... 23
Figure 7 – State diagram: One Time Check ... 24
Figure 8 – Parameter value and associated information ... 24
Figure 9 – Parameterize device offline ... 28
Figure 10 – Parameterize device with offline parameterize and subsequent download ... 29
Figure 11 – Parameterize device with online connection (synchronized) ... 30
Figure 12 – Parameterize device with online connection (non synchronized) ... 31

Table 1 – Contents of Identification Area ... 14
Table 2 – Toolbar ... 15
Table 3 – Methods for UI using Block Mode ... 16
Table 4 – Methods for UI using Direct Mode ... 17
Table 5 – Wizard actions ... 17
Table 6 – Contents of Status Bar ... 18
Table 7 – Possible connection states ... 18
Table 8 – Possible data source and target states ... 19
Table 9 – Possible states of the instance data set ... 19
Table 10 – Possible modification states ... 20
Table 11 – Possible device diagnostic states (see [1]) ... 20
Table 12 – Display of inadmissible data ... 24
Table 13 – Priority of parameter value states ... 25
Table 14 – Recommended default application ... 27

AVA Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 62: Field device tool (FDT) styleguide for common language infrastructure

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 62453-62, which is a Technical Report, has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
65E/442/DTR	65E/515/RVC

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The list of all parts of the IEC 62453 series, under the general title *Field device tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

INTRODUCTION

This document is a user interface design specification for developers of FDT (field device tool) components for Function Control and Data Access within a Client/Server architecture. This document is a result of an analysis and design process to develop standard interfaces to facilitate the development of components by multiple vendors that interoperate seamlessly.

A device-specific software component, called DTM (Device Type Manager), is supplied by the field device manufacturer with its device. The DTM is integrated into engineering tools via the FDT interfaces defined in this specification. The approach to integration is in general open for all kinds of fieldbusses and thus meets the requirements for integrating different kinds of devices into heterogeneous control systems.

To ensure the consistent management of a plant-wide control and automation technology, fieldbusses, devices and sub-systems are fully integrated as a seamless part of a wide range of automation tasks covering the whole automation life-cycle. This integration also requires a consistent look and feel of device specific components.

Figure 1 shows how IEC TR 62453-62 is aligned in the structure of IEC 62453 (all parts).



Figure 1 – IEC 62453-62 in IEC 62453 (all parts)

Documents
Document Sharing Hub
Full document details: PD CLC/TR IEC 62453-62:2019

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 62: Field device tool (FDT) styleguide for common language infrastructure

1 Scope

IEC TR 62453-62, which is a Technical Report, explains the guidelines and rules for the CLI-based implementation of a Device Type Manager (DTM) and parts of a Frame Application with regard to the user interface and its behaviour. These guidelines and rules are part of the FDT specification (IEC TR 62453-42) and are intended to ensure that all users are provided with clear and consistent user interface functions and features across DTMs in a system.

This specification neither contains the FDT specification nor modifies it.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62453-1, *Field device tool (FDT) interface specification – Part 1: Overview and guidance*

IEC 62453-2, *Field device tool (FDT) interface specification – Part 2: Concepts and detailed description*

IEC TR 62453-42, *Field device tool (FDT) interface specification – Part 42: Object model integration profile – Common Language Infrastructure*

3 Terms, definitions, symbols, abbreviated terms and conventions

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62453-1, IEC 62453-2, [7] and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1.1
Application
DTM UI Applications and DTM UI Functions

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

3.2 Symbols and abbreviated terms

For the purposes of this specification the symbols and abbreviated terms given in IEC 62453-1, IEC 62453-2, IEC 62453-42 and the following apply.

UI	user interface
NAMUR	User Association of Automation Technology in Process Industries
WPF	Windows Presentation Foundation (Microsoft user interface library)

3.3 Conventions

3.3.1 Data type names and references to data types

The conventions for naming and referencing of data types are explained in [7].

3.3.2 Vocabulary for requirements

The following expressions are used when specifying requirements.

Usage of "shall" or "Mandatory"	No exceptions allowed.
Usage of "should" or "Recommended"	Strong recommendation. It may make sense in special exceptional cases to differ from the described behaviour.
Usage of "can" or "Optional"	A DTM may provide the function or behaviour depending on the task and type of the DTM. If a function or behaviour is provided, it shall follow the style guide.

3.3.3 Specific formatting

The following formatting is used to describe specific context.

CAPITAL LETTERS	Names of keys on the keyboard – for example, SHIFT, CTRL, or ALT
[Button text]	Button with the specified text
ClassName::PropertyName or InterfaceName::MethodName	Name of property or method according to definition in FDT 2.0 Technical Specification

4 Fundamentals of designing DTM user interfaces

The design of UIs for DTMs is based on the ten general principles for user interface design accepted in general public [3], [4]. They are called "heuristics" because they are more in the nature of rules of thumb than specific usability guidelines. The heuristics should give the DTM developer some general hints on how to implement a DTM. For additional fundamentals of user interface design, please see the available literature (e.g. [5], [6]). The ten general principles are the following.

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

Visibility of system status
The system should always keep users informed about what is going on, through appropriate feedback within an acceptable time limit (dependant on the task, e.g. 1 sec.).

Match between system and the real world
The system should speak the users' language with words, phrases and concepts familiar to the user, rather than system-oriented terms. Follow real-world conventions, making information appear in a natural and logical order.

User control and freedom
Users often choose system functions by mistake and need a clearly marked "emergency exit" to leave the unwanted state without having to go through an extended dialogue. Support undo and redo.

Consistency and standards
Users should not have to wonder whether different words, situations, or actions mean the same thing. Follow platform conventions.

Error prevention
A careful design, which prevents a problem from occurring in the first place, is even better than good error messages.

Recognition rather than recall
Make objects, actions, and options visible. The user should not have to remember information from one part of the dialogue to another. Instructions for use of the system should be visible or easily retrievable whenever appropriate.

Flexibility and efficiency of use
Accelerators – unseen by the novice user – may often speed up the interaction for the expert user such that the system can cater to both inexperienced and experienced users. Allow users tailoring of frequent actions.

Aesthetic and minimalist design
Dialogue should not contain information, which is irrelevant or rarely needed. Every extra unit of information in a dialogue competes with the relevant units of information and diminishes their relative visibility.

Help users recognize, diagnose, and recover from errors
Error messages should be expressed in plain language (no codes), precisely indicate the problem, and constructively suggest a solution.

Help and documentation
Even though it is better if the system can be used without documentation, it may be necessary to provide help and documentation. Any such information should be easy to search, focus on the user's task, list concrete steps to be carried out, be context sensitive and not be too large.

5 Benefits from the FDT user's point of view

Using DTMs compliant with this style guide enables a user to operate more efficiently and more safely. The user is able to parameterize and manage the data of devices from various manufacturers in a uniform way. Therefore, the user is presented with a clearly structured concept regardless of the manufacturer or the type of the device. Details or requirements for developers of a DTM are given within the following clauses.

Guideline and rules are defined for:

- Uniform user guidance: DTM user interfaces are used and displayed in engineering systems and stand alone tools in the same manner regardless of the device or DTM manufacturer or communication protocol employed.
- Uniform behaviour of a DTM.

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019

- Clear identification of the DTM and the assigned device.
- Ensuring users will be updated on the status and the parameterization of the configuration constantly. All changes of the configuration are marked.
- Informing users, whether UI input affects the device directly or the offline configuration.
- Executing plausibility checks of the configuration on a lexically (e.g. only certain characters are accepted), syntactically (e.g. a limited number of characters) and semantically (e.g. given value is below upper limit) correct basis.

6 DTM user interface

6.1 Objective

The user interface of a DTM application shall be designed to provide a user with a software component that is easy to use and self-explanatory. The user interface assists the user to be able to concentrate on his/her main tasks. Novel user interface elements or features should not detract the user.

6.2 Appearance

6.2.1 General

In general, a DTM user interface is divided into the following areas:

- Identification Area: contains information about the device that is handled by the DTM;
- Application Area: contains all necessary UI elements for the selected function.

These areas shall be arranged as described in the following subclauses.

In addition, the two following DTM related areas are displayed and controlled by the Frame Application:

- Action Area that contains buttons to initiate the user's choice;
- Status Area that contains status information of the DTM.

Icons of the FDT icon library should be used for all FDT tools and states that are described in this document.

6.2.2 DTM user interface categories

6.2.2.1 General

Three categories of DTM user interfaces are specified.

- Standard layout, where one presentation object displays one application with no or only with limited navigation capability.
- Advanced layout, where one presentation object displays one application with advanced navigation capability.
- Wizard layout, where one presentation object displays a guided input user interface.

Documents
Document Sharing Hub

Full document details: PD CLC/TR IEC 62453-62:2019