BSI Standards Publication

Household and similar electrical air cleaning appliances — Methods for measuring the performance

Part 3-1: Method for assessing the reduction rate of key bioaerosols by portable air cleaners using an aerobiology test chamber

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

National foreword

This Published Document is the UK implementation of IEC PAS 63086-3-1:2023.

The UK participation in its preparation was entrusted to Technical Committee CPL/59, Performance of household electrical appliances.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 27436 3

ICS 23.120

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 June 2023.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

IEC PAS 63086-3-1

Edition 1.0 2023-05

PUBLICLY AVAILABLE SPECIFICATION

colour inside

Household and similar electrical air cleaning appliances – Methods for measuring the performance
Part 3-1: Method for assessing the reduction rate of key bioaerosols by portable air cleaners using an aerobiology test chamber

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 23.120

ISBN 978-2-8322-7057-8

Warning! Make sure that you obtained this publication from an authorized distributor.

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

CONTENTS

FOREWORD 3
INTRODUCTION 5
1 Scope 6
2 Normative references 6
3 Terms and definitions 7
4 Principle 9
5 Apparatus and materials 9
6 Preparation of the stock cultures and working cultures of the test microbes 12
7 Procedures 12
8 Calculation and expression of results 16
9 Test report 20
Annex A (informative) Test chamber 21
Annex B (informative) Example calculations for machine decay 23
Annex C (informative) Alternate microbes for testing 24
Annex D (informative) Slit sampler operation 25
Annex E (informative) Suggested test report using this method 26
Bibliography 28

Figure 1 – SKC biosampler 11
Figure 2 – Process table 16
Figure 3 – Alternate process table 16
Figure A.1 – Example – Main chamber with a glove box for external operation 21
Figure A.2 – See-through of example chamber 22
Figure B.1 − Graphical representation for decay curves 23

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HOUSEHOLD AND SIMILAR ELECTRICAL AIR CLEANING APPLIANCES – METHODS FOR MEASURING THE PERFORMANCE –

Part 3-1: Method for assessing the reduction rate of key bioaerosols by portable air cleaners using an aerobiology test chamber

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

A PAS is an intermediate specification made available to the public and needing a lower level of consensus than an International Standard to be approved by vote (simple majority).

IEC PAS 63086-3-1 has been processed by subcommittee 59N: Electrical air cleaners for household and similar purposes, of IEC technical committee 59: Performance of household and similar electrical appliances, in co-operation with ISO technical committee 142: Cleaning equipment for air and other gases.

It is published as a double logo PAS.

It is based on ANSI/AHAM AC-5-2022.

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

The text of this PAS is based on the following document:	This PAS was approved for publication by the P-members of the committee concerned as indicated in the following document
Draft PAS	**Report on voting**
59N/28/DPAS	59N/33/RVDPAS

Following publication of this PAS, which is a pre-standard publication, the technical committee or subcommittee concerned may transform it into an International Standard.

This PAS shall remain valid for an initial maximum period of 2 years starting from the publication date. The validity may be extended for a single period up to a maximum of 2 years, at the end of which it shall be published as another type of normative document, or shall be withdrawn.

Words in **bold** type in the text are defined in Clause 3.

A list of all parts in the IEC 63086 series, published under the general title *Household and similar electrical air cleaning appliances*, can be found on the IEC website.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

INTRODUCTION

This Publicly Available Specification (PAS) contains test procedures for measuring the reduction by the air cleaner of micro-organisms suspended in the air in the specified test chamber. It also prescribes a method for measuring the operating power and stand-by power of the air cleaner. The test procedures may be applied to any brand or model of household and similar electrical air cleaners within the stated confines of the standard limits of measurability for measuring performance.

The annexes to this PAS are included for informative purposes only unless the annexes are noted as normative.

Warning – The tests given in this document shall be performed by expert staff trained to handle microorganism-related techniques and in properly equipped laboratories under the supervision of a skilled microbiologist. Some of the test micro-organisms might be facultative pathogens for humans, animals and plants and require a laboratory of an appropriate bio-safety level. National and international safety procedures for working with infectious biomaterials shall be followed to prevent any contamination of laboratory staff, apparatus, working place or environment in compliance with national standards or regulations. This document does not purport to address all of the safety aspects, if any, associated with its use. It is the responsibility of the user to establish appropriate safety and health practices and ensure compliance with any national, regional or international regulatory conditions.

This PAS may involve hazardous materials, operations and equipment. This PAS does not purport to address all of the safety problems associated with its use. It is the responsibility of whoever uses this PAS to consult and establish appropriate safety and health practices and determine the applicability of any regulatory limitations prior to use.

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

HOUSEHOLD AND SIMILAR ELECTRICAL AIR CLEANING APPLIANCES – METHODS FOR MEASURING THE PERFORMANCE –

Part 3-1: Method for assessing the reduction rate of key bioaerosols by portable air cleaners using an aerobiology test chamber

1 Scope

This part of IEC 63086 specifies a method to evaluate the capability of portable household air cleaners to reduce the concentration and viability of key experimentally generated bioaerosols in a specified chamber.

Indoor air free of harmful microbes is important to the health of occupants. This is particularly relevant with regard to increased time spent indoors.

Air cleaners are used to reduce the concentrations of microorganisms in indoor air.

The efficiency of such air cleaners to reduce airborne microorganisms can be assessed in test chambers at controlled air temperature and relative air humidity.

The test is applicable to portable air cleaners commonly used in single room spaces such as those based on mechanical filtration, ultraviolet (UV), ionizers, photocatalytic oxidation, and ozone generators in-unit technology.

If the air cleaner does not claim to have the function of reducing microorganisms, this document may not be applicable unless it is being used to simply evaluate the performance.

This document deals with measurement procedures regarding the reduction of the microbial contamination related to electrical air cleaner appliances for household and similar use.

This document does not apply to appliances intended to be used in medical, veterinary, or pharmaceutical applications.

This document does not address sanitization, disinfection, or sterilization measures.

This document does not support, by itself any health-related claims or conclusions about prevention or treatment of a disease or health improvement.

NOTE 1 IEC 63086-3-1 is created for household and similar electrical air cleaners and is not intended to conflict with or replace standards for commercial or industrial consumers.

NOTE 2 In this document, we do not suggest performance test methods that measure the by-products of either the interaction between microbes or between the air cleaner and the microbes tested in this document. The formation of by-products is an important subject. The subject of measuring by-products is under study, and AHAM will address this in future documents.

NOTE 3 This document does not apply to appliances intended for use in medical treatment locations, such as surgical suites, laboratories, medical treatment rooms, etc.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

AVA Documents
Document Sharing Hub

IEC 63086-1:2020, *Household and similar electrical air cleaning appliances − Methods for measuring the performance − Part 1: General requirements*

ASTM E741-11:2017, *Standard Test Method for Determining Air Change in a Single Zone by Means of a Tracer Gas Dilution*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at https://www.electropedia.org/
- ISO Online browsing platform: available at https://www.iso.org/obp

3.1
air cleaner
electrically powered household, or similar, appliance that employs one or multiple technologies to reduce, destroy, and/or inactivate one or more types of indoor air pollutants

Note 1 to entry: The term "air purifier" is defined as an Electrically powered device that is basically built of a fan and a set of components possessing the ability to capture and/or (partially or totally) destroy air pollutants [Source: ISO 16000-36] but PAS 63086-3-1 has chosen to not use this term in this document as it may not be possible to totally destroy an air pollutant.]

[Source: IEC 63086-1:2020, 3.1, modified – "destroy, and/or inactivate" and the note to entry have been added]

3.2
background concentration
quantity of **microbes** in the chamber after the chamber has undergone cleaning and prior to any testing or addition of **microbes** via nebulization

3.3
bacteria
prokaryotic, single-celled, microscopic organism with peptidoglycan cell wall

3.4
bacteriophage or phage
group of **viruses** that infect **bacteria** or **fungi**

3.5
bioaerosol
airborne particle that is composed of or derived from biological matter (such as a bacterial cell, fungal or bacteria spore, **virus**, or endotoxin)

3.6
biological safety levels
BSL
series of protections relegated to autoclave-related activities that take place in particular biological labs

Note 1 to entry: This includes individual safeguards designed to protect laboratory personnel, as well as the surrounding environment and community. For BSL level expectations, a lab should follow the most recent version of the WHO Laboratory Biosafety Manual, the CDC Biosafety in Microbiological and Biomedical Laboratories (BMBL) or the Canadian Biosafety Standards and Guidelines.

Documents
Document Sharing Hub

Full document details: PD IEC PAS 63086-3-1:2023

3.7
CADR
clean air delivery rate
measure of **air cleaner** performance by this test procedure

Note 1 to entry: Clean Air Delivery Rate (CADR) is defined as the measure of the delivery of contaminant-free air, within the defined particle size range, by an **air cleaner**, expressed in cubic feet per minute (cfm) or cubic meters per hour. Clean Air Delivery Rates are the rates of contaminant reduction in the test chamber when the **air cleaner** is turned on, minus the rate of **natural decay** when the **air cleaner** is not running, multiplied by the volume of the test chamber as measured in cubic feet or cubic meters (see 8.5). CADR values are always the measurement of an **air cleaner** performance as a complete system, and they have no linear relationship to air movement per se or to the characteristics of any particular particle removal methodology.

Note 2 to entry: For this document, we use the designation of m-CADR which is the clean air delivery rate for microbes.

3.8
colony forming units for bacteria and fungi
CFU
unit of measurement by which the number of culturable **microbes** (***Bacteria*** *and* ***fungi****)* is expressed

3.9
device under test
DUT
test sample of the **air cleaner** undergoing examination

3.10
fungi
multicellular eukaryotic organisms without chlorophyll and with cell walls

3.11
impaction
sampling of the airborne **microbe** by inertial separation on a semisolid agar surface

3.12
impinger method
glass or plastic device for the collection of air samples into a liquid medium through a scrubbing action.

Note 1 to entry: The liquid volume is subsequently utilized for dilution and inoculation of counting plates.

3.13
initial concentration
concentration of **microbes** inside the chamber immediately at the start time of sampling of either the **natural decay** or the total decay

3.14
maximum performance mode
through manual operation the DUT is set to the highest flow rate with all air cleaning functions switched on, set to maximum, where applicable, and with all filters in place

Note 1 to entry: If the DUT has zero flow rate, the m-CADR is measured with all air cleaning functions switched on.

3.15
microbes
microorganisms
microscopic living beings that cannot be seen with the naked eye, including **bacteria**, protozoa, **viruses** and **some fungi**/fungal components

Note 1 to entry: They are common in the environment as well as in/on our own bodies.

Documents
Document Sharing Hub
Full document details: PD IEC PAS 63086-3-1:2023