PD IEC TR 61000-4-40:2020

BSI Standards Publication

Electromagnetic compatibility (EMC)

Part 4-40: Testing and measurement techniques — Digital methods for the measurement of power quantities of modulated or distorted signals

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

National foreword

This Published Document is the UK implementation of IEC TR 61000-4-40:2020.

The UK participation in its preparation was entrusted to Technical Committee GEL/210/11, EMC - Standards Committee.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 580 91894 0

ICS 33.100.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 March 2020.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

IEC TR 61000-4-40

Edition 1.0 2020-03

TECHNICAL REPORT

colour inside

Electromagnetic compatibility (EMC) – Part 4-40: Testing and measurement techniques – Digital methods for the measurement of power quantities of modulated or distorted signals

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 33.100.01

ISBN 978-2-8322-7907-6

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

This page deliberately left blank

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
4 General 7
5 Modulated sine waveforms used in this document to compare measurement algorithms 9
5.1 General 9
5.2 Half-wave rectification 10
5.3 Full-wave rectification 10
5.4 Multi-cycle symmetrical control 11
5.5 Random on-off control 12
6 Measurement algorithms 12
6.1 General 12
6.2 Averaging algorithms 12
6.2.1 General 12
6.2.2 Performance of the averaging algorithm 13
6.2.3 Instrumental errors of the averaging algorithm 18
6.3 Smoothing filter algorithm 19
6.3.1 Frequency and step response 19
6.3.2 Verification of the smoothing filter algorithm 21
6.3.3 Instrumental errors of the filtering algorithm 25
7 Conclusions 25
Annex A (informative) Smoothing filter studied in this document 27
A.1 Algorithm 27
A.2 General C++ class program code 31
Bibliography 34

Figure 1 – Typical resistive load current and supply voltage waveform of half-wave rectification 10
Figure 2 – Typical full-bridge rectifier current and supply voltage waveforms 11
Figure 3 – Current and voltage patterns in an MCSC circuit, (left) 1/3 MCSC and (right) 2/3 MCSC 11
Figure 4 – Amplitude of 50 Hz current with on and off periods varying within a 1 min to 2 min range 12
Figure 5 – Step response of an algorithm in Formula (6) with a half-cycle, 1-cycle and 10-cycle measurement interval 14
Figure 6 – RMS current and active power for half-wave rectification 15
Figure 7 – Sliding average RMS current and active power of a device controlled with a 1/3 MCSC circuit 15
Figure 8 – Worst case 1/3 MCSC circuit active power calculation variation 16
Figure 9 – Example of a 10 min sliding average power calculation for a load having a 92 s period 17
Figure 10 – Active power of randomly fluctuating load averaged over a sliding 10 min interval 18

AVA Documents
Document Sharing Hub
Full document details: PD IEC TR 61000-4-40:2020

Figure 11 – Sensitivity of the full-bridge rectifier RMS current and active power measurement to time interval error of single-cycle sliding average calculation 19

Figure 12 – Comparison of the first and the 10th order filters used to estimate RMS current of a step signal 20

Figure 13 – Filter frequency responses 20

Figure 14 – Filter step responses 20

Figure 15 – Output of the 10th order smoothing filter used to calculate the active power of a signal with a step change 21

Figure 16 – Delay and response time of a 10th order filter used to assess the sinusoidal current of a sinusoidal waveform 22

Figure 17 – Measurement of the current and power of a half-wave rectified signal using a smoothing filter with a 10 Hz cut-off frequency 22

Figure 18 – Power quantities in full wave rectification assessed using a smoothing filter with 16,667 Hz cut-off frequency 23

Figure 19 – MCSC 1/3 pattern power quantities filtered with approximately 5,556 Hz cut-off frequency 23

Figure 20 – Active power of a load having a 92 s period measured with different algorithms 24

Figure 21 – Active power of randomly fluctuating load measured using different algorithms 25

Table 1 – Calculated power of 2/3 MCSC for different measurement windows 16

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-40: Testing and measurement techniques – Digital methods for the measurement of power quantities of modulated or distorted signals

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61000-4-40, which is a Technical Report, has been prepared by subcommittee SC77A: EMC – Low frequency phenomena, of IEC technical committee TC 77: Electromagnetic compatibility.

The text of this Technical Report is based on the following documents:

Enquiry draft	Report on voting
77A/1055/DTR	77A/1065/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

AVA Documents
Document Sharing Hub

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61000 series, published under the general title *Electromagnetic compatibility (EMC)*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

INTRODUCTION

IEC 61000 is published in separate parts, according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description levels

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts, published either as International Standards, Technical Specifications or Technical Reports, some of which have already been published as sections. Others are and will be published with the part number followed by a dash and a second number identifying the subdivision (example: IEC 61000-6-1).

This document gives the rationale for the assessment of electrical power quantities (RMS voltage, RMS current and active power) under non-stationary conditions. It explains and compares two digital methods that can be used in digital measurement instrumentation to either average or filter the signals when measuring fluctuating loads, and algorithms for the realization of both methods. The examples relate to 50 Hz or 60 Hz power systems because power quantity assessments are predominantly required for these systems.

The digital averaging or integration algorithm is evaluated for fluctuating, or non-stationary, conditions, as is a digital filtering algorithm that emulates the traditional analogue power meter.

This document aims to illustrate the application of the two measurement algorithms given above to characterize existing, and commonly found, non-stationary loads, which have been selected to help interpret the measurement results obtained using both algorithms.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-40: Testing and measurement techniques – Digital methods for the measurement of power quantities of modulated or distorted signals

1 Scope

This part of IEC 61000, which is a Technical Report, deals with the assessment of electrical power quantities (RMS voltage, RMS current and active power). It explains and compares two digital algorithms suitable for power quantity measurements in fluctuating or non-periodic loads. The examples are from 50 Hz or 60 Hz power systems.

This document does not attempt to cover all possible digital implementations of the algorithms used for power quantity assessment in fluctuating loads, for example in the context of the EMC assessment described in several IEC documents. Rather, it compares averaging with one of the filtering algorithms. This document aims to highlight some examples of applications that illustrate how the presented algorithms work. Further, guidance is given for quantifying the accuracy of each approach.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the cited edition applies. For undated references, the latest edition of the referenced document applies, including any amendments.

IEC TR 61000-1-7:2016, *Electromagnetic compatibility (EMC) – Part 1-7: General – Power factor in single phase systems under non-sinusoidal conditions*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC TR 61000-1-7 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

4 General

IEC TR 61000-1-7:2016, 3.1, defines the root-mean square (RMS) value of a time-dependent quantity as a positive square root of the mean value of the square of the quantity taken over a given time interval.

IEC TR 61000-1-7:2016, 5.1.4, further states that the RMS value of the voltage U (current I) is defined as the positive square root of the mean value of the square of the voltage $u(t)$ (current $i(t)$) taken over an integer number of periods kT of the AC power supply system:

Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020

$$U = \sqrt{\frac{1}{kT} \int_{\tau}^{\tau+kT} \left[u(t)\right]^2 \, dt} \tag{1}$$

$$I = \sqrt{\frac{1}{kT} \int_{\tau}^{\tau+kT} \left[i(t)\right]^2 \, dt} \tag{2}$$

where

T is the reciprocal of the reference fundamental frequency;

k is an integer number;

τ is the time when the measurement starts.

Similarly, the active power is defined in IEC TR 61000-1-7 as the mean value, taken over an integer number of periods kT, of the instantaneous power $p(t) = u(t)\ i(t)$:

$$P = \frac{1}{kT} \int_{\tau}^{\tau+kT} p(t) \ \ dt \tag{3}$$

In digital instrumentation, the assessment of the RMS value of voltage or current is performed by first obtaining the squares of the sampled values of the signal. Similarly, for the assessment of active power the products of each pair of the instantaneous voltage $u(t)$ and current $i(t)$ samples are obtained. Then the instrument performs the integration of the squared or multiplied samples over the measurement time interval. To adhere to IEC TR 61000-1-7, the measurement time interval is normally set to an integer multiple of the period of the power system fundamental frequency, but many instruments permit the user to select arbitrary time intervals. Further, for AC power systems, such as 50 Hz or 60 Hz public supply networks, the values of non-active power and apparent power can be derived from the obtained RMS values of current, voltage and active power.

For a sinusoidal signal, the multiplication of voltage and current, or the squaring operation, gives a function whose period is half of the period of the sine wave. This function contains a zero-frequency (DC) component that is equal to the active power or the square of the RMS value. In addition to the desired DC component, there is also an AC component at twice the frequency of the sine wave that it is essential to remove, or at least heavily attenuate, to retrieve the DC value.

Historically, instruments for the measurement of power quantities were implemented in an analogue form, using certain characteristics of thermal, magnetic or electrical components. In moving iron meters, for example, the squaring step is realised through a magnetic force applied to a vane made of iron. This magnetic force, proportional to the square of the current, is generated by a current flowing in a coil. When measuring a sinusoidal signal, the force oscillates at twice the frequency of the sine wave and causes the vane with its attached pointer to vibrate at the same frequency. To produce a stable reading, the assembly is mechanically damped (a smoothing function). The damper is analogous to a low-pass filter, decreasing oscillations caused by the alternating current. The measured RMS value is indicated on a non-linear scale devised according to the electromechanical properties of the meter.

Since the RMS value of an electric signal represents a heating effect, another analogue approach, implemented using thermal converters, is to heat a resistor (heater) with a voltage or a current applied across its terminals. The heater temperature is then measured with a thermocouple producing a DC voltage proportional to the square of the RMS current passing through the resistor. The thermal medium of the thermal converter smoothes the temperature measured by the thermocouple. Thus this thermal smoothing effect also behaves like a low-pass filter.

AVA Documents
Document Sharing Hub

Further modifications of these techniques, with two coils (electrodynamic wattmeters) or two or more thermal converters (thermal wattmeters and thermal power comparators), enable the measurement of active power in stationary conditions.

In analogue devices the processed signal is smoothed with the internal time constant of the meter, which allows for a steady reading of the result to be made for stationary input signals. Even with fluctuating loads, when the needle of the meter is not completely stable, it is often possible to determine the average value by observing where the variation is centred.

To obtain a similar result, the manufacturers of digital instruments usually add digital filtering to their measuring algorithms, which helps stabilize and/or average the readings. In the simplest form, the filtering is based on averaging over multiple periods of the signal. As the power system frequency is usually quite accurate, digital measurement instruments often use a constant measurement time interval corresponding to a multiple of the nominal period of the power system. For example, the 200 ms time interval specified in IEC 61000-4-7 corresponds to 10 cycles of a 50 Hz signal and 12 cycles of a 60 Hz signal. Further filtering can be obtained by using a digital implementation of the low-pass filter function. For example, in IEC 61000-4-7 a low-pass filter with a 1,5 s time constant was selected, partly because it reproduces the typical behaviour of a moving coil instrument.

When the period of the signal does not correspond to the nominal 50 Hz or 60 Hz power system frequency, readings from instruments that use a constant measurement time interval often show fluctuating results. For example, multi-cycle symmetrical control (MCSC) used in water heaters produces current waveforms with periods that are longer than the fundamental frequency period of the power system voltage feeding the device. Additionally, these MCSC controls can vary the control cycle from one instant to another as required, to maintain water temperature under different flow conditions. Another example is fluctuating loads, such as refrigerators, where compressor motors can be energised at random times, producing non-periodic currents. It is also noted that supply voltage frequency variations are common, for example, in isolated power systems having no electrical connections to a large interconnected system, such as is common in remote communities served by small generation sources.

To characterise the performance of various devices, many documents require the determination of reference current or power. Additionally, for various voltage quality assessments, specific measurement time intervals have been defined by IEC documents, such as half-cycle, 10 or 12 cycles for 50 Hz or 60 Hz power systems, 3 s, 10 min and 2 h.

Stable readings are often a prerequisite in order to obtain comparable results. In the case of fluctuating loads these are sometimes difficult to achieve using conventional voltage, current and power meters. In these situations the current and voltage can be recorded by data loggers and post-processed using, for example, spreadsheet software. Smoothing functions corresponding to the fluctuation rates can then be implemented as required. As data logger recordings are often limited in their duration, fast-settling filters are desirable.

This document compares one averaging and one filtering algorithm used to assess the power quantities for four typical groups of waveforms. For simplicity, the amplitude of the current waveform used in the study was adjusted to give an RMS current of 1 A. The voltage was also adjusted at the appropriate level to obtain an active power of 100 W.

5 Modulated sine waveforms used in this document to compare measurement algorithms

5.1 General

For an ideal sine wave with constant amplitude and frequency, most measurement algorithms would produce accurate results within the capabilities of the measuring instrument. The situation becomes more complicated if the sine wave is randomly modulated and/or contains distortion, as found in uncontrolled environments. Some examples of current waveforms produced by real-life equipment that challenge the assessment of power quantities are described in Clause 5. There exist even more complex situations that are not addressed in this document.

AVA Documents
Document Sharing Hub

Full document details: PD IEC TR 61000-4-40:2020