PD IEC TR 61400-21-3:2019

BSI Standards Publication

Wind energy generation systems

Part 21-3: Measurement and assessment of electrical characteristics — Wind turbine harmonic model and its application

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

National foreword

This Published Document is the UK implementation of IEC TR 61400-21-3:2019.

The UK participation in its preparation was entrusted to Technical Committee PEL/88, Wind turbines.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2019
Published by BSI Standards Limited 2019

ISBN 978 0 539 02201 8

ICS 27.180

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 September 2019.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

IEC TR 61400-21-3

Edition 1.0 2019-09

TECHNICAL REPORT

colour inside

Wind energy generation systems – Part 21-3: Measurement and assessment of electrical characteristics – Wind turbine harmonic model and its application

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ICS 27.180

ISBN 978-2-8322-7288-6

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 8
3 Terms, definitions and abbreviations 8
3.1 Terms and definitions 8
3.2 Abbreviations 12
4 General description 13
4.1 Overview 13
4.2 Background 14
5 Recommendations of minimal requirements 17
5.1 General 17
5.2 Application 18
5.3 Input parameters 18
5.4 Harmonic model terminal 18
5.5 Output variables 19
5.6 Structure 19
6 Interfaces to other IEC documents 20
6.1 IEC 61400-21-1:2019, Annex D – Harmonic evaluation 20
6.2 IEC 61400-21-1:2019, Annex E – Assessment of power quality of wind turbines and wind power plants 21
7 Harmonic model 21
7.1 General 21
7.2 Thévenin/Norton equivalent circuit 22
7.3 Equivalent harmonic voltage/current sources 22
7.3.1 General 22
7.3.2 Harmonic equivalent impedance 23
7.4 Wind turbine types 24
7.4.1 General 24
7.4.2 Type 1 and Type 2 24
7.4.3 Type 3 25
7.4.4 Type 4 26
8 Validation 28
8.1 General 28
8.2 Overview 28
8.3 Model validation 29
8.4 Fictitious grid 30
9 Limitations 30
Bibliography 32

Figure 1 – Example of a phase angle between the harmonic current and the harmonic voltage component as well as the fundamental voltage 9
Figure 2 – Example of wind power plant typical components relevant for the harmonic studies and potential challenges in harmonic performance 14
Figure 3 – Example of a WPP complex structure 15
Figure 4 – Example of a WPP complex electrical infrastructure with many WTs 16

AVA Documents
Document Sharing Hub

Figure 5 – Harmonic impedance estimated at the point of connection specified in Figure 4 17
Figure 6 – Generic harmonic model structure represented as Norton/Thévenin equivalent circuit 20
Figure 7 – Main electrical and mechanical components of Type 3 WTs [6] 25
Figure 8 – Example of a structure of a DFAG harmonic model (from [13]) 26
Figure 9 – Main electrical and mechanical components of Type 4 WTs [6] 26
Figure 10 – Example of a converter harmonic model as Thévenin equivalent circuit together with an example of a WT power circuit (from [9]) 27
Figure 11 – Harmonic voltage comparison for respective power bins 28

Table 1 – Example of a representation/template of the harmonic voltage source 23
Table 2 – Example of a representation/template of the harmonic current source 23
Table 3 – Example of a representation/template of the harmonic equivalent impedance 24

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

INTERNATIONAL ELECTROTECHNICAL COMMISSION

WIND ENERGY GENERATION SYSTEMS –

Part 21-3: Measurement and assessment of electrical characteristics – Wind turbine harmonic model and its application

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61400-21-3, which is a Technical Report, has been prepared by IEC Technical Committee 88: Wind energy generation systems.

The text of this Technical Report is based on the following documents:

DTR	Report on voting
88/698/DTR	88/717/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

AVA Documents
Document Sharing Hub

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61400 series, published under the general title *Wind energy generation systems*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

INTRODUCTION

The purpose of this IEC Technical Report (TR) is to provide a methodology that will ensure understanding, consistency and accuracy in application, structure and validation of the harmonic model of grid connected wind turbines (WTs).

There is an understandable requirement from wind power industry shareholders, e.g. transmission system operators (TSOs) and distribution system operators (DSOs), wind power plant (WPP) developers, WT manufacturers, WT component suppliers, academic units, research institutions, certifying bodies and standardization groups (e.g. TC88 MT21), for having a standardized WT harmonic model.

The standardized harmonic model would find a broad application in many areas of electrical engineering related to design, analysis, and optimisation of electrical infrastructure of onshore as well as offshore WPPs. Among others, this could be the evaluation of the WT harmonic performance, system-level harmonic studies, electrical infrastructure design and proposal of harmonic mitigation measures.

Standardized WT harmonic models as a performance measure starts to be important in such multi stakeholder systems as large offshore WPPs where TSOs, WPP developers and operators as well as WT manufacturers need to have a common understanding about harmonic modelling of WTs and harmonic studies in WPPs.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

WIND ENERGY GENERATION SYSTEMS –

Part 21-3: Measurement and assessment of electrical characteristics – Wind turbine harmonic model and its application

1 Scope

This part of IEC 61400 provides guidance on principles which can be used as the basis for determining the application, structure and recommendations for the WT harmonic model. For the purpose of this Technical Report, a harmonic model means a model that represents harmonic emissions of different WT types interacting with the connected network.

This document is focused on providing technical guidance concerning the WT harmonic model. It describes the harmonic model in detail, covering such aspects as application, structure, as well as validation. By introducing a common understanding of the WT representation from a harmonic performance perspective, this document aims to bring the overall concept of the harmonic model closer to the industry (e.g. suppliers, developers, system operators, academia, etc.).

A standardized approach of WT harmonic model representation is presented in this document. The harmonic model will find a broad application in many areas of electrical engineering related to design, analysis, and optimisation of electrical infrastructure of onshore as well as offshore WPPs.

The structure of the harmonic model presented in this document will find an application in the following potential areas:

- evaluation of the WT harmonic performance during the design of electrical infrastructure and grid-connection studies;
- harmonic studies/analysis of modern power systems incorporating a number of WTs with line side converters;
- active or passive harmonic filter design to optimize electrical infrastructure (e.g. resonance characteristic shaping) as well as meet requirements in various grid codes;
- sizing of electrical components (e.g. harmonic losses, static reactive power compensation, noise emission, harmonic compatibility levels, etc.) within WPP electrical infrastructure;
- evaluation of external network background distortion impact on WT harmonic assessment;
- standardised communication interfaces in relation to WT harmonic data exchange between different stakeholders (e.g. system operators, generators, developers, etc.);
- universal interface for harmonic studies for engineering software developers;
- possible benchmark of WT introduced to the academia and the industry.

The advantage of having standardized WT harmonic performance assessment by means of the harmonic model is getting more and more crucial in case of large systems with different types of WTs connected to them, e.g. multi-cluster wind power plants incorporating different types of WTs connected to the same offshore or onshore substation.

The WT harmonic model can cover the integer harmonic range up to the 40th, 50th, or 100th. And can be expanded, depending on requirements and application, to higher harmonic range as well as can also cover interharmonic components.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-415:1999, *International Electrotechnical Vocabulary – Part 415: Wind turbine generator systems* (available at <http://www.electropedia.org/)

IEC TR 61000-3-6:2008, *Electromagnetic compatibility (EMC) – Part 3-6: Limits – Assessment of emission limits for the connection of distorting installations to MV, HV and EHV power systems*

IEC 61000-4-7:2002, *Electromagnetic compatibility (EMC) – Part 4-7: Testing and measurement techniques – General guide on harmonics and interharmonics measurements and instrumentation, for power supply systems and equipment connected thereto*

IEC 61400-21-1:2019, *Wind energy generation systems – Part 21-1: Measurement and assessment of electrical characteristics – Part 1 – Wind turbines*

3 Terms, definitions and abbreviations

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60050-415 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1.1
compatibility levels
reference levels of a particular disturbance in a particular environment defined for co-ordinating the emission and immunity of equipment which is part of, or supplied by, a supply system in order to ensure the EMC in the whole system (including system and connected equipment)

Note 1 to entry: Compatibility levels are generally based on the 95 % probability levels of entire systems, using statistical distributions which represent both time and space variations of disturbances.

Note 2 to entry: There is allowance for the fact that the system operator or owner cannot control all points of a system at all times. Therefore, evaluation with respect to compatibility levels should be made on a system-wide basis and no assessment method is provided for evaluation at a specific location.

3.1.2
factor K
indicator of the ability of a transformer to be loaded with non-sinusoidal currents

Note 1 to entry: The equivalent power rating is equal to the power based on the RMS value of the non-sinusoidal current multiplied by the factor K.

[SOURCE: EN 50464-3:2007, modified – additional elaboration, creation of a note to entry and deletion of the formula]

Documents
Document Sharing Hub

Full document details: PD IEC TR 61400-21-3:2019

3.1.3
harmonic phase or angle
phase (angle) α_h of the spectral component y_h, that is, the phase between the harmonic current component or harmonic voltage component and the fundamental component voltage defined in Figure 1 and equation below

$$y_h = c_h \sin\left(h\omega_1 t + \alpha_h\right)$$

where c_h is the spectral component magnitude



Figure 1 – Example of a phase angle between the harmonic current and the harmonic voltage component as well as the fundamental voltage

Note 1 to entry: The sign convention used for the voltages and currents is the generator convention as defined in IEC 61400-21-1:2019, Annex C.

Note 2 to entry: Please check IEC 61400-21-1:2019, Annex D for more details.

3.1.4
harmonic distortion
cyclic departure of a waveform from the sinusoidal shape

Note 1 to entry: This can be described by the addition of one or more harmonics to the fundamental.

3.1.5
harmonic model
model that represents harmonic emissions of a WT interacting with the connected network

Note 1 to entry: Different WT types may be modelled by changing the model parameters.

3.1.6
harmonic model terminals
reference point on the electric power system where here the harmonic model is connected

3.1.7
negative-sequence component of 3-phase voltages (or currents)
symmetrical vector system derived by application of the Fortescue's transformation matrix, and that rotates in the opposite direction to the power frequency voltage (or current)

[SOURCE: IEC TR 61000-3-13:2008, 3.26.4, modified – the formula has been deleted]

3.1.8
operational mode
<wind turbine> operation according to control setting, for example voltage control mode, frequency control mode, reactive power control mode, active power control mode, etc.

[SOURCE: IEC 61400-21-1:2019, 3.9]

Documents
Document Sharing Hub
Full document details: PD IEC TR 61400-21-3:2019