PD IEC TR 61547-1:2020

BSI Standards Publication

Equipment for general lighting purposes — EMC immunity requirements

Part 1: Objective light flickermeter and voltage fluctuation immunity test method

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

National foreword

This Published Document is the UK implementation of IEC TR 61547-1:2020. It supersedes PD IEC/TR 61547-1:2017, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee CPL/34, Lamps and Related Equipment.

A list of organizations represented on this committee can be obtained on request to its committee secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 539 04312 9

ICS 29.140.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 July 2020.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

IEC TR 61547-1

Edition 3.0 2020-07

TECHNICAL REPORT

colour inside

Equipment for general lighting purposes – EMC immunity requirements – Part 1: Objective light flickermeter and voltage fluctuation immunity test method

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.140.20

ISBN 978-2-8322-8532-9

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

CONTENTS

FOREWORD 5
INTRODUCTION 7
1 Scope 8
2 Normative references 8
3 Terms, definitions, abbreviated terms and symbols 9
3.1 Terms and definitions 9
3.2 Abbreviated terms 10
3.3 Symbols 11
4 General 11
5 Light flickermeter 13
6 Voltage fluctuation disturbance signal 13
6.1 General 13
6.2 Mains signal parameters 14
6.3 Disturbance signal parameters and test levels 15
7 Test setup and equipment 16
7.1 General 16
7.2 Test voltage 17
7.3 Optical test environment 17
7.4 Light sensor and amplifier 18
7.5 Signals to be measured 18
7.6 Signal processing 18
7.6.1 Anti-aliasing filter 18
7.6.2 Sampling frequency 19
7.6.3 Signal resolution 19
8 Verification procedure 21
8.1 General 21
8.2 Light flickermeter 21
8.3 Mains voltage parameters without modulation 22
8.3.1 Nominal voltage level 22
8.3.2 Mains frequency 22
8.4 Voltage fluctuation level 22
8.4.1 General 22
8.4.2 Option 1: measure the actual modulation frequencies and voltage levels 22
8.4.3 Option 2: measure P_{st}^{V} values using a flickermeter 22
8.5 Light sensor and amplifier 23
8.6 Test environment 23
8.7 Light flicker noise 23
9 Test procedure 24
9.1 General 24
9.2 Measuring the intrinsic flicker performance 25
9.3 Testing the flicker immunity against voltage fluctuations 26
9.4 Dimmer compatibility testing 26
9.5 Controlgear testing 27
10 Conditions during testing 27
11 Evaluation of the test result 28

AVA Documents
Document Sharing Hub

12 Test report 28
Annex A (informative) Specification of the light flickermeter 29
A.1 Voltage flickermeter modifications 29
A.2 Specification of the light flickermeter 30
A.2.1 General 30
A.2.2 Block a: illuminance adapter 30
A.2.3 Block b: weighting filters 30
A.2.4 Block c: squaring multiplier, sliding mean filter and scaling 31
A.2.5 Block d: statistical analysis 31
A.3 Verification of the light flickermeter 32
A.4 Example of P_{st}^{LM} implementation in MATLAB® 33
Annex B (informative) Uncertainty considerations 34
B.1 General 34
B.2 General symbols 34
B.3 Measurand 34
B.4 Influence quantities 34
B.5 Uncertainty budget 36
Annex C (informative) Examples of test results of lighting equipment 38
C.1 Test without voltage fluctuations (P_{st}^{LM}) 38
C.2 Test with (intentional) voltage fluctuations P_{st}^{LM} (I) 38
C.3 Test under dimming conditions 42
Annex D (informative) Guidance for P_{st}^{LM} testing based on test type 44
Bibliography 45

Figure 1 – Full EMC approach for mains voltage fluctuations 12
Figure 2 – Illustration of the mains test signal including a rectangular modulated voltage fluctuation (see Equation (1)) 14
Figure 3 – Block diagram voltage-fluctuation immunity test 17
Figure 4 – Example of a recorded mains voltage fluctuation and illuminance signal of a 60 W incandescent lamp 21
Figure 5 – Measuring P_{st}^{LM} 26
Figure 6 – Measuring P_{st}^{LM} (I) 26
Figure 7 – Dimmer compatibility testing 26
Figure 8 – Controlgear testing 27
Figure A.1 –Structure of the IEC 61000-4-15 flickermeter that uses voltage as input 29
Figure A.2 – Structure of the light flickermeter based on a modified voltage flickermeter 29
Figure A.3 – Flickermeter response to different waveshapes 33
Figure C.1 – Graphical $P_{st}^{LM}(I)$ results for three EUTs with rectangular modulation at five frequencies ($P_{st}^{V} = 1$) 39
Figure C.2 – EUT1: recorded signals (no mains voltage modulation) 40
Figure C.3 – EUT1: recorded signals (with modulation) 41

Documents
Document Sharing Hub
Full document details: PD IEC TR 61547-1:2020

Figure C.4 – EUT2: relative illuminance – Mains voltage modulation d = 0,407 % at 13,5 Hz ($P_{st}^{V} = 1$) 42

Figure C.5 – EUT3: relative illuminance – Mains voltage modulation d = 0,407 % at 13,5 Hz ($P_{st}^{V} = 1$) 42

Figure C.6 – Graphical P_{st}^{LM} (C) results for four EUTs under dimming conditions 43

Table 1 – Voltage fluctuations – Test specification of voltage fluctuations applied at input AC mains 120/230 V and 50/60 Hz 16

Table 2 – Guidance for P_{st}^{LM} testing 25

Table A.1 – Test specification of illuminance fluctuations for lightmeter classifier 32

Table B.1 – Influence quantities and their recommended tolerances 35

Table B.2 – Uncertainty budget of the voltage fluctuation immunity test 37

Table C.1 – Numerical results P_{st}^{LM} calculations for three EUTs without voltage modulation 38

Table C.2 – Numerical results P_{st}^{LM} (I) calculations for three EUTs with voltage modulation 38

Table C.3 – Numerical results P_{st}^{LM} (C) calculations for four EUTs under dimming conditions 43

Table D.1 – Guidance for P_{st}^{LM} testing based on test conditions 44

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EQUIPMENT FOR GENERAL LIGHTING PURPOSES – EMC IMMUNITY REQUIREMENTS –

Part 1: Objective light flickermeter and voltage fluctuation immunity test method

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a Technical Report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 61547-1, which is a Technical Report, has been prepared by IEC technical committee 34: Lighting.

This third edition cancels and replaces the second edition published in 2017. This edition constitutes a technical revision.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

This edition includes the following significant technical changes with respect to the previous edition:

a) the scope of this document has been clarified to make a distinction between flicker testing without voltage fluctuations to measure the intrinsic performance of lighting equipment and flicker testing in which a specific set of voltage fluctuations are applied in order to measure the immunity of the lighting equipment to voltage fluctuations present on the mains;

b) the test procedure for flicker testing has been clarified.

The text of this Technical Report is based on the following documents:

Draft TR	Report on voting
34/668/DTR	34/701/RVDTR

Full information on the voting for the approval of this Technical Report can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 61547 series, published under the general title *Equipment for general lighting purposes – EMC immunity requirements*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

INTRODUCTION

The fast rate at which solid state light (SSL) sources can change their intensity is one of the main drivers behind the revolution in the lighting world and applications of lighting. Linked to the fast rate of the intensity change is a direct transfer of the modulation of the driving current, both intended and unintended, to a modulation of the luminous output. This light modulation can give rise to changes in the perception of the environment. While in some very specific entertainment, scientific or industrial applications a change of perception due to light modulation is desired, for most everyday applications and activities the change is detrimental and undesired. These changes in the perception of the environment are called "temporal light artefacts" (TLAs) and can have a large influence on the judgment of the light quality. Moreover, the visible modulation of light can lead to a decrease in performance, increased fatigue as well as health problems like epileptic seizures and migraine episodes [17][18][1].

Different terms exist to describe the different types of TLAs that may be perceived by humans. The term "flicker" refers to light variation that may be directly perceived by an observer. "Stroboscopic effect" is an effect which may become visible for an observer when a moving or rotating object is illuminated (CIE TN 006:2016 [26]).

Possible causes for light modulation of lighting equipment that may give rise to flicker or stroboscopic effect are:

– AC supply combined with light source technology and its driver topology;
– light regulation technology of externally applied light level regulators or internal light level regulators;
– mains voltage fluctuations caused by electrical apparatus connected to the mains (conducted electromagnetic disturbances) or intentionally applied for mains-signalling purposes.

Lighting products that show unacceptable flicker are considered as poor-quality lighting.

This document provides a description of an objective light flickermeter and a method for measuring the intrinsic flicker of lighting equipment as well as testing the immunity of lighting equipment against mains voltage fluctuations caused by electrical apparatus connected to the mains at levels that are allowed through IEC 61000-3-3.

Flicker perception, as well as IEC 61000-3-3 and IEC 61000-4-15, the associated standards for voltage fluctuations and the flickermeter, are based on the 60 W incandescent lamp. As a result of the phasing out of incandescent lamps and the widespread introduction of alternative lighting equipment technologies, a new reference lamp was considered. It has been demonstrated that new lighting technologies are in general less but sometimes also more sensitive to supply voltage fluctuations than the current 60 W incandescent lamp. A CIGRE working group has assessed the impact of new lighting technologies on the existing flicker standards [16]. For the moment, the present flicker sensitivity curve of IEC 61000-3-3 remains as the reference. However, because of the increased diversity of sensitivity of lighting equipment to voltage fluctuations, there is a future need for a voltage-fluctuation immunity test specifically for lighting equipment. In this way, the full EMC approach (Figure 1) is introduced for flicker, i.e. with a view to limiting voltage fluctuations caused by equipment connected to the grid, and in addition to establishing a minimum level of flicker immunity of lighting equipment against these voltage fluctuations.

This document will allow the lighting industry to gain experience in flicker immunity test methods. Results of actual tests will be reported in a separate IEC Technical Report. Based on the experience gained on this immunity test method, the adoption of a similar test to be applied for IEC 61547, the immunity standard for lighting equipment, will be considered.

[1] Numbers in square brackets refer to the Bibliography.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

EQUIPMENT FOR GENERAL LIGHTING PURPOSES – EMC IMMUNITY REQUIREMENTS –

Part 1: Objective light flickermeter and voltage fluctuation immunity test method

1 Scope

This part of IEC 61547 describes an objective light flickermeter, which can be applied for the following purposes:

– measuring the intrinsic performance of all lighting equipment without the application of voltage fluctuations in terms of illuminance flicker; during this measurement, the lighting equipment is supplied with a stable mains;

– testing the immunity performance of lighting equipment against (unintentional) voltage fluctuation disturbance on the AC mains in terms of illuminance flicker; during this test a set of defined voltage fluctuations are applied to the AC mains and the immunity of the lighting equipment to the disturbance is determined.

Apart from the above two purposes, the immunity performance of lighting equipment can also be tested against intentional voltage fluctuation on the AC mains arising for example from mains signalling. This is however not described in further detail in this document.

NOTE 1 IEC 61000-4-13:2015 [24] provides guidance regarding test levels and frequencies for mains signalling.

The object of this document is to establish a common and objective reference for evaluating the performance of lighting equipment in terms of illuminance flicker. Temporal changes in the colour of light (chromatic flicker) are not considered in this test.

This method can be applied to lighting equipment which is within the scope of IEC technical committee 34, such as lamps and luminaires, intended for connection to a low voltage electricity supply. Independent auxiliaries such as drivers can also be tested by application of a representative light source to that auxiliary.

The objective light flickermeter and voltage fluctuation immunity method described in this document are based on the IEC 61000-3-3 standard for voltage fluctuation limits and the flickermeter standard IEC 61000-4-15.

The objective light flickermeter described in this document can be applied to objectively assess flicker of lighting equipment that is powered from any type of source, AC mains, DC mains, battery fed or fed through an external light level regulator. The specific voltage fluctuation immunity test method described in this document applies to lighting equipment rated for 120 V AC and 230 V AC, 50 Hz and 60 Hz.

NOTE 2 The principle of the method can be applied for other nominal voltages and frequency ratings.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Documents
Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020

IEC 61000-3-3:2013, *Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection*

IEC 61000-4-15:2010, *Electromagnetic compatibility (EMC) – Part 4-15: Testing and measurement techniques – Flickermeter – Functional and design specifications*

3 Terms, definitions, abbreviated terms and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61000-3-3 and IEC 61000-4-15 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1.1
flicker
perception of visual unsteadiness induced by a light stimulus the luminance or spectral distribution of which fluctuates with time, for a static observer in a static environment

Note 1 to entry: The fluctuations of the light stimulus with time include periodic and non-periodic fluctuations and can be induced by the source itself, the power source or other influencing factors.

[SOURCE: CIE TN 006:2016]

3.1.2
flickermeter
instrument designed to measure any quantity representative of flicker

[SOURCE: IEC 60050-614:2016, 614-01-30]

3.1.3
voltage flickermeter
instrument which is designed to measure any quantity representative of flicker resulting from mains voltage fluctuations

Note 1 to entry: Specifications of the voltage flickermeter can be found in IEC 61000-4-15.

3.1.4
illuminance
quotient of the luminous flux $\mathrm{d}\Phi_\mathrm{v}$ incident on an element of the surface containing the point, by the area $\mathrm{d}A$ of that element

Equivalent definition. Integral, taken over the hemisphere visible from the given point, of the expression $L_\mathrm{v} \cdot \cos\theta \cdot \mathrm{d}\Omega$ where L_v is the luminance at the given point in the various directions of the incident elementary beams of solid angle $\mathrm{d}\Omega$, and θ is the angle between any of these beams and the normal to the surface at the given point

$$E_\mathrm{v} = \frac{\mathrm{d}\Phi_v}{\mathrm{d}A} = \int_{2\pi\ \mathrm{sr}} L_\mathrm{v} \cdot \cos\theta \cdot \mathrm{d}\Omega$$

Note 1 to entry: Illuminance is expressed in lx or $\mathrm{lm \cdot m^{-2}}$.

Documents
Document Sharing Hub
Full document details: PD IEC TR 61547-1:2020

[SOURCE: IEC 60050-845:1987, 845-01-38]

3.1.5
light flickermeter
instrument designed to measure flicker resulting from temporal changes in the intensity of the light in an objective way

Note 1 to entry: The light flickermeter is based on the IEC 61000-4-15 specifications.

3.1.6
threshold of flicker irritability
maximum value of a fluctuation of luminance or of spectral distribution which gives rise to a flicker tolerated without discomfort by a specified sample of the population

[SOURCE: IEC 60050-161:1990, 161-08-16]

3.1.7
short-term flicker indicator
P_{st}
measure of flicker evaluated over a specified time interval of a relatively short duration

Note 1 to entry: The duration is typically 10 min, in accordance with IEC 61000-4-15.

Note 2 to entry: The alternative term "short term flicker severity" is used in IEC 61000-3-3 and IEC 61000-4-15.

[SOURCE: IEC 60050-161:1990, 161-08-18, modified – Note 2 has been added.]

3.2 Abbreviated terms

AC	alternating current
CFL	compact fluorescent lamp
CIE	Commission Internationale de l'Éclairage
cpm	changes per minute
DC	direct current
EUT	equipment under test
EMC	electromagnetic compatibility
Hz	hertz
IEEE	Institute of Electrical and Electronics Engineers
kHz	kilohertz
LED	light emitting diode
ms	millisecond
RMS	root mean square
SSL	solid state lighting
V	volt
W	watt

Documents
Document Sharing Hub
Full document details: PD IEC TR 61547-1:2020

3.3 Symbols

α	multiplication factor
C_A	gain of the light amplifier
d	relative voltage change
d_E	relative change of the rectangular modulation of the illuminance
d_r	relative change of the 100 Hz-illuminance ripple
ΔL	instantaneous total light variation after a voltage fluctuation
Δu	instantaneous total voltage variation after a voltage fluctuation
ΔU	total voltage variation of the half-period RMS value after a voltage fluctuation
f	mains frequency (50 Hz or 60 Hz)
f_m	modulation frequency
L	light
m	modulation index
%	percent
pp	percentage point
P_{inst}	instantaneous flicker sensation
P_{st}	short-term flicker indicator
P_{st}^{LM}	flicker metric of the illuminance of an EUT without the application of voltage fluctuations and measured with a light flickermeter
$P_{st}^{LM}(I)$	flicker metric of the illuminance of an EUT with the application of voltage fluctuations and measured with a light flickermeter
$P_{st}^{LM}(C)$	flicker metric of the illuminance of the combination of a light source and a dimmer measured with a light flickermeter
P_{st}^{V}	flicker metric of the supply voltage measured with a voltage flickermeter
$P_{st}^{V}(N)$	flicker metric of the noise level from an unmodulated supply voltage measured with a voltage flickermeter
s	complex Laplace variable
$\hat{u}$	amplitude of the mains voltage
$u(t)$	mains voltage signal
$u_E(t)$	output voltage of the light sensor amplifier
T_m	modulation period
T_{test}	period of time over which the illuminance is measured during application of the voltage fluctuation
U	half-period RMS-value

4 General

The immunity of lighting equipment to voltage fluctuations may be tested by applying specific types and levels of voltage fluctuations to the mains, in accordance with the short-term flicker indicator $P_{st} = 1$ curve for the reference incandescent lamp of 60 W specified in IEC 61000-3-3. In this way, the full EMC approach is applied for flicker, i.e. voltage fluctuations caused by equipment connected to the grid are limited by the voltage fluctuation emission test of IEC 61000-3-3, while the level of flicker immunity of lighting equipment

AVA Documents
Document Sharing Hub
Full document details: PD IEC TR 61547-1:2020

against these P_{st}^{V} = 1 voltage fluctuations is tested using the method specified in this document (see Figure 1).

During the test, the supply voltage is modulated with a fluctuation of P_{st}^{V} = 1 which is extracted from the threshold of the flicker irritability curve. The luminous intensity variation of the lighting equipment is measured and recorded. A light flickermeter is applied to measure the value of the metric which is denoted by $P_{st}^{LM}(I)$, which indicates that the test is carried out with the application of voltage fluctuations and the letter I stands for immunity. Further details of the voltage fluctuations can be found in Table 1.

A flicker measurement can also be performed in order to determine the intrinsic flicker performance of the lighting equipment. During this test, a stable mains source (see 6.2) is used (i.e. no voltage fluctuations are applied). Similar to the above, the luminous intensity variation of the lighting equipment is measured and recorded. A light flickermeter is applied to measure the value of the metric which is denoted by P_{st}^{LM}.

NOTE In principle, flicker perfomance tests can be applied to an individual product as well as to test the flicker performance of installations in actual applications (in-situ). However, the latter in-situ testing is much more prone to measurement uncertainties due to various influence quantities such as ambient light, light modulations from other light sources or daylight or moving subjects and (undefined/irregular) voltage fluctuation on the network. Therefore, P_{st}^{LM} measurements are normally done at product level. The TLA performance of an actual application environment of multiple light sources is generally better than the TLA performance of a single light source due to the averaging out of the light modulation from the different light sources. Note that the flicker immunity test against voltage fluctuations ($P_{st}^{LM}(I)$) cannot be performed in-situ.



a) Voltage fluctuation emission test in IEC 61000-3-3, using the IEC voltage flickermeter in IEC 61000-4-15



b) Voltage fluctuation immunity test specified in this document

Figure 1 – Full EMC approach for mains voltage fluctuations

Documents
Document Sharing Hub
Full document details: PD IEC TR 61547-1:2020

5 Light flickermeter

For an objective assessment of flicker due to low-frequency light modulation, the flickermeter specified in Annex A is used. Additional requirements for this light flickermeter are given in 7.3, 7.4, 7.5 and 7.6.

This light flickermeter can be applied to objectively assess the flicker of lighting equipment that is powered from any type of source, AC mains, DC mains, battery powered or powered through an external light level regulator. In this document, specific mains voltage disturbance signals are given in Clause 6 for 120 V AC and 230 V AC, 50 Hz and 60 Hz networks.

6 Voltage fluctuation disturbance signal

6.1 General

The immunity test against voltage fluctuations is carried out in accordance with the test method specified in Clause 7. The disturbances are rectangular amplitude modulations that are applied on the AC mains.

The mains signal is amplitude modulated with rectangular signals with frequencies between approximately 0,3 Hz and 40 Hz. For the rectangular modulated mains signal $u(t)$, the following Equation (1) applies:

$$u(t) = \hat{u} \cdot \sin(2\pi f t) \cdot \{1 + m \cdot \text{signum}\,(\sin(2\pi f_m t))\} \tag{1}$$

where

$\hat{u}$ is the amplitude of the mains voltage;

f is the mains frequency;

m is the modulation index;

signum(x) = the signum function, signum(x) = 1 for $x > 0$
signum(x) = 0 for $x = 0$
signum(x) = –1 for $x < 0$

f_m is the modulation frequency = $1/T_m$.

Furthermore, the half-period RMS value U of the unmodulated mains signal can be written as:

$$U = \hat{u} / \sqrt{2} \tag{2}$$

In IEC 61000-4-15, the relative voltage change d is applied:

$$d = \Delta u / \hat{u} = \Delta U / U\,, \tag{3}$$

for rectangular amplitude modulation with modulation frequencies $< f$

where

Δu is the instantaneous total voltage variation after a voltage fluctuation;

ΔU is the total voltage variation of the half-period RMS value after a voltage fluctuation.

For a rectangular modulated mains signal with modulation index m the relative voltage change d is:

AVA Documents Document Sharing Hub

Full document details: PD IEC TR 61547-1:2020