PD IEC/TS 61463:2016

BSI Standards Publication

Bushings — Seismic qualification

Documents
Document Sharing Hub

Full document details: PD IEC/TS 61463:2016

National foreword

This Published Document is the UK implementation of IEC/TS 61463:2016.

The UK participation in its preparation was entrusted to Technical Committee PEL/36, Insulators for power systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2016.
Published by BSI Standards Limited 2016

ISBN 978 0 580 87524 3
ICS 29.080.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 August 2016.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC/TS 61463:2016

IEC TS 61463

Edition 2.0 2016-07

TECHNICAL SPECIFICATION

Bushings – Seismic qualification

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.080.20

ISBN 978-2-8322-3518-8

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

Documents
Document Sharing Hub

Full document details: PD IEC/TS 61463:2016

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
4 Symbols and abbreviated terms 8
5 Methods of seismic qualification 9
6 Severities 10
6.1 At the ground 10
6.2 At the bushing flange 10
7 Qualification by static calculation 11
8 Qualification by dynamic analysis 13
8.1 General 13
8.2 Modal analysis using the time-history method 14
8.3 Modal analysis using the RRS 14
9 Qualification by vibration test 14
9.1 General 14
9.1.1 General 14
9.1.2 Mounting 15
9.1.3 External load 15
9.1.4 Measurements 15
9.1.5 Standard frequency range 15
9.1.6 Test methods 15
9.1.7 Testing 17
9.2 Test on complete apparatus 18
9.3 Test on the bushing mounted on a simulating support 18
9.4 Test on the bushing alone 18
10 Evaluation of the seismic qualification 18
10.1 Combination of stresses 18
10.2 Cantilever test 19
10.3 Acceptance criteria 19
11 Necessary exchange of information 20
11.1 Information supplied by the apparatus manufacturer 20
11.2 Information supplied by the bushing manufacturer 20
Annex A (informative) Flow chart for seismic qualification 23
Annex B (informative) Natural frequency and damping determination: Free oscillation test 24
B.1 Free oscillation test 24
B.2 Sine sweep frequency search 25
Annex C (informative) Static calculation method – Additional considerations 26
C.1 General 26
C.2 Effect of the first bending mode 26
C.3 Determination of S_c 26
C.4 Value of a_{bg} 26
C.5 Typical seismic response of cantilever type structures 27

AVA Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

C.6 Superelevation factor K 29
Annex D (informative) Qualification by static calculation – Example on transformer bushing 33
D.1 Seismic ground motion 33
D.2 Critical part of the bushing 33
D.3 Static calculation 33
D.3.1 General 33
D.3.2 Seismic load 34
D.3.3 Wind load 35
D.3.4 Terminal load 35
D.4 Guaranteed bending strength 36
Annex E (informative) Center clamped bushings 37
Bibliography 40

Figure 1 – Example of model of the transformer system 14
Figure 2 – RRS for ground mounted equipment – ZPA = 0,5 g [1] [2] 17
Figure 3 – Response factor R 21
Figure 4 – Test with simulating support according to 9.3 22
Figure 5 – Determination of the severity 22
Figure A.1 – Flow chart for seismic qualification 23
Figure B.1 – Typical case of free oscillations 24
Figure B.2 – Case of free oscillations with beats 25
Figure C.1 – Single degree of freedom system 27
Figure C.2 – Structure at the flange of a bushing with cemented porcelain [5] [7] 28
Figure C.3 – Spring stiffness C in function of cemented part geometry [5] [7] 29
Figure C.4 – Superelevation factor due to the existence of transformer body and foundation [5] 30
Figure D.1 – Critical part of the bushing 33
Figure D.2 – Forces affecting the bushing 34
Figure D.3 – Porcelain diameters 35
Figure E.1 – Failure process [6] 37
Figure E.2 – Failure process, flow chart [5] [6] 38
Figure E.3 – Stress profile during the opening process [6] 38
Figure E.4 – Relation between compression and tensile stress in the bottom edge of the porcelain due to the opening process [6] 39

Table 1 – Ground acceleration levels 10
Table 2 – Dynamic parameters obtained from experience on bushings with porcelain insulators (f_0 = natural frequency, d = damping) 12
Table 3 – Dynamic parameters obtained from experience on bushings with composite insulators (f_0= natural frequency, d = damping) 12
Table 4 – Example of qualification level: AG5: ZPA = 0,5 g 17
Table 5 – Response factor R 21
Table C.1 – Examples of typical seismic responses 31

Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

INTERNATIONAL ELECTROTECHNICAL COMMISSION

_____

BUSHINGS – SEISMIC QUALIFICATION

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- The subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 61463, which is a Technical Specification, has been prepared by subcommittee 36A: Insulated bushings, of IEC technical committee 36: Insulators.

This second edition cancels and replaces the first edition published in 1996 and Amendment 1:2000. This edition constitutes a technical revision.

Documents
Document Sharing Hub

Full document details: PD IEC/TS 61463:2016

This edition includes the following significant technical changes with respect to the previous edition:

a) the seismic spectrum profile has been substituted with the one of IEEE Std 693-2005, worldwide used as a reference;

b) the acceptance criteria have been reviewed and the maximum permissible stress for each main material has been harmonized with the relevant IEC Standard for that material;

c) a load on the head has been prescribed when the bushing is subject to the vibration test;

d) the sine sweep test has been added as a method of search of resonance frequency, worldwide used.

The text of this document is based on the following documents:

Enquiry draft	Report on voting
36A/178/DTS	36A/179/RVC

Full information on the voting for the approval of this document can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC/TS 61463:2016

INTRODUCTION

As it is not always possible to define accurately the seismic severity at the bushing flange level, IEC TS 61463, which is a Technical Specification, presents three alternative methods of qualification. The three methods are equally acceptable. If the required response spectrum (RRS) at the bushing flange is not known, a severity (in terms of acceleration values) based on standard response spectra at the ground level may be used to carry out qualification through one of the three methods described in this document.

When the environmental characteristics are not sufficiently known, qualification by static calculation is acceptable. Where high safety reliability of equipment is required for a specific environment, precise data are used, therefore qualification by dynamic analysis or vibration test is recommended. The choice between vibration testing and dynamic analysis depends mainly on the capacity of the test facility for the mass and volume of the specimen, and, also if non-linearities are expected.

When qualification by dynamic analysis is foreseen, it is recommended that the numerical model be adjusted by using vibration data (see Clause 5).

This document was prepared with the intention of being applicable to bushings whatever their construction material and their internal configuration.The information contained, originally directed to porcelain bushings, has been partially updated to include also composite bushings.

Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

BUSHINGS – SEISMIC QUALIFICATION

1 Scope

IEC TS 61463, which is a Technical Specification, is applicable to alternating current and direct current bushings for highest voltages above 52 kV (or with resonance frequencies placed inside the seismic response spectrum), mounted on transformers, other apparatus or buildings. For bushings with highest voltages less than or equal to 52 kV (or with resonance frequencies placed outside from the seismic response spectrum), due to their characteristics, seismic qualification is not used as far as construction practice and seismic construction practice comply with the state of the art.

This document presents acceptable seismic qualification methods and requirements to demonstrate that a bushing can maintain its mechanical properties, insulate and carry current during and after an earthquake.

The seismic qualification of a bushing is only performed upon request.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-47, *Environmental testing – Part 2-47: Test – Mounting of specimens for vibration, impact and similar dynamic tests*

IEC 60068-2-57, *Environmental testing – Part 2-57: Tests – Test Ff: Vibration – Time-history and sine-beat method*

IEC 60068-3-3:1991, *Environmental testing – Part 3-3: Guidance – Seismic test methods for equipments*

IEC 60137, *Insulated bushings for alternating voltages above 1 000 V*

IEC 61462, *Composite hollow insulators – Pressurized and unpressurized insulators for use in electrical equipment with rated voltage greater than 1 000 V – Definitions, test methods, acceptance criteria and design recommendations*

IEC 62155, *Hollow pressurized and unpressurized ceramic and glass insulators for use in electrical equipment with rated voltages greater than 1 000 V*

IEC 62217, *Polymeric insulators for indoor and outdoor use – General definitions, test methods and acceptance criteria*

ISO 2041, *Mechanical vibration, shock and condition monitoring – Vocabulary*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60068-3-3, IEC 60137, IEC 61462, ISO 2041 and the following apply.

AVA Documents
Document Sharing Hub

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1
critical cross-section
section of the bushing that is most likely to fail during an earthquake

3.2
response spectrum
plot of the maximum response to a defined input motion of a family of single-degree-of-freedom bodies at a specified damping ratio

[SOURCE: IEC 60068-2-57:2013, 3.18, modified — The words "as a function of their natural frequencies and at a specified damping ratio" has been replaced by "at a specified damping ratio".]

3.3
rigid equipment
equipment whose natural frequency is greater than 33 Hz is considered rigid for the purpose of this technical specification

3.4
standard frequency range
predominant frequencies of a typical earthquake

Note 1 to entry: This range is generally between 0,3 Hz and 33 Hz.

Note 2 to entry: This range is sufficient to determine the critical frequencies of the equipment and for its testing. In certain cases the test frequency range may be extended or reduced dependent on the critical frequencies present, but this shall be justified.

3.5
zero period acceleration
high frequency asymptotic value of acceleration of a response spectrum (above the cut-off frequency of 33 Hz)

Note 1 to entry: This acceleration corresponds to the maximum acceleration of the time history used to derive the spectrum.

4 Symbols and abbreviated terms

a_{bg} equivalent maximum acceleration to the centre of gravity of the bushing during the seismic event

a_f maximum acceleration of the bushing flange

a_g maximum acceleration of the ground resulting from the motion of a given earthquake

NOTE a_g is equal to the zero period acceleration (ZPA) of Figure 2.

d damping of the bushing

d_p distance between the centre of gravity of the part of the bushing which is under consideration and the critical cross-section

f_0 first natural frequency of the bushing

Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

K superelevation factor between ground and bushing flange: factor accounting for the change in the acceleration from the ground to the flange due to the amplification by foundation, buildings and structure

m_p mass of the part of the bushing which is under consideration

M_s bending moment at the critical cross-section of the part of the bushing considered, due to an earthquake

R response factor derived from the required response spectrum (RRS) as the ratio between the response acceleration and the ZPA (see Figure 3)

RRS required response spectrum: response spectrum specified by the user

S_c coefficient established to take into account the effects of both multifrequency excitation and multimode response

S_a spectral acceleration

ZPA zero period acceleration (see a_g)

5 Methods of seismic qualification

Seismic qualification should demonstrate the ability of a bushing to withstand seismic stresses and to maintain its required function without failure, during and after an earthquake of a specified severity (see Clause 6).

As bushings are mounted on apparatus or buildings, the seismic qualification of the bushing must consider the behaviour of the system on which the bushing is fixed. In the seismic qualification of a bushing, all parts should be included, which contribute to the stresses in the critical cross-sections during a seismic event, for example the conductor and inner spacer in gas insulated bushings.

Three methods and combinations thereof are described in this document:

– qualification by static calculation (Clause 7);
– qualification by dynamic analysis (Clause 8);
– qualification by vibration test (Clause 9).

A combination of the methods may be used

– to qualify a bushing which cannot be qualified by testing alone (e.g. because of size and/or complexity of the apparatus),
– to qualify a bushing already tested under different seismic conditions, and
– to qualify a bushing similar to a bushing already tested but which includes modifications influencing the dynamic behaviour (e.g. change in the length of insulators or in the mass).

Vibrational data (damping, critical frequencies, stresses of critical elements as a function of input acceleration) for analysis can be obtained by

a) a dynamic test on a similar bushing,
b) a dynamic test at reduced test level, and
c) determination of natural frequencies and damping by other tests such as free oscillation tests or sine sweep tests (see Annex B).

The methods result in the value of M_s which is determined for each part of the bushing on either side of the flange. The stress due to this moment should be combined with the other stresses acting in the bushing, and it should be demonstrated that the bushing withstands the combined stress (Clause 10).

The different methods of seismic qualification are illustrated in the flow chart given in Annex A.

AVA Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

6 Severities

6.1 At the ground

The ground acceleration depends upon the seismic conditions of the site where the apparatus is to be located. When it is known, it should be prescribed by the relevant specification. Otherwise, the severity level should be selected from Table 1.

Table 1 – Ground acceleration levels

Ground acceleration reference	Description of earthquake					
	General	*ZPA* = a_g m/s^2	Richter scale magnitude	UBC zone[a]	Intensity MSK[b]	RRS
AG2	Light to medium earthquakes	2 (0,2 g)	< 5,5	1 to 2	< VIII	Figure 1[c]
AG3	Medium to strong earthquakes	3 (0,3 g)	5,5 to 7,0	3	VIII to IX	Figure 1[c]
AG5	Strong to very strong earthquakes	5 (0,5 g)	> 7,0	4	> IX	Figure 1

[a] Approximate Uniform building code zone (International conference of building officials).

[b] MSK (Medvedev-Sponheuer-Karnik) corresponds to modified Mercalli intensity scale.

[c] Values for AG2 and AG3 are obtained by multiplying the values from Figure 2 by 2/5 and 3/5 respectively.

The selected qualification level should be in accordance with expected earthquakes of maximum ground motions for the site location, for which certain structures, systems and components are designed to remain functional. These structures are those essential to assure proper function, integrity and safety of the total system (S_2 type earthquakes, according to IEC 60068-3-3).

For qualification, it should be assumed that

– the horizontal movements as described in Table 1 act in any direction
– the severities of the vertical accelerations are 50 % of the horizontal (if a different value is used, a justification shall be provided), and
– both directions may reach their maximum values simultaneously.

The ground motion can be described by natural time histories when known, or by artificial time histories, which should comply with the RRS; this is used as input for dynamic analysis or vibration test on the complete apparatus.

NOTE Information on the correlation between seismic qualification levels, seismic zone and seismic scales is given in IEC 60721-2-6 [1][1] and IEC 60068-3-3.

6.2 At the bushing flange

The severity at the bushing flange (see Figure 5) may be available from the manufacturer of the apparatus and structures (i.e. transformers, gas insulated apparatuses (GIS), building) in terms of RRS or maximum acceleration (a_f). Where no information is available, the following simplified formula is used in order to establish an acceleration value at the flange of the bushing.

$$a_f = K \times a_g$$

The superelevation factor K can be

[1] Numbers in square brackets refer to the Bibliography.

Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

– calculated by finite element analysis including soil interaction or any other careful modelling, or
– derived from results from calculations or tests on comparable apparatus or structures, or
– taken from typical values obtained from experience.

So far, very little experience is reported. Unless more background information is available, K should be assumed to be 1 for through-wall bushings, 1,5 for GIS bushings and for transformer bushings directly mounted on the transformer cover, and 2 for transformer bushings mounted on a turret. If the mounting configuration on the transformer is not known, K will be assumed as 1,5.

See also IEC 60068-3-3:1991, Table 4.

7 Qualification by static calculation

This method is valid for rigid equipment. It may be extended to flexible equipment, such as a bushing, taking into consideration the response factor R, as an alternative to the method by analysis. This allows simpler evaluation with increased conservatism.

Using the static calculation method, the bending moment in the critical cross-section of the part of the bushing under consideration is calculated from an equivalent acceleration of the centre of gravity of that part (a_{bg}):

$$M_s = a_{bg} \times d_p \times m_p$$

This acceleration, a_{bg}, is calculated from the flange acceleration a_f by multiplication with a coefficient S_c and the response factor R (see Annex C):

$$a_{bg} = a_f \times S_c \times R$$

The value of S_c depends on the natural frequency f_0 of the mounted bushing:

$f_0 \leq 8$ Hz	$S_c = 1{,}5$
$8 < f_0 < 33$ Hz	$S_c = 1 + 0{,}5 \times (33 - f_0) / (33\text{-}8)$
$f_0 \geq 33$ Hz	$S_c = 1{,}0$

If the natural frequency f_0 is not known, the conservative value S_c = 1,5 should be used.

The value R can be established by one of the following methods.

a) From the spectrum at the bushing flange (if available).
b) When the spectrum at the bushing flange is not known, the spectrum at the ground (Figure 2) may be used assuming that the levels at all frequencies are equally amplified (K factor) from the ground to the flange. For such cases, the values of R are summarized in Figure 3. The value of R is derived from the RRS (Figure 2 and Table 4) by dividing the spectrum values with the ZPA value of asymptotic acceleration.

   In order to correctly use the R values, it is necessary to know the first natural frequency f_0 and the damping d % of the bushing mounted on its supporting structure. The natural frequency can either be calculated as indicated for the superelevation factor or found by a free oscillation test as described in Annex B.
c) R may be assumed to be equal to 2,5 when information for frequency f_0 and damping d % of the bushing mounted on a transformer is not available. The value of 2,5 corresponds to the frequency range 1,1 Hz to 8 Hz and 5 % damping ratio (ref. to Figure 3 and Table 5).

AVA Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016

d) R may be assumed to be equal to 2,9 when information for frequency f_0 and damping d % of the bushing mounted on a GIS structure is not available. The value of 2,9 corresponds to the frequency range 1,1 Hz to 8 Hz and 3 % damping ratio (ref. to Figure 3 and Table 5).

Different R values can be agreed between purchaser and manufacturer if justified.

Collected data show that the first natural frequency of a mounted bushing is lower than that of the bushing itself. Reported natural frequencies show a great variation, while the damping ratios lie within a limited range (see Table 2 and Table 3).

An example of the application of the method for bushings mounted on a transformer is given in Annex D.

Table 2 – Dynamic parameters obtained from experience on bushings with porcelain insulators (f_0 = natural frequency, d = damping)

Type of mounting	Highest voltage of equipment							
	123 kV to 170 kV		245 kV to 362 kV		420 kV to 550 kV		800 kV to 1 200 kV	
	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]
Bushing alone (mounted on a rigid structure)	15 to 35	2 to 4	10 to 24	2 to 4	3 to10	2 to 5	1.5 to 5	2 to 6
Bushing mounted on a transformer tank	5 to 20	3 to 6	5 to 15	5	3 to 8	5	1 to 4	5
Bushing mounted on a GIS	4 to 12	3 to 5	4 to 10	–	3,5 to 10	–	4 to 5	1,5 to 3
Bushing mounted on a building	–	–	–	–	–	–	–	–

NOTE 1 In the case of special dissipating systems, higher damping ratios can be obtained.

NOTE 2 Additional data will be included in this table based on experience of the practical application of this technical specification.

Table 3 – Dynamic parameters obtained from experience on bushings with composite insulators (f_0= natural frequency, d = damping)

Type of mounting	Highest voltage of equipment							
	123 kV to 170 kV		245 kV to 362 kV		420 kV to 550 kV		800 kV to 1 200 kV	
	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]	f_0 [Hz]	d [%]
Bushing alone (mounted on a rigid structure)	14 to 18	1.5 to 2	5,5 to 13	1 to 3,5	3.5 to6,5	1 to 4		
Bushing mounted on a transformer tank								
Bushing mounted on a GIS			10		4 to 5,5	1 to 4		
Bushing mounted on a building								

NOTE 1 In the case of special dissipating systems, higher damping ratios can be obtained.

NOTE 2 An empty space means that data are not yet available. Additional data or ranges of values will be included in this table based on experience of the practical application of this technical specification.

AVA Documents
Document Sharing Hub
Full document details: PD IEC/TS 61463:2016