PD IEC/TS 62257-1:2015

BSI Standards Publication

Recommendations for renewable energy and hybrid systems for rural electrification

Part 1: General introduction to IEC 62257 series and rural electrification

bsi.

...making excellence a habit.™

Document Sharing Hub

National foreword

This Published Document is the UK implementation of IEC/TS 62257-1:2015. It supersedes PD IEC/TS 62257-1:2013 which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee GEL/82, Photovoltaic Energy Systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2015.
Published by BSI Standards Limited 2015

ISBN 978 0 580 89792 4
ICS 27.160

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 December 2015.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD IEC/TS 62257-1:2015

IEC TS 62257-1

Edition 3.0 2015-10

TECHNICAL SPECIFICATION

colour inside

Recommendations for renewable energy and hybrid systems for rural electrification –
Part 1: General introduction to IEC 62257 series and rural electrification

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.160

ISBN 978-2-8322-2914-9

Warning! Make sure that you obtained this publication from an authorized distributor.

® Registered trademark of the International Electrotechnical Commission

Documents
Document Sharing Hub

Full document details: PD IEC/TS 62257-1:2015

CONTENTS

FOREWORD 3
INTRODUCTION 5
1 Scope 6
2 Normative references 6
3 Terms, definitions and abbreviations 7
4 Methodology for rural electrification using hybrid renewable energy systems 8
4.1 Rural electrification: which solution to choose? 8
4.2 Decentralized electrification requiring a range of systems 10
5 How to use the IEC 62257 series for a rural electrification project 12
5.1 Overview 12
5.2 Review of the IEC 62257 series: links with the phases of a rural electrification project (see Table 3) 15
5.2.1 Opportunity study 15
5.2.2 Specification of a project 15
5.2.3 Feasibility study of a project 17
5.2.4 Detailed technical studies 18
5.2.5 Implementation of a project 19
5.2.6 Validation of a project 20
5.2.7 On field operation 21
Annex A (normative) Terms, definitions and abbreviations in use in the IEC 62257 series 23

Figure 1 – Example of electrification progress following a master plan methodology 9
Figure 2 – Example of electrification of a village using both CESs and IESs 10
Figure 3 – Contractual relationship between project participants – (IEC TS 62257-3:2015, Figure 1) 16
Figure 4 – Example of the content of a non-technical preliminary study – (IEC TS 62257-2:2015, Figure 1) 18
Figure 5 – TN-C-S system – (IEC TS 62257-5:2015, Figure B.2) 19
Figure 6 – Phase A battery endurance test – (IEC TS 62257-8-1:2007, Figure 2) 20
Figure 7 – Test 3, operating cycles – (IEC TS 62257-9-6:2008, Figure 3) 21

Table 1 – Some advantages and disadvantages of the proposed single and multiple user systems 11
Table 2 – Contents of the 62257 series 13
Table 3 – Utilization of the different parts of the IEC 62257 series according to the main project phases 14
Table 4 – Combined categorization – (IEC TS 62257-2:2015, Table C.1) 17
Table 5 – Service specification (example) – (IEC TS 62257-2:2015, Table C.2) 17
Table 6 – Verification of the adherence to commitments – (IEC TS 62257-6:2015, Table 8) 21
Table 7 – AOMR participant involvement – (IEC TS 62257-6:2015, Table 3) 22

Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RECOMMENDATIONS FOR RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –

Part 1: General introduction to IEC 62257 series and rural electrification

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 62257-1, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems. It was developed in cooperation with other IEC technical committees and subcommittees dealing with renewable energies and related matters, namely IEC technical committee 21 (Secondary cells and batteries), subcommittee

Documents
Document Sharing Hub

21A (Secondary cells and batteries containing alkaline or other non-acid electrolytes), IEC technical committee 64 (Electrical installations and protection against electric shock), IEC technical committee 88 (Wind turbines).

This third edition cancels and replaces the second edition issued in 2013. It constitutes a technical revision.

The main technical changes with regard to the previous edition are as follows:

– Redefine the maximum AC voltage from 500 Va.c. to 1 000 Va.c., the maximum DC voltage from 750 Vd.c. to 1 500 Vd.c. and removal of the limitation of 100 kVA system size. Hence the removal of the word “small” in the title and related references in this technical specification.

This technical specification shall be used in conjunction with the other documents of the IEC 62257 series.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/942/DTS	82/979/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62257 series, published under the general title *Recommendations for renewable energy and hybrid systems for rural electrification*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: PD IEC/TS 62257-1:2015

INTRODUCTION

Rural electrification is one of the predominant policy actions designed to increase the well-being of rural populations together with access to clean water, improved healthcare, education, personal advancement and economic development.

Several strategies can be adopted to implement rural electrification. Rural electrification can be completed through connection to a national or regional electrification grid. The IEC 62257 series applies to cases where the grid is too far away (too costly) or the individual demand centres are too small to make grid access economic, where autonomous power systems may be used to supply these services.

This series IEC 62257 provides technical specifications to different players involved in rural electrification projects (such as project developers, project implementers, installers, etc.) for the setting up of renewable energy and hybrid systems with AC voltage below 1 000 Vac and DC voltage below 1 500 Vdc.

These specifications are recommendations:

a) to choose the right system for the right place,

b) to design the system,

c) to operate and maintain the system.

The specifications focus on rural electrification concentrating on, but not specific to, developing countries. They must not be considered as all inclusive to rural electrification. That means that they could be used for rural electrification or electrification of remote sites in developed countries also. They try to promote the use of renewable energies in rural areas, but they do not deal with clean mechanisms development at this time (CO_2 emission, carbon credit, etc.) Further developments in this field could be introduced in future steps.

This consistent set of documents is best considered as a whole with different parts corresponding to items for safety, sustainability of systems and at the lowest life cycle cost as possible. One of the main objectives is to provide the minimum sufficient requirements, relevant to the field of application, that is: renewable energy and hybrid off-grid systems.

Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015

RECOMMENDATIONS FOR RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –

Part 1: General introduction to IEC 62257 series and rural electrification

1 Scope

This part of IEC 62257 first introduces a methodology for implementing rural electrification using autonomous hybrid renewable energy systems.

Secondly, it provides a guide for facilitating the reading and the use of the IEC 62257 series for setting up decentralized rural electrification in developing countries or in developed countries, the only difference being the level of quality of service and the needed quantity of energy that the customer can afford.

The IEC 62257 series is designed as follows:

- Parts 2 to 6 are methodological supports for the management and implementation of projects.
- Parts 7 to 12 are technical specifications for individual or collective systems and associated components.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC TS 62257-2:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 2: From requirements to a range of electrification systems*

IEC TS 62257-3:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 3: Project development and management*

IEC TS 62257-4:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 4: System selection and design*

IEC TS 62257-5:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 5: Protection against electrical hazards*

IEC TS 62257-6:2015, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 6: Acceptance, operation, maintenance and replacement*

IEC TS 62257-7, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 7: Generators*

IEC TS 62257-7-1, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 7-1: Generators – Photovoltaic arrays*

IEC TS 62257-7-3, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 7-3: Generator set – Selection of generator sets for rural electrification systems*

AVA Documents
Document Sharing Hub

IEC TS 62257-8-1:2007, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 8-1: Selection of batteries and battery management systems for stand-alone electrification systems – Specific case of automotive flooded lead-acid batteries available in developing countries*

IEC TS 62257-9-1, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-1: Micropower systems*

IEC TS 62257-9-2, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-2: Microgrids*

IEC TS 62257-9-3, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-3: Integrated system – User interface*

IEC TS 62257-9-4, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-4: Integrated system – User installation*

IEC TS 62257-9-5, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-5: Integrated system – Selection of stand-alone lighting kits for rural electrification*

IEC TS 62257-9-6:2008, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 9-6: Integrated system – Selection of Photovoltaic Individual Electrification Systems (PV-IES)*

IEC TS 62257-12-1, *Recommendations for renewable energy and hybrid systems for rural electrification – Part 12-1: Selection of self-ballasted lamps (CFL) for rural electrification systems and recommendations for household lighting equipment*

3 Terms, definitions and abbreviations

For the purposes of this document, the following terms, definitions and abbreviations apply. The main glossary used in the IEC 62257 series is given in Annex A.

3.1
Collective Electrification System
CES
micropower plant and microgrid that supplies electricity to multiple consumption points using a single or multiple energy resource points

3.2
GS
general specification

3.3
hybrid system
multi-energy sources system

3.4
Individual Electrification System
IES
micropower plant system that supplies electricity to one consumption point usually with a single energy resource point

Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015

3.5
micropower plant
power plant that produces less than 50 kVA through the use of a single resource or hybrid system

3.6
microgrid
grid that transfers a capacity level less than 50 kVA and powered by a micropower plant

3.7
RE
renewable energy

4 Methodology for rural electrification using hybrid renewable energy systems

4.1 Rural electrification: which solution to choose?

When developing a policy of electrification for a given country or region, there is a requirement to envision the target situation in the medium term (10 years) and long term (20 to 30 years). This means that a “master plan” for electrifying the country or this region should preferably be constructed in order to define the lowest life cycle cost solution. Essentially, this master plan shall take into account both grid extension and autonomous systems solutions.

The master plan should allow selection between two modes of electrification (national/regional grids or decentralized system) and also, to determine the most suitable time frame to execute the work. Regarding the decentralized part, each village needs to be investigated to obtain a variety of sociological, economical and geophysical data. With this approach, the demand needs can be assessed for each village. This assessment should include possible changes in the power requirements as a function of the future economic development for each village. The urban development and the demographic characteristics of each village are also important to determine the best electrification solution and to assess the amount of capital investment needed.

Electrification can be achieved by installing decentralized systems if at some points the community can be (economically) interconnected. Provision can also be made for the integration or relocation of such systems. Obviously, the solution of using both a local (grid) and dispersed RE sources generation may be appropriate.

Geographical Information Systems (GIS) are readily available off-the-shelf today and allow a beneficial and useful graphical presentation of the master plan. In such a representation, each village can be identified on an appropriate map with colour codes depicting the corresponding type of power supply.

Furthermore, in such a master plan, villages can be prioritized for further scheduling of the electrification work on a yearly or 5 year basis. In this process, the cost effectiveness of the electrification per village would be taken as one of the most significant prioritizing criteria.

This criterion is less important in the developed world but is critical in developing countries. Simulations can also be made by varying all the relevant parameters to allow a comprehensive financial analysis of the selected system. Figure 1 is an illustration of electrification progress following such a master plan methodology.

Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015



Figure 1 – Example of electrification progress following a master plan methodology

In the same way, the best strategy shall be determined for electrifying a village or a small town, according to its topography. Figure 2 shows a village with a densely populated core and a sparsely populated peripheral zone.

The economic calculation shows that the most economical solution is to electrify the centre of the village with Collective Electrification Systems (micropower stations and microgrids) and to electrify the peripheral zone with IES (Individual Electrification Systems) as the cost per consumer of the microgrid would be higher than the cost of the IESs in this zone.

This methodology provides the lowest electrification cost per customer.

Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015



Figure 2 – Example of electrification of a village using both CESs and IESs

4.2 Decentralized electrification requiring a range of systems

Rural electrification using decentralized systems is designed to supply power to demand points located in rural areas that cannot be easily (economically) connected to national grids.

In most cases, these consumption points would consist of the following types of demand:

– specific processes (for example public pumping, battery charging center),
– isolated homes,
– collective facilities (for example public lighting, schools, health and care center, places of worship, administrative buildings, etc.),
– business activities (for example workshop, micro industry, trade, etc.).

The decentralized system solution can have two basic topologies: Collective Electrification Systems (CES) which supply electricity to multiple consumption points using a single (or multiple energy resource points) and Individual Electrification Systems (IES) which supply electricity to one consumption point (usually with a single energy resource point).

CES systems may be appropriate for rural, relatively highly populated areas, for example, large villages whereas the IES may be appropriate for more sparsely populated regions and (or) isolated households.

Individual Electrification Systems (IES) for single users would incorporate two subsystems:

– one electrical power production subsystem,
– one subsystem for utilizing this electrical power.

Collective Electrification Systems (CES) for multiple users on the other hand would incorporate three subsystems:

– an electrical power production subsystem,

  by convention, this part is designated as “micropower plant” where ‘micro’ refers to a modest production power level (from a few kVA to a few tens kVA),

AVA Documents
Document Sharing Hub
Full document details: PD IEC/TS 62257-1:2015