



BSI Standards Publication

Microgrids

Part 3-1: Technical requirements — Protection and dynamic control

National foreword

This Published Document is the UK implementation of IEC TS 62898-3-1:2020+A1:2023. It supersedes PD IEC TS 62898-3-1:2020, which is withdrawn.

The start and finish of text introduced or altered by amendment is indicated in the text by tags. Tags indicating changes to IEC text carry the number of the IEC amendment. For example, text altered by IEC amendment 1 is indicated by A1 A1.

The UK participation in its preparation was entrusted to Technical Committee GEL/8, Systems Aspects for Electrical Energy Supply.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2023
Published by BSI Standards Limited 2023

ISBN 978 0 539 29519 1

ICS 29.240.01

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 September 2020.

Amendments/corrigenda issued since publication

Date	Text affected
31 December 2023	Implementation of IEC amendment 1:2023



TECHNICAL SPECIFICATION



Microgrids – Part 3-1: Technical requirements – Protection and dynamic control

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01

ISBN 978-2-8322-8764-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	8
4 Microgrid protection requirements.....	15
4.1 General.....	15
4.2 Main requirements specific to microgrids	16
4.2.1 General	16
4.2.2 Phase fault protection	16
4.2.3 Earth fault protection	17
4.3 General protection requirements	17
4.3.1 General	17
4.3.2 Dependability of protection	17
4.3.3 Security of protection.....	18
4.3.4 Availability and selectivity of protection.....	18
4.3.5 Operating time (speed) of protection.....	19
4.4 Particular requirements for non-isolated microgrids.....	19
4.5 Particular requirements for isolated microgrids.....	20
5 Protection systems for microgrids	20
5.1 General.....	20
5.2 Short-circuit protection.....	21
5.2.1 Overcurrent protection	21
5.2.2 Directional overcurrent protection	23
5.2.3 Distance protection.....	24
5.2.4 Directional power protection	24
5.2.5 Differential protection	24
5.3 System protection	25
5.3.1 Under/over voltage protection.....	25
5.3.2 Frequency protection	26
5.4 Centralized protection systems	26
6 Dynamic stability and control	27
6.1 General.....	27
6.2 Dynamic stability in microgrids.....	27
6.2.1 General	27
6.2.2 Disturbances in microgrids.....	28
6.2.3 Voltage and frequency stability	28
6.3 Dynamic control in microgrids	29
6.3.1 General requirements	29
6.3.2 Dynamic control functions.....	29
6.3.3 Control elements in microgrids.....	30
6.3.4 Control systems of microgrids.....	31
6.3.5 Control of microgrids during grid-connected mode	35
6.3.6 Control of microgrids during island mode	35
Annex A (informative) Use cases for dynamic control of microgrids	36
Bibliography.....	36

Figure 1 – Ratio between maximum load current/minimum short-circuit current in the microgrid	22
Figure 2 – Control elements in microgrids	30
 Figure 3 – Functional mapping for operation and control of microgrids	32
Figure 4 – Typical multilevel control of microgrids 	32
Figure A.1 – Simple microgrid platform for testing transient disturbance during motor start-up	36
Figure A.2 – Transient control strategy based on reactive current compensation control	36
 Figure A.3 – Voltage profile during field testing of transient disturbance with and without transient control device	37
Figure A.4 – Current profile during field testing of transient disturbance with and without transient control device 	37
Figure A.5 – Microgrid platform with high proportion of RES for testing dynamic disturbance control	38
 Figure A.6 – Dynamic control strategy	38
Figure A.7 – The voltage profile of field testing with and without dynamic control device 	39

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a Technical Specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical Specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC TS 62898-3-1, which is a Technical Specification, has been prepared by IEC subcommittee 8B: Decentralized Electrical Energy Systems of IEC technical committee 8: System aspects of electrical energy supply.

The text of this Technical Specification is based on the following documents:

Draft TS	Report on voting
8B/53/DTS	8B/59/RVDTS

Full information on the voting for the approval of this Technical Specification can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62898 series, published under the general title *Microgrids*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Microgrids can serve different purposes depending on the primary objectives of their applications. They are usually seen as a means to manage reliability of supply in a grid contingency and to facilitate local optimization of energy supply by controlling distributed energy resources (DER). Microgrids also present a way to provide electricity supply in remote areas, to use renewable energy as a systematic approach for rural electrification and to increase resiliency and security of supply to end users.

Deployment of DER can cause a microgrid or distribution system of a grid to face several challenges, including fault protection and dynamic control issues. There are, however, some issues commonly faced in the protection and control of microgrids which are less prevalent in large grids. These issues include: bidirectional flow of power resulting in voltage excursions outside acceptable limits, fault current being supplied from multiple sources, loss of synchronism between multiple sources when a fault occurs, potentially limited fault current magnitude, lower inertia or lower primary time constant, regular changes in operational configuration due to economic optimization, and intermittency of source-dependent renewable distributed generators. These issues worsen when the microgrid contains several converter-based generators (CBGs) and operates in island mode. As such, conventional protection and control strategies may not be suitable or sufficient for microgrids. Protection systems different from the conventional ones may be required. In some instances, protection systems may need to be adjusted dynamically based on the operating state of the microgrid.

Conventional power systems have predominantly consisted of power sources, such as fossil fuel-fired thermal power plants, hydro power plants and nuclear power plants, which are relatively stable and easy to control. On the other hand, microgrids often contain many different types of sources, many of which are intermittent. Hence, protection and dynamic control in microgrids need to be more sophisticated than in conventional power systems. However, the main grid contributes to the fault currents in the grid-connected mode of operation and hence the fault currents are large enough to actuate conventional protection devices. Though it is possible to employ conventional protection principles and existing standards for the protection of microgrids operating in grid-connected mode, the existing protection settings should be systematically assessed as the existence of DER may compromise the coordination of the protection system.

Due to the specific characteristics of microgrids and their frequent use of converter-based generators, disturbances in microgrids require special consideration. The disturbance problems in microgrids can be addressed by dynamic control. Dynamic control can be classified as transient disturbance control and dynamic disturbance control. Transient disturbance control damps disturbances in microgrids caused by forced or unintended sudden and severe voltage and current changes due to switching of large sources or loads, mode transfer or fault clearance, and characterized by large magnitude and phase change and with a time duration of milliseconds. Dynamic disturbance control regulates disturbances in microgrids caused by forced or unintended voltage and current changes due to generator and load variation, and characterized by magnitude and phase changes beyond the normal operating limits, and continuing for milliseconds to seconds.

The initial characteristics of faults are very similar to initial characteristics of transient and dynamic disturbances. Distinguishing the two types of incidents from each other is critical for the proper operation of microgrids. Thus, protection and dynamic control of microgrids are closely related and need to be coordinated with each other.

This part of IEC 62898 specifies requirements to address the above-mentioned protection and dynamic control issues in microgrids.

IEC TS 62898 (all parts) intends to provide general guidelines and technical requirements for microgrids.

a) IEC TS 62898-1 mainly covers the following issues:

- determination of microgrid purposes and application;
- preliminary study necessary for microgrid planning, including resource analysis, load forecast, DER planning and power system planning;
- principles of microgrid technical requirements that should be specified during planning stage;
- microgrid evaluation to select an optimal microgrid planning scheme.

b) IEC TS 62898-2 mainly covers the following issues:

- operation requirements and control targets of microgrids under different operation modes;
- basic control strategies and methods under different operation modes;
- requirements of energy storage, monitoring and communication under different operation modes;
- power quality.

c) IEC TS 62898-3-1 mainly covers the following issues:

- requirements for microgrid protection;
- protection systems for microgrids;
- dynamic control for transient and dynamic disturbances in microgrids;

Microgrids can be stand-alone or a sub-system of an interconnected grid. The technical requirements in this Technical Specification are intended to be consistent with:

- 1) IEC 60364-7 (all parts and amendments related to low-voltage electrical installations);
- 2) IEC TS 62786, requirements for connection of generators intended to be operated in parallel with the grid;
- 3) IEC TS 62257 (all parts) with respect to rural electrification;
- 4) IEC TS 62749 with respect to power quality;
- 5) IEC TS 62898-1;
- 6) IEC TS 62898-2;
- 7) IEC TS 63268;

MICROGRIDS –

Part 3-1: Technical requirements – Protection and dynamic control

1 Scope

The purpose of this part of IEC 62898 is to provide guidelines for the specification of fault protection and dynamic control in microgrids. Protection and dynamic control in a microgrid are intended to ensure safe and stable operation of the microgrid under fault and disturbance conditions.

This document applies to AC microgrids comprising single or three-phase networks or both. It includes both isolated microgrids and non-isolated microgrids with a single point of connection (POC) to the upstream distribution network. It does not apply to microgrids with two or more points of connection to the upstream distribution network, although such systems can follow the guidelines given in this document. This document applies to microgrids operating at LV or MV or both. DC and hybrid AC/DC microgrids are excluded from the scope, due to the particular characteristics of DC systems (extremely large fault currents and the absence of naturally occurring current zero crossings).

This document defines the principles of protection and dynamic control for microgrids, general technical requirements, and specific technical requirements of fault protection and dynamic control. It addresses new challenges in microgrid protection requirements, transient disturbance control and dynamic disturbance control requirements for microgrids. It focuses on the differences between conventional power system protection and new possible solutions for microgrid protection functions.

Depending on specific situations, additional or stricter requirements can be defined by the microgrid operator in coordination with the distribution system operator (DSO).

This document does not cover protection and dynamic control of active distribution systems. This document does not cover product requirements for measuring relays and protection equipment.

This document does not cover safety aspects in low voltage electrical installations, which are covered by IEC 60364 (all parts and amendments related to low-voltage electrical installations). Requirements relating to low voltage microgrids can be found in IEC 60364-8-2.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364 (all parts), *Low voltage electrical installations*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

code

<electric power system> collection of rules concerning rights and duties of the parties involved in a certain part of the electric power system

EXAMPLE Grid code, distribution code.

[SOURCE: IEC 60050-617:2009, 617-03-03]

3.2

(electronic) (power) converter

(electronic) (power) convertor

operative unit for electronic power conversion, comprising one or more electronic valve devices, transformers and filters if necessary and auxiliaries if any

Note 1 to entry: In English, the two spellings "convertor" and "converter" are in use, and both are correct. In this document, the spelling "converter" is used in order to avoid duplications.

[SOURCE: IEC 60050-551:1998, 551-12-01, modified – The figure has been deleted.]

3.3

converter-based generator

CBG

generator of AC power that is naturally a DC source, or an AC source whose frequency is different from the power frequency, and is connected to the electric power system through a power converter

3.3.1

grid-forming CBG

generator which is connected to the network through a converter that can be controlled as a voltage source capable of controlling voltage and frequency of the network

Note 1 to entry: There are also stiff grid-forming CBGs which are a special type of grid-forming CBGs delivering power at constant frequency and voltage.

3.3.2

grid-supporting CBG

generator which is connected to the network through a converter with a power source capable of actively assisting the regulation of voltage and frequency of the network

3.3.3

grid-following CBG

generator which is connected to the network through a converter with a power source that does not have the capability to actively assist the regulation of voltage and frequency of the network

3.4

distributed energy resources

DER

generators (with their auxiliaries, protection and connection equipment), including loads having a generating mode (such as electrical energy storage systems), connected to a low-voltage or a medium-voltage network

[SOURCE: IEC 60050-617:2017, 617-04-20]

A1 3.4.1
renewable energy sources
RES

distributed energy resources whose primary energy source is constantly replenished and will not become depleted

Note 1 to entry: Examples of renewable energy are: wind, solar, geothermal, hydropower.

Note 2 to entry: Fossil fuels are non-renewable. **A1**

3.5
distributed generation
embedded generation
dispersed generation
DG

generation of electric energy by multiple sources which are connected to the power distribution system

[SOURCE: IEC 60050-617:2009, 617-04-09, modified – "distributed generation" has been listed as a first preferred term and the abbreviated term "DG" has been added.]

3.6
distribution system operator
distribution network operator
distributor
DSO

party operating a distribution system

[SOURCE: IEC 60050-617:2009, 617-02-10, modified – The abbreviated term "DSO" has been added.]

3.7
dynamic disturbance

<microgrid> series of voltage and current changes in a microgrid caused by output of renewable energy sources reaching a sufficiently high proportion, non-linear loads, intentional islanding, intermittency and output power fluctuation of renewable energy resources and grid side faults, which continue for a period of 50 ms to 2 s

3.8
electrical energy storage
EES

installation able to absorb electrical energy, to store it for a certain amount of time and to release electrical energy during which energy conversion processes may be included

EXAMPLE A device that absorbs AC electrical energy to produce hydrogen by electrolysis, stores the hydrogen, and uses that gas to produce AC electrical energy is an electrical energy storage.

Note 1 to entry: The term "electrical energy storage" may also be used to indicate the activity that an apparatus, described in the definition, carries out when performing its own functionality.

Note 2 to entry: The term "electrical energy storage" should not be used to designate a grid-connected installation, "electrical energy storage system" is the appropriate term.

[SOURCE: IEC 62933-1:2018, 3.1]

3.8.1
energy intensive application

EES system application generally not very demanding in terms of step response performances but with frequent and long charge and discharge phases at variable discharge powers

Note 1 to entry: Reactive power exchange with the electric power system is frequently present together with active power exchange.

[SOURCE: IEC 62933-1:2018, 3.12, modified – "energy intensive application" has been listed as a preferred term instead of an admitted term, "frequent" has been added in the definition, "may be present" has been replaced with "is frequently present" in Note 1 to entry and Note 2 to entry has been deleted.]

3.8.2

power intensive application

EES system application generally demanding in terms of step response performances and with frequent charge and discharge phase transition or with reactive power exchange with the electric power system

[SOURCE: IEC 62933-1:2018, 3.13, modified – "power intensive application" has been listed as a preferred term instead of an admitted term and the note has been deleted.]

3.9

fault ride-through

FRT

ability of a generating unit or power plant to stay connected during specified faults in the electric power system

3.10

high voltage

HV

- 1) in a general sense, the set of voltage levels in excess of low voltage
- 2) in a restrictive sense, the set of upper voltage levels used in power systems for bulk transmission of electricity

[SOURCE: IEC 60050-601:1985, 601-01-27]

3.11

island

<power system> portion of a power system, that is disconnected from the remainder of the system, but remains energized

[SOURCE: IEC 60050-603:1986, 603-04-46]

3.11.1

intentional island

island resulting from planned action(s) of automatic protections, or from deliberate action by the responsible network operator, or both, in order to keep supplying electrical energy to a section of an electric power system

[SOURCE: IEC 60050-617:2017, 617-04-17]

3.11.2

unintentional island

island that is not anticipated by the relevant network operator

[SOURCE: IEC 60050-617:2017, 617-04-18]

3.12

low voltage

LV

set of voltage levels used for the distribution of electricity and whose upper limit is generally accepted to be 1 000 V for alternating current

[SOURCE: IEC 60050-601:1985, 601-01-26]

3.13
medium voltage
MV

any set of voltage levels lying between low and high voltage

Note 1 to entry: The boundaries between medium- and high-voltage levels overlap and depend on local circumstances and history or common usage. Nevertheless the band 30 kV to 100 kV frequently contains the accepted boundary.

[SOURCE: IEC 60050-601:1985, 601-01-28]

3.14
microgrid

<electric power system> group of interconnected loads and distributed energy resources with defined electrical boundaries forming a local electric power system at distribution voltage levels, that acts as a single controllable entity and is able to operate in either grid-connected or island mode

Note 1 to entry: This definition covers both (utility) distribution microgrids and (customer owned) facility microgrids.

[SOURCE: IEC 60050-617:2017, 617-04-22]

3.14.1
isolated microgrid
stand-alone microgrid

group of interconnected loads and distributed energy resources with defined electrical boundaries forming a local electric power system at distribution voltage levels, that cannot be connected to a wider electric power system

Note 1 to entry: Isolated microgrids are usually designed for geographical islands or for rural electrification.

[SOURCE: IEC 60050-617:2017, 617-04-23]

3.14.2
non-isolated microgrid

group of interconnected loads and distributed energy resources with defined electrical boundaries forming a local electric power system at distribution voltage levels, that can be connected to a wider electric power system

[SOURCE: IEC 60050-617:2017, 617-04-23, modified – The definition is a modification of that of "isolated microgrid" (3.14.1).]

3.15
over-voltage ride-through
OVRT

ability of a generating unit or power plant to stay connected during a limited duration rise of system voltage

Note 1 to entry: In some documents the expression "High Voltage Ride Through (HVRT)", is used for the same capability.

3.16
phase locked loop
PLL

feedback circuit for synchronizing an oscillator with the phase of an input signal

[SOURCE: IEC 60050-713:1998, 713-10-48]