PD ISO/PAS 24499:2024

BSI Standards Publication

Method of test for burning velocity measurement of A2L flammable gases

Documents
Document Sharing Hub

Full document details: PD ISO/PAS 24499:2024

National foreword

This Published Document is the UK implementation of ISO/PAS 24499:2024.

The UK participation in its preparation was entrusted to Technical Committee RHE/18, Refrigeration safety.

A list of organizations represented on this committee can be obtained on request to its committee manager.

Contractual and legal considerations

This publication has been prepared in good faith, however no representation, warranty, assurance or undertaking (express or implied) is or will be made, and no responsibility or liability is or will be accepted by BSI in relation to the adequacy, accuracy, completeness or reasonableness of this publication. All and any such responsibility and liability is expressly disclaimed to the full extent permitted by the law.

This publication is provided as is, and is to be used at the recipient's own risk.

The recipient is advised to consider seeking professional guidance with respect to its use of this publication.

This publication is not intended to constitute a contract. Users are responsible for its correct application.

This publication is not to be regarded as a British Standard.

© The British Standards Institution 2024
Published by BSI Standards Limited 2024

ISBN 978 0 539 25418 1

ICS 71.100.45

Compliance with a Published Document cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 31 May 2024.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: PD ISO/PAS 24499:2024

Publicly Available Specification

ISO/PAS 24499

First edition
2024-05

Method of test for burning velocity measurement of A2L flammable gases

Méthode d'essai pour mesurer la vitesse d'inflammabilité des gaz inflammables A2L

Reference number
ISO/PAS 24499:2024(en)

© ISO 2024

Documents
Document Sharing Hub

Full document details: PD ISO/PAS 24499:2024

COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

Contents

Page

Foreword ... **v**
Introduction ... **vi**
1 Scope ... **1**
2 Normative references ... **1**
3 Terms and definitions ... **1**
4 General test method ... **2**
4.1 General ... 2
4.2 Principle of the test method ... 2
5 Measurement parameters ... **4**
5.1 General ... 4
5.2 Flame propagation velocity ... 4
5.3 Flame front area ... 5
5.4 Cross-sectional area of the flame base ... 5
6 Test method ... **5**
6.1 General ... 5
6.2 Gas handling and mixtures preparation ... 6
6.3 The test tube ... 7
6.3.1 General ... 7
6.3.2 Dimensions ... 8
6.3.3 Position ... 9
6.3.4 Tube ends ... 9
6.3.5 Interchangeable damping orifices ... 9
6.3.6 Flame quenching ... 10
6.3.7 Tube glass type ... 10
6.3.8 Tube purging with test mixture ... 10
6.3.9 Tube etching ... 10
6.4 Ignition ... 11
6.4.1 General ... 11
6.4.2 Ignition type ... 11
6.4.3 Positioning ... 11
6.4.4 Electrodes ... 11
6.4.5 Power supply ... 11
6.4.6 Ignition time ... 11
6.5 Flame front visualization ... 12
6.5.1 General ... 12
6.5.2 Luminous zone and direct photography ... 12
6.5.3 Flame emission spectra ... 12
6.5.4 Acquisition camera ... 12
6.5.5 Exposure Time ... 13
6.5.6 Positioning ... 13
6.5.7 Scaling and optical distortion ... 13
6.5.8 Resolution of the flame images ... 14
6.6 Purge, exhaust and gas treatment systems ... 14
6.7 Test temperature setting ... 15
6.8 Experimental protocol for mixtures prepared using partial pressure technique ... 16
7 Evaluation and expression of results ... **16**
7.1 General ... 16
7.2 Uncertainty ... 17
7.2.1 Uncertainty in the burning velocity ... 17
7.2.2 Uncertainty estimation of concentrations ... 17
8 Safety precautions ... **17**

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

9 Overview on flame shape, propagation regimes and stability **18**
9.1 Flame shape 18
9.2 Flame propagation regimes 19
9.3 Flame stability in tubes 20
9.4 Observations of flames in tubes 21
9.5 Flame quenching in circular tubes 21
9.6 Flame propagation velocity and tube diameter 22
9.7 Flame area calculation 22

Bibliography **24**

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 8, *Refrigerants and refrigeration lubricants*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

Introduction

Safety classification and relative flammability properties of refrigerants are a critical part of ISO 817. The flammability limits of refrigerant gas in air, as described in Annex B of ISO 817:—[1)] give a partial measure of the relative flammability. Another dimension of flammability is how fast a substance burns, releases energy and spreads a flame. One can measure the rate at which a flame front moves through a cloud of refrigerant gas in air, or its burning velocity (BV). This document describes one method that can be useful for BV measurement, and thereby better quantify and compare relative flame fronts for some refrigerant classes. In this test, a flame is allowed to propagate upward (vertically) through a well-mixed, quiescent column of a refrigerant-air mixture enclosed in an open-ended glass tube. Optical systems are used to measure the upward velocity of the flame front.

The measurement of BV has been widely used in the past to compare highly energetic fluids, such as motor fuels and rocket propellants. The BV measurement of slow burning fluids, such as ammonia and fluorinated refrigerants can be more difficult to measure due to the inherent instability of a slow flame. The low rate of energy evolution from a slow flame makes it susceptible to quenching from a variety of sources. For slow burning refrigerants, turbulence and convection currents, can break the flame front, and hence quench the flame. In addition, the test chamber surface can quench free radical flame intermediates as well as extract some of the heat necessary for flame propagation. Gas-phase thermal radiation is also important for flames with low burning velocity. These effects are important to note as they tend to diminish and sometimes quench a weak flame.

The use of the vertical tube method for BV characterization of slow burning refrigerants was the subject of doctoral research which was used in Annex C of ISO 817:— and is the basis for this document.[1] In addition, ASHRAE research notes the use and limitations of the vertical tube technique.[2][3] While the basic framework of the method is relatively simple, some sophisticated imaging instrumentation and mathematics are necessary to extract an average local burning velocity separate from the bulk burning speed as the flame progresses up the tube. Since 2004 other laboratories have used the basic principle of vertical tube method and have shown acceptable results for reproducing the measurement of R-32, at 6,7 +/- 0,7 cm/s. Slower burning velocities (i.e. <4 cm/s) become more difficult to measure reproducibility, so variability may increase as flame instability is increasing. The lower burning velocity limit of this method, as described, is between 3 cm/s and 4 cm/s, depending on the actual design and geometry of the apparatus being used. The uncertainty of the measurement of flames that burn more slowly than R-32 has not yet been determined in any multi lab comparative testing. The appealing aspects of this test are the relative simplicity and low cost of its implementation.

1) Under preparation. Stage at the time of publication: ISO/DIS 817:2023.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

Method of test for burning velocity measurement of A2L flammable gases

1 Scope

This document specifies a method of measuring the burning velocity (BV) of slowing burning refrigerants (< 10 cm/s) for use with other standards that utilize the BV for determining safety classification of refrigerants (e.g. ISO 817) or that use the BV in establishing requirements on the use of slow burning refrigerants (e.g. ISO 5149).

2 Normative references

There are no normative references in this document.

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

— ISO Online browsing platform: available at https://www.iso.org/obp

— IEC Electropedia: available at https://www.electropedia.org/

3.1
blends
mixtures composed of two or more refrigerants

3.2
burning velocity
S_u
maximum velocity at which a laminar *flame* propagates in a normal direction relative to the unburned gas ahead of it

Note 1 to entry: This value is expressed in centimetres per second.

3.3
combustion
exothermic reaction between an oxidant (e.g. air) and a combustible fuel

3.4
compound
substance composed of two or more atoms chemically bonded in definite proportions

3.5
flame
space where combustion takes place, resulting in a temperature increase and light emission

3.6
flame propagation
combustion, causing a continuous *flame* which moves upward and outward from the point of ignition without the influence of the ignition source

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

3.7
flame propagation velocity
S_s
velocity at which the continuous *flame* moves upward and outward from the point of ignition without the point of ignition and without the influence of the ignition source

3.8
flame surface area
A_f
surface area of the *flame* generated during the combustion of the *flammable* gas

3.9
flammable
property of a mixture in which a *flame* is capable of self-propagating

3.10
quenching
effect of extinction of the flame near a surface due to heat conduction losses, absorption of active chemical species and viscous effects of the surface

3.11
refrigerant
fluid used for heat transfer in a refrigerating system, which absorbs heat at a low temperature and a low pressure of the fluid and rejects it at a higher temperature and a higher pressure of the fluid usually involving changes of the phase of the fluid

3.12
stoichiometric concentration
C_{st}
concentration of a fuel in a fuel-air mixture that contains exactly the necessary quantity of air (approximately 21 % O_2 / 79 % N_2 by volume) needed for the complete oxidation of all the compounds (3.1.4) present

4 General test method

4.1 General

The test method is based on:

a) the initiation of the combustion of the gas, or blends of gases, in a stagnant homogeneous mixture with air contained in a vertical cylindrical tube;

b) the observation and the recording of the flame propagation;

c) determining the surface area of the flame.

The burning velocity is a function of the flammable gas concentration in the total mixture with air. The burning velocity reaches a maximum in the vicinity of the stoichiometric concentration.

This test method involves the use of hazardous substances and therefore requires, for a safe handling and testing, the knowledge of safety parameters and prevention measures. These measures shall be the user's responsibility. However, general safety precautions are given in Clause 8.

4.2 Principle of the test method

The test method consists of initiating the combustion of a homogeneous mixture of a flammable gas (or a flammable mixture of gases) and air, contained in a vertical tube opened at the lower ignition end, and propagating a flame upwardly to the upper closed end; see Figure 1. In the early stages of this propagation, there is a phase of uniform movement during which the shape and the size of the flame are constant.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024

Taking into account the mass and species balance through the flame front, the burning velocity, S_u, is calculated from the knowledge of the flame propagation velocity, S_s, in the tube and the ratio of the flame front area to its base cross-sectional area. The volume of burned gas per second and per unit area, or the burning velocity, S_u, is obtained by dividing the mixture volume which is consumed per second, at the test temperature and pressure, by the flame surface area, A_f (the subscript "f" denotes the flame). The volume consumption of the mix per second is the volume swept by a cross-sectional area of the flame base, a_f, with a velocity equal to the flame propagation velocity S_s. Formula (1) is used to determine volume consumption per unit time.

$$S_u = S_s \times \frac{a_f}{A_f} \tag{1}$$

where

a_f is the cross-sectional area of the flame base;

A_f is the flame surface area;

S_s is the flame propagation velocity;

S_u is the burning velocity.

NOTE The cross-sectional area of the flame base is equal to the tube cross-section reduced by the quenching area (the area between the edge of the flame and the tube wall).

At a given temperature and pressure, the burning velocity is only a function of the type of flammable substance and its concentration with the oxidant and is dependent to a limited extent on the experimental apparatus.

© ISO 2024 – All rights reserved

Documents
Document Sharing Hub
Full document details: PD ISO/PAS 24499:2024