

SEMI C6.4-90 (Reapproved 1111) PARTICLE SPECIFICATION FOR GRADE 20/0.02 NITROGEN (N₂) AND ARGON (Ar) DELIVERED AS PIPELINE GAS

This Standard was technically approved by the global Gases Technical Committee. This edition was approved for publication by the global Audits and Reviews Subcommittee on September 12, 2011. Available at www.semiviews.org and www.semi.org in November 2011; originally published in 1990; previously published November 2002.

NOTICE: This Document was reapproved with minor editorial changes.

1 Purpose

1.1 The purposes of this Document are: (1) to set a maximum permissible particle concentration for 20/0.02 grade nitrogen and argon bulk supply gases, and (2) to describe a reference method for its verification.

2 Scope

2.1 This Document applies only to nitrogen gas and argon gas delivered through pipelines; it is not applicable to cylinder gases or gases in their liquid state.

NOTICE: SEMI Standards and Safety Guidelines do not purport to address all safety issues associated with their use. It is the responsibility of the users of the Documents to establish appropriate safety and health practices, and determine the applicability of regulatory or other limitations prior to use.

3 Referenced Standards and Documents

3.1 None.

4 Terminology

4.1 Abbreviations and Acronyms

4.1.1 *CNCs* — condensation nucleus counters

4.1.2 *SCF* — standard cubic feet

4.2 Variables

4.2.1 V_{Mi} — volume of the i^{th} sample interval of the pipeline gas.

4.2.2 V_{Bi} — volume of the i^{th} sample interval of the background.

4.2.3 X_{Mi} — concentration of particles observed in the i^{th} sample interval of the pipeline gas.

4.2.4 X_{Bi} — concentration of particles observed in the i^{th} sample interval of the background.

4.2.5 N_M — number of sample intervals of the pipeline gas.

4.2.6 N_B — number of sample intervals of the background.

4.2.7 $\bar{X}_M$ — average observed concentration of counts in the pipeline gas sample.

4.2.8 $\bar{X}_B$ — average observed concentration of background counts.

4.2.9 $\bar{X}_C$ — calculated concentration of particles in the pipeline gas.

4.2.10 S_M — standard deviation of $\bar{X}_M$.

4.2.11 S_B — standard deviation of $\bar{X}_B$.

4.2.12 S_C — standard deviation of $\bar{X}_C$.

4.3 Definitions

4.3.1 *average observed concentration of counts* ($\bar{X}_M, \bar{X}_B$) — the average concentration of counts, that is:

$$\bar{X}_M = \frac{\sum X_{Mi}}{N_M} \quad \bar{X}_B = \frac{\sum X_{Bi}}{N_B} \quad (1)$$

4.3.2 *calculated concentration of particles* ($\bar{X}_C$) — the concentration of particles in the pipeline gas obtained by correcting the observed concentration in the pipeline gas for the observed concentration in the background, that is:

$$\bar{X}_C = \bar{X}_M - \bar{X}_B \quad (2)$$

4.3.3 *gas sample volume* (V_{Mi}, V_{Bi}) — the volume of the sample interval, expressed in standard liters at standard conditions, 0°C (32°F) and 1.00° atmosphere pressure. Standard cubic feet (SCF) is defined at 21.1°C (70°F) and 1.00° atmosphere pressure.

4.3.4 *standard deviation* (S_M, S_B, S_C) — a statistical measure of the spread of the concentration of the counts or particles. The first two are obtained from the interval and average concentrations and the number of intervals, that is:

$$S_M = \left[\frac{\sum (X_{Mi} - \bar{X}_M)^2}{(N_M - 1)} \right]^{1/2} \quad S_B = \left[\frac{\sum (X_{Bi} - \bar{X}_B)^2}{(N_B - 1)} \right]^{1/2} \quad (3)$$

The third is obtained from the first two, that is:

$$S_C = (S_M^2 + S_B^2)^{1/2} \quad (4)$$

NOTE 1: These expressions are derived from an assumption of a Gaussian (Normal) distribution.

5 Apparatus

5.1 *Particle Counter* — An instrument suitable for counting particles in gaseous nitrogen or argon with a minimum detection efficiency of 90% at 0.02 micrometers as determined by the manufacturer of the particle counter. Condensation nucleus counters (CNCs) typically satisfy this requirement.

5.2 *Pressure Reducer* — An accessory required for counters operated at atmospheric pressure, it should preferably use expansion of the gas through a critical orifice.

6 Test Method

NOTE 2: The details of sampling configuration, measurement procedure, and instrument calibration procedure and frequency must be agreed upon by the user and supplier, taking into account good engineering practice.

6.1 Determine the average observed concentration of counts in the background ($\bar{X}_B$) by passing air, nitrogen or argon, believed to be free of particles of 0.02 micrometers or more in diameter, through the instrument and recording the total number of counts. Count a minimum of 8 sample intervals, each at least 25 standard liters (0.95 SCF) or 30 minutes, whichever is greater. A suggested assembly for performing this test, using a filter which removes particles in this size range, is shown in Figure 1. Calculate $\bar{X}_B$ as defined in § 4. $\bar{X}_B$ must not exceed 2 particles per 25 standard liters.

6.2 The sampling point should be at outlet of system, and sampling lines should be as short as possible.

6.3 A suggested sampling probe configuration for turbulent main line flow is shown in Figure 2. The flow rate in the sampling tube at pipeline pressure should be set so that the mean sampling flow velocity at the probe inlet matches as closely as possible the axial flow velocity in the pipeline. The pitot sampling tube ID should be no less than 2 mm (0.08 inch). The orifice and sampling horn should be sized so that the mean flow velocity at the particle counter probe inlet matches the axial flow velocity in the horn as closely as possible.