

SEMI E99.1-0303

SPECIFICATION FOR SECS-I AND SECS-II PROTOCOL FOR CARRIER ID READER/WRITER FUNCTIONAL STANDARD

This specification was technically approved by the Global Information and Control Committee and is the direct responsibility of the Japanese Information and Control Committee. Current edition approved by the Japanese Regional Standards Committee on January 10, 2003. Initially available at www.semi.org January 2003; to be published March 2003. Originally published June 2000.

1 Purpose

1.1 This document maps the services and data of the Carrier ID Reader/Writer (CIDRW) standard to SECS-II streams and functions and data definitions.

2 Scope

2.1 This document applies to all implementations of CIDRW that use the SECS-II message protocol (SEMI E5).

NOTICE: This standard does not purport to address safety issues, if any, associated with its use. It is the responsibility of the users of this standard to establish appropriate safety and health practices and determine the applicability of regulatory or other limitations prior to use.

3 Referenced Standards

3.1 SEMI Standards

SEMI E4 — SEMI Equipment Communications Standard 1 Message Transfer (SECS-I)

SEMI E5 — SEMI Equipment Communications Standard 2 Message Content (SECS-II)

NOTICE: As listed or revised, all documents cited shall be the latest publications of adopted standards.

4 Terminology

4.1 Abbreviations and Acronyms

4.1.1 *CIDRW* — Carrier ID Reader/Writer; represents both the Reader and the Read/Writer.

4.1.2 *SECS* — SEMI Equipment Communications Standard

5 Physical Requirements

5.1 The CIDRW using the SECS-I protocol shall use a 9-pin female connector.

6 Service Message Mapping

6.1 Table 1 shows the specific SECS-II streams and functions that shall be used for SECS-II implementations of the service messages defined in SEMI E99.

6.2 Request and notification messages are mapped to primary (odd-numbered) SECS-II functions and response messages are mapped to secondary (even-numbered) SECS-II functions.

6.3 In some cases, a common set of parameters allows more than one service to be mapped to the same stream and function, with an additional SECS-II data item used to differentiate between the two services.

Table 1 Services Mapped to SECS-II Messages

Message Name	Stream,Function	SECS-II Name
ChangeState	S18,F13/F14	Subsystem Command Request/Acknowledge
Get Attributes	S18,F1/F2	Read Attribute Request/Data
Get Status	S18,F13/F14	Subsystem Command Request/Acknowledge
Perform Diagnostics	S18,F13/F14	Subsystem Command Request/Acknowledge
Read Data	S18,F5/F6	Read Request/Data
Read ID	S18,F9/F10	Read ID Request/Data
Reset	S18,F13/F14	Subsystem Command Request/Acknowledge
Set Attributes	S18,F3/F4	Write Attribute Request/Acknowledge
Write Data	S18,F7/F8	Write Request/Acknowledge
Write ID	S18,F11/F12	Write ID Request/Acknowledge

7 Service Parameter to Data Item Mapping

7.1 Table 2 shows the mapping between message parameters defined by CIDRW and data items defined by SECS-II. For parameters specified in the definitions of a CIDRW service, either the parameters themselves, or individual elements of complex parameters, map to a specific data item.

Table 2 Service Parameters to Data Item Mapping

Parameter Name	SECS-II Data Item	Format	Values
Attribute ID	ATTRID	20	Name of attribute
Attribute Value	ATTRVAL	20	
Carrier ID	MID	20	20 ₁₆ - 7E ₁₆ (Visible ASCII)
Data	DATA	20	All characters 00H-0FFH
DataSize	DATALLENGTH	52	
DataSeg	DATASEG	20	
PM Information	STATUS	20	“NE” = Normal execution, “MR” = Maintenance required
Result Status	SSACK	20	“NO” = Normal operation; “EE” = Execution error; “CE” = Communication error; “HE” = Hardware error; “TE” = Tag error
Status	List of STATUS	L,4 1. <PMInformation> 2. <AlarmStatus> 3. <OperationalStatus> 4. <HeadStatus>	Current values of PM Information with the corresponding attributes for CIDRW and Head (if applicable). See Tables 4 and 5.
StateRequest	CPVAL	20	“OP”, “MT”

NOTE 1: There are also data items used in SECS-II messages that do not map to specific services parameters. Services with the same set of parameters are mapped to the same SECS-II message by adding an additional data item to differentiate between the services. Table 3 contains the SECS-II data items that have not a corresponding CIDRW service parameter:

Table 3 Additional Data Requirements Table

SECS-II Data Item	Function	Value
SSCMD	Used to differentiate between different subsystem commands indicated.	“ChangeState” “GetStatus” “Perform Diagnostics” “Reset”

8 Data

8.1 CIDRW Attributes

8.1.1 Table 4 specifies the values for the CIDRW attribute identifiers and limitations on values.

Table 4 CIDRW Attribute Definitions

Attribute Name	Description	Access	Format	Value
<i>Fundamental</i>				
“Configuration”	Number of heads.	RO	20	“01”–“31”
“AlarmStatus”	Current CIDRW substate of ALARM STATUS	RO	20	“0” = NO ALARMS “1” = ALARMS