

DEP SPECIFICATION

STEAM TURBINES - SELECTION, TESTING AND INSTALLATION

DEP 31.29.60.10-Gen.

September 2011

ECCN EAR 99

DESIGN AND ENGINEERING PRACTICE



© 2011 Shell Group of companies

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, published or transmitted, in any form or by any means, without the prior written permission of the copyright owner or Shell Global Solutions International BV.

This document contains information that is classified as EAR99 and, as a consequence, can neither be exported nor re-exported to any country which is under an embargo of the U.S. government pursuant to Part 746 of the Export Administration Regulations (15 C.F.R. Parts 746) nor can be made available to any national of such country. In addition, the information in this document cannot be exported nor re-exported to an end-user or for an end-use that is prohibited by Part 744 of the Export Administration Regulations (15 C.F.R. Parts 744).

PREFACE

DEP (Design and Engineering Practice) publications reflect the views, at the time of publication, of Shell Global Solutions International B.V. (Shell GSI) and, in some cases, of other Shell Companies.

These views are based on the experience acquired during involvement with the design, construction, operation and maintenance of processing units and facilities. Where deemed appropriate DEPs are based on, or reference international, regional, national and industry standards.

The objective is to set the recommended standard for good design and engineering practice to be applied by Shell companies in oil and gas production, oil refining, gas handling, gasification, chemical processing, or any other such facility, and thereby to help achieve maximum technical and economic benefit from standardization.

The information set forth in these publications is provided to Shell companies for their consideration and decision to implement. This is of particular importance where DEPs may not cover every requirement or diversity of condition at each locality. The system of DEPs is expected to be sufficiently flexible to allow individual Operating Units to adapt the information set forth in DEPs to their own environment and requirements.

When Contractors or Manufacturers/Suppliers use DEPs, they shall be solely responsible for such use, including the quality of their work and the attainment of the required design and engineering standards. In particular, for those requirements not specifically covered, the Principal will typically expect them to follow those design and engineering practices that will achieve at least the same level of integrity as reflected in the DEPs. If in doubt, the Contractor or Manufacturer/Supplier shall, without detracting from his own responsibility, consult the Principal.

The right to obtain and to use DEPs is restricted, and is granted by Shell GSI (and in some cases by other Shell Companies) under a Service Agreement or a License Agreement. This right is granted primarily to Shell companies and other companies receiving technical advice and services from Shell GSI or another Shell Company. Consequently, three categories of users of DEPs can be distinguished:

- 1) Operating Units having a Service Agreement with Shell GSI or another Shell Company. The use of DEPs by these Operating Units is subject in all respects to the terms and conditions of the relevant Service Agreement.
- 2) Other parties who are authorised to use DEPs subject to appropriate contractual arrangements (whether as part of a Service Agreement or otherwise).
- 3) Contractors/subcontractors and Manufacturers/Suppliers under a contract with users referred to under 1) or 2) which requires that tenders for projects, materials supplied or - generally - work performed on behalf of the said users comply with the relevant standards.

Subject to any particular terms and conditions as may be set forth in specific agreements with users, Shell GSI disclaims any liability of whatsoever nature for any damage (including injury or death) suffered by any company or person whomsoever as a result of or in connection with the use, application or implementation of any DEP, combination of DEPs or any part thereof, even if it is wholly or partly caused by negligence on the part of Shell GSI or other Shell Company. The benefit of this disclaimer shall inure in all respects to Shell GSI and/or any Shell Company, or companies affiliated to these companies, that may issue DEPs or advise or require the use of DEPs.

Without prejudice to any specific terms in respect of confidentiality under relevant contractual arrangements, DEPs shall not, without the prior written consent of Shell GSI, be disclosed by users to any company or person whomsoever and the DEPs shall be used exclusively for the purpose for which they have been provided to the user. They shall be returned after use, including any copies which shall only be made by users with the express prior written consent of Shell GSI. The copyright of DEPs vests in Shell Group of companies. Users shall arrange for DEPs to be held in safe custody and Shell GSI may at any time require information satisfactory to them in order to ascertain how users implement this requirement.

All administrative queries should be directed to the DEP Administrator in Shell GSI.

TABLE OF CONTENTS

1.	INTRODUCTION	4
1.1	SCOPE	4
1.2	DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS	4
1.3	DEFINITIONS	4
1.4	CROSS-REFERENCES	5
1.5	CHANGES FROM PREVIOUS EDITION	5
1.6	COMMENTS ON THIS DEP	6
2.	RESPONSIBILITIES	7
3.	TYPE SELECTION	8
3.1	GENERAL	8
3.2	GENERAL-PURPOSE STEAM TURBINES	8
3.3	SPECIAL-PURPOSE STEAM TURBINES	8
3.4	IMPULSE TURBINES VERSUS REACTION TURBINES	8
3.5	SELECTION	9
4.	INSTALLATION AND CONFIGURATION	10
5.	NOISE LEVELS	12
5.1	LIMITS	12
5.2	INFORMATION TO BE SUBMITTED WITH THE TENDER	12
6.	MATERIALS	13
6.1	GENERAL	13
6.2	MATERIALS CERTIFICATION	13
7.	INSPECTION	14
7.1	GENERAL-PURPOSE STEAM TURBINES	14
7.2	SPECIAL-PURPOSE STEAM TURBINES	14
8.	GENERAL-PURPOSE STEAM TURBINES	15
8.1	GENERAL	15
8.2	VIBRATION	15
8.3	LUBRICATION	15
8.4	MAINTENANCE	16
9.	SPECIAL-PURPOSE STEAM TURBINES	17
9.1	GENERAL	17
9.2	ACCESSORIES	17
10.	REFERENCES	19

1. INTRODUCTION

1.1 SCOPE

This DEP specifies requirements and gives recommendations for the type selection, testing and installation of steam turbines.

This DEP is a revision of the DEP of the same title and number dated April 2003. A summary of changes from the previous edition is listed in (1.5).

1.2 DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS

Unless otherwise authorised by Shell GSI, the distribution of this DEP is confined to Shell companies and, where necessary, to Contractors and Manufacturers/Suppliers nominated by them. Any authorised access to DEPs does not for that reason constitute an authorization to any documents, data or information to which the DEPs may refer.

This DEP is intended for use in oil refineries, chemical plants, gas plants and, where applicable, exploration and production facilities and supply/marketing installations.

When DEPs are applied, a Management of Change (MOC) process should be implemented. This is of particular importance when existing facilities are to be modified.

If national and/or local regulations exist in which some of the requirements could be more stringent than in this DEP, the Contractor shall determine by careful scrutiny which of the requirements are the more stringent and which combination of requirements will be acceptable with regards to the safety, environmental, economic and legal aspects. In all cases the Contractor shall inform the Principal of any deviation from the requirements of this DEP which is considered to be necessary in order to comply with national and/or local regulations. The Principal may then negotiate with the Authorities concerned, the objective being to obtain agreement to follow this DEP as closely as possible.

1.3 DEFINITIONS

1.3.1 General definitions

The **Contractor** is the party that carries out all or part of the design, engineering, procurement, construction, commissioning or management of a project or operation of a facility. The Principal may undertake all or part of the duties of the Contractor.

The **Manufacturer/Supplier** is the party that manufactures or supplies the turbine and provides associated back-up services to perform the duties specified by the Contractor.

The **Principal** is the party that initiates, and ultimately pays for, the project. The Principal will generally specify the technical requirements. The Principal may also include an agent or consultant, authorised to act for the Principal.

The **Purchaser** is the party that buys the turbine and its auxiliaries for its own use or as agent for the owner. The Purchaser may be either the Principal or the Contractor.

The word **shall** indicates a requirement.

The word **should** indicates a recommendation.

1.3.2 Specific definitions

Continuous service: A service in which it is not expected that the turbine will have to be started/stopped during normal plant operation.

Intermittent service: A service in which it is expected that the turbine will be started/stopped at unspecified intervals, e.g.,

- automatic starts and stops at intervals by process operated controls;
- manual starts and stops at intervals by manual control for batch processes.

NOTE: The above two definitions are independent of the requirements for service life, which shall be in accordance with DEP 31.29.60.30-Gen. (for general-purpose turbines) and DEP 31.29.60.31-Gen. (for special-purpose turbines).

Essential service A service in which failure of equipment renders a plant inoperable or reduces performance to an unacceptable level.

1.4 CROSS-REFERENCES

Where cross-references to other parts of this DEP are made, the referenced section number is shown in brackets. Other documents referenced by this DEP are listed in (10).

1.5 CHANGES FROM PREVIOUS EDITION

The previous edition of this DEP was dated April 2003. There have been editorial changes, and information added to retain knowledge from OU standards.

Old section	New Section	Change
1.3.2 Specific definitions	1.3.2 Specific definitions	Added definition for essential service
3.3 Special Purpose Steam Turbines	3.3 Special Purpose Steam Turbines	Added "Shall be specified as horizontal"
3.5 Selection	3.5 Selection	Added paragraphs that provide guidance on the design decisions that effect efficiency, from 11 EG 612.
4.0 Installation and Configuration	4.0 Installation and Configuration	Added paragraphs that guide instrumentation and water wash decisions, from 11 EG 611.
7.1 General Purpose Steam Turbines	7.1 General Purpose Steam Turbines	Removed note.
8.3 Lubrication	8.3 Lubrication	Removed comments and note regarding dry gas seals.
none	8.4 Maintenance	Added paragraph describing recommendations to facilitate Maintenance.
10.0 References	10.0 References	Updated references

1.6 COMMENTS ON THIS DEP

Comments on this DEP may be sent to the Administrator at standards@shell.com, using the DEP Feedback Form. The DEP Feedback Form can be found on the main page of “DEPs on the Web”, available through the Global Technical Standards web portal <http://www.shell.com/standards> and on the main page of the DEPs DVD-ROM.