

DEP SPECIFICATION

INSTRUMENT ASSET MANAGEMENT

DEP 32.30.20.14-Gen.

February 2012

DESIGN AND ENGINEERING PRACTICE



© 2012 Shell Group of companies

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, published or transmitted, in any form or by any means, without the prior written permission of the copyright owner or Shell Global Solutions International BV.

PREFACE

DEP (Design and Engineering Practice) publications reflect the views, at the time of publication, of Shell Global Solutions International B.V. (Shell GSI) and, in some cases, of other Shell Companies.

These views are based on the experience acquired during involvement with the design, construction, operation and maintenance of processing units and facilities. Where deemed appropriate DEPs are based on, or reference international, regional, national and industry standards.

The objective is to set the standard for good design and engineering practice to be applied by Shell companies in oil and gas production, oil refining, gas handling, gasification, chemical processing, or any other such facility, and thereby to help achieve maximum technical and economic benefit from standardization.

The information set forth in these publications is provided to Shell companies for their consideration and decision to implement. This is of particular importance where DEPs may not cover every requirement or diversity of condition at each locality. The system of DEPs is expected to be sufficiently flexible to allow individual Operating Units to adapt the information set forth in DEPs to their own environment and requirements.

When Contractors or Manufacturers/Suppliers use DEPs, they shall be solely responsible for such use, including the quality of their work and the attainment of the required design and engineering standards. In particular, for those requirements not specifically covered, the Principal will typically expect them to follow those design and engineering practices that will achieve at least the same level of integrity as reflected in the DEPs. If in doubt, the Contractor or Manufacturer/Supplier shall, without detracting from his own responsibility, consult the Principal.

The right to obtain and to use DEPs is restricted, and is granted by Shell GSI (and in some cases by other Shell Companies) under a Service Agreement or a License Agreement. This right is granted primarily to Shell companies and other companies receiving technical advice and services from Shell GSI or another Shell Company. Consequently, three categories of users of DEPs can be distinguished:

- 1) Operating Units having a Service Agreement with Shell GSI or another Shell Company. The use of DEPs by these Operating Units is subject in all respects to the terms and conditions of the relevant Service Agreement.
- 2) Other parties who are authorised to use DEPs subject to appropriate contractual arrangements (whether as part of a Service Agreement or otherwise).
- 3) Contractors/subcontractors and Manufacturers/Suppliers under a contract with users referred to under 1) or 2) which requires that tenders for projects, materials supplied or - generally - work performed on behalf of the said users comply with the relevant standards.

Subject to any particular terms and conditions as may be set forth in specific agreements with users, Shell GSI disclaims any liability of whatsoever nature for any damage (including injury or death) suffered by any company or person whomsoever as a result of or in connection with the use, application or implementation of any DEP, combination of DEPs or any part thereof, even if it is wholly or partly caused by negligence on the part of Shell GSI or other Shell Company. The benefit of this disclaimer shall inure in all respects to Shell GSI and/or any Shell Company, or companies affiliated to these companies, that may issue DEPs or advise or require the use of DEPs.

Without prejudice to any specific terms in respect of confidentiality under relevant contractual arrangements, DEPs shall not, without the prior written consent of Shell GSI, be disclosed by users to any company or person whomsoever and the DEPs shall be used exclusively for the purpose for which they have been provided to the user. They shall be returned after use, including any copies which shall only be made by users with the express prior written consent of Shell GSI. The copyright of DEPs vests in Shell Group of companies. Users shall arrange for DEPs to be held in safe custody and Shell GSI may at any time require information satisfactory to them in order to ascertain how users implement this requirement.

All administrative queries should be directed to the DEP Administrator in Shell GSI.

TABLE OF CONTENTS

1.	INTRODUCTION	4
1.1	SCOPE.....	4
1.2	DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS	4
1.3	DEFINITIONS	4
1.4	CROSS-REFERENCES	6
1.5	COMMENTS ON THIS DEP	6
2.	INSTRUMENT ASSET MANAGEMENT MINIMUM REQUIREMENTS.....	7
3	HART, FOUNDATION, FIELDBUS, WIRELESS, AND OTHER COMMUNICATION PROTOCOLS.....	9
3.1	HART AND NAMUR NE 43 (BAD PV HANDLING)	9
3.2	ROLE BASED SECURITY / AREA ACCESS	9
3.3	DEVICE ACCESS SAFETY APPLICATIONS	9
3.4	REMOTE ACCESS	9
3.5	DEVICE CONNECTION AND PROTOCOLS	10
3.6	CONNECTIVITY AND TOOLS	10
4.	CONFIGURATION MANAGEMENT (ON-LINE / OFF-LINE)	11
4.1	TEMPLATES.....	11
4.2	DATA MANAGEMENT	11
4.3	DATABASE MANAGEMENT	11
4.4	INTEGRATED HOST DIAGNOSTICS.....	11
4.5	NAMUR NE 107 MAINTENANCE ALARM PRIORITY GROUPS	11
4.6	SYSTEM AND TOOL INTEGRATION	12
4.7	HUMAN INTERFACE AND NAVIGATION	12
5.	LIFECYCLE WORK PROCESSES	13
5.1	DEFINE PHASE (FEED).....	13
5.2	DESIGN (IMPLEMENT AND FAT) PHASE	13
5.3.	FAT	13
5.4	COMMISSIONING PHASE.....	14
6.	REFERENCES	15

1. INTRODUCTION

1.1 SCOPE

This new DEP specifies requirements and gives recommendations for Instrument Asset Management Systems (IAMS) and all smart instruments/devices connected to Distributed Control Systems (DCS), Safety Instrumented Systems (SIS), and Fire and Gas Systems (FGS). Basically all smart devices connected to any Process Automation System (PAS) in a production unit/plant.

1.2 DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS

Unless otherwise authorised by Shell GSI, the distribution of this DEP is confined to Shell companies and, where necessary, to Contractors and Manufacturers/Suppliers nominated by them. Any authorized access to DEPs does not for that reason constitute an authorization to any documents, data or information to which the DEPs may refer.

This DEP is intended for use in facilities related to oil and gas production, gas handling, oil refining, chemical processing, gasification, distribution and supply/marketing. This DEP may also be applied in other similar facilities.

When DEPs are applied, a Management of Change (MOC) process shall be implemented; this is of particular importance when existing facilities are to be modified.

If national and/or local regulations exist in which some of the requirements could be more stringent than in this DEP, the Contractor shall determine by careful scrutiny which of the requirements are the more stringent and which combination of requirements will be acceptable with regards to the safety, environmental, economic and legal aspects. In all cases the Contractor shall inform the Principal of any deviation from the requirements of this DEP which is considered to be necessary in order to comply with national and/or local regulations. The Principal may then negotiate with the Authorities concerned, the objective being to obtain agreement to follow this DEP as closely as possible.

1.3 DEFINITIONS

1.3.1 General definitions

The **Contractor** is the party that carries out all or part of the design, engineering, procurement, construction, commissioning or management of a project or operation of a facility. The Principal may undertake all or part of the duties of the Contractor.

The **Manufacturer/Supplier** is the party that manufactures or supplies equipment and services to perform the duties specified by the Contractor.

The **Principal** is the party that initiates the project and ultimately pays for it. The Principal may also include an agent or consultant authorised to act for, and on behalf of, the Principal.

The word **shall** indicate a requirement.

The word **should** indicate a recommendation.

1.3.2 Specific definitions

Term	Definition
Alarm (alert/event/warning) setpoint	Pre-set value of a parameter at which an alarm is activated to warn of a condition that requires immediate evaluation or corrective action.
Availability	Measure of probability that a machine will, when used under specific conditions, operate satisfactorily and effectively when required doing so.
Condition based maintenance	Maintenance governed by condition monitoring programmes, and plant availability.

Term	Definition
DACA (Data Acquisition and Control Architecture)	IT requirements for separation of data flow between the office domain and the process control domain, refer DEP 32.01.20.10-Gen.
Failure	Termination of the ability of an item to perform its required function.
FAR (Field Auxiliary Room)	Room located next to or in the subject plant/unit.
FF-H1	Interface between the Foundation™ fieldbus Host system and the devices. The field network is basically called the H1.
Integrated Host	Basically the DCS/FGS/IPS and the IAMS all together
Main Automation Contractor (MAC)	The selected Supplier for the process automation systems (Full Automation infrastructure) including, but not limited to, networks, databases, servers and controllers.
Monitor system	System comprising signal processing, alarm/shutdown/integrity logic processing, power supply, display/indication, inputs/outputs, and protective relays.
Off-line system	System that allows data capture on a periodic but not automatic basis. It is normally accomplished by manual data collection with time intervals that are typically daily, weekly, or monthly.
On-line system	System that automatically scans information at specific time intervals. The system performs signal processing, alarming, data storage, reporting, etc. This may be continuous or periodic.
OPC (Open Process Control)	Open standard for connectivity and interoperability of industrial automation and enterprise systems.
PAS supplier Toolkit	A set of typical solutions, based on project standards, for implementation of the selected DCS/SIS/FGS, and IAMS.

1.3.3 Abbreviations

Term	Definition
AMS	Asset Management System
BPCS	Basic Process Control System
CFF	Common File Format
DACA	Data Acquisition and Control Architecture
DB	Data Base
DCS	Distributed Control System
DD	Device Description
DTM	Device Type Manager
EDDL	Electronic Device Description Language
EFA	Enterprise Frame Agreements
ERP	Enterprise Resource Planning
FAT	Factory Acceptance Test
FDI	Field device Integration
FDT	Field Device Tool