

DEP SPECIFICATION

POWER TRANSFORMERS
(AMENDMENTS/SUPPLEMENTS TO IEC 60076-1 AND
IEC 60076-11)

DEP 33.65.40.31-Gen.

September 2013

DESIGN AND ENGINEERING PRACTICE



© 2013 Shell Group of companies
All rights reserved. No part of this document may be reproduced, stored in a retrieval system, published or transmitted, in any form or by any means, without the prior written permission of the copyright owner or Shell Global Solutions International BV.

PREFACE

DEP (Design and Engineering Practice) publications reflect the views, at the time of publication, of Shell Global Solutions International B.V. (Shell GSI) and, in some cases, of other Shell Companies.

These views are based on the experience acquired during involvement with the design, construction, operation and maintenance of processing units and facilities. Where deemed appropriate DEPs are based on, or reference international, regional, national and industry standards.

The objective is to set the standard for good design and engineering practice to be applied by Shell companies in oil and gas production, oil refining, gas handling, gasification, chemical processing, or any other such facility, and thereby to help achieve maximum technical and economic benefit from standardization.

The information set forth in these publications is provided to Shell companies for their consideration and decision to implement. This is of particular importance where DEPs may not cover every requirement or diversity of condition at each locality. The system of DEPs is expected to be sufficiently flexible to allow individual Operating Units to adapt the information set forth in DEPs to their own environment and requirements.

When Contractors or Manufacturers/Suppliers use DEPs, they shall be solely responsible for such use, including the quality of their work and the attainment of the required design and engineering standards. In particular, for those requirements not specifically covered, the Principal will typically expect them to follow those design and engineering practices that will achieve at least the same level of integrity as reflected in the DEPs. If in doubt, the Contractor or Manufacturer/Supplier shall, without detracting from his own responsibility, consult the Principal.

The right to obtain and to use DEPs is restricted, and is typically granted by Shell GSI (and in some cases by other Shell Companies) under a Service Agreement or a License Agreement. This right is granted primarily to Shell companies and other companies receiving technical advice and services from Shell GSI or another Shell Company. Consequently, three categories of users of DEPs can be distinguished:

- 1) Operating Units having a Service Agreement with Shell GSI or another Shell Company. The use of DEPs by these Operating Units is subject in all respects to the terms and conditions of the relevant Service Agreement.
- 2) Other parties who are authorised to use DEPs subject to appropriate contractual arrangements (whether as part of a Service Agreement or otherwise).
- 3) Contractors/subcontractors and Manufacturers/Suppliers under a contract with users referred to under 1) or 2) which requires that tenders for projects, materials supplied or - generally - work performed on behalf of the said users comply with the relevant standards.

Subject to any particular terms and conditions as may be set forth in specific agreements with users, Shell GSI disclaims any liability of whatsoever nature for any damage (including injury or death) suffered by any company or person whomsoever as a result of or in connection with the use, application or implementation of any DEP, combination of DEPs or any part thereof, even if it is wholly or partly caused by negligence on the part of Shell GSI or other Shell Company. The benefit of this disclaimer shall inure in all respects to Shell GSI and/or any Shell Company, or companies affiliated to these companies, that may issue DEPs or advise or require the use of DEPs.

Without prejudice to any specific terms in respect of confidentiality under relevant contractual arrangements, DEPs shall not, without the prior written consent of Shell GSI, be disclosed by users to any company or person whomsoever and the DEPs shall be used exclusively for the purpose for which they have been provided to the user. They shall be returned after use, including any copies which shall only be made by users with the express prior written consent of Shell GSI. The copyright of DEPs vests in Shell Group of companies. Users shall arrange for DEPs to be held in safe custody and Shell GSI may at any time require information satisfactory to them in order to ascertain how users implement this requirement.

All administrative queries should be directed to the DEP Administrator in Shell GSI.

TABLE OF CONTENTS

PART I	INTRODUCTION	5
1.1	SCOPE.....	5
1.2	DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS	5
1.3	DEFINITIONS	6
1.4	CROSS-REFERENCES	6
1.5	SUMMARY OF MAIN CHANGES.....	6
1.6	COMMENTS ON THIS DEP	7
PART II	GENERAL REQUIREMENTS	8
1.1	GENERAL	8
PART III	REQUIREMENTS FOR OIL-IMMERSED POWER TRANSFORMERS (AMENDMENTS/SUPPLEMENTS TO IEC 60076-1)	9
1.	SCOPE AND SERVICE CONDITIONS	9
1.2	SERVICE CONDITIONS.....	9
4.	RATING	9
7.	RATING PLATE	9
7.1	INFORMATION TO BE GIVEN IN ALL CASES	10
7.2	INFORMATION TO BE GIVEN IN CERTAIN CASES.....	10
8.	MISCELLANEOUS REQUIREMENTS.....	10
8.1	DIMENSIONS OF NEUTRAL CONNECTION	10
8.4	CONSTRUCTIONAL REQUIREMENTS	10
8.5	ADDITIONAL REQUIREMENTS FOR SEALED TRANSFORMERS	17
8.6	ADDITIONAL REQUIREMENTS FOR CONSERVATOR-TYPE TRANSFORMERS.....	17
9.	TOLERANCES	18
9.1	LOSSES.....	18
9.2	TOLERANCES.....	18
10.	TESTS.....	18
10.1	GENERAL REQUIREMENTS FOR TYPE, ROUTINE AND SPECIAL TESTS.....	18
10.9	INSPECTION AND TESTS.....	19
PART IV	ADDITIONAL REQUIREMENTS FOR DRY-TYPE TRANSFORMERS (AMENDMENTS/SUPPLEMENTS TO IEC 60076-11)	20
1	SCOPE.....	20
4	SERVICE CONDITIONS.....	20
4.1	GENERAL	20
5	TAPPINGS.....	20
8	RATING	20
8.1	GENERAL	20
9	RATING PLATE	20
11	COOLING METHODS AND TEMPERATURE-RISE	20
11.1	NORMAL TEMPERATURE-RISE LIMITS	20
11.4	TEMPERATURE MEASUREMENT	20
31	DEGREES OF PROTECTION PROVIDED BY ENCLOSURES.....	21
34	CORE CONSTRUCTION.....	21
35	NOISE LIMITS	21
PART V	ADDITIONAL REQUIREMENTS FOR KORNDORFER STARTING TRANSFORMERS.....	22
1.	SCOPE.....	22

2.	DEFINITIONS	22
2.1	CHARACTERISTICS	22
3.	RATINGS	22
4.	DESIGN AND CONSTRUCTION	22
4.1	DESIGN COORDINATION	22
4.2	PERFORMANCE REQUIREMENTS	22
4.3	LIFETIME AND RELIABILITY	22
5.	TESTS.....	23
5.1	TYPE TESTS	23
5.2	ROUTINE TESTS	23
PART VI	DOCUMENTATION REQUIREMENTS.....	24
1.	GENERAL.....	24
2.	MANUFACTURER'S DRAWINGS AND DOCUMENTS.....	24
3.	TEST REPORTS	24
PART VII	REFERENCES	25

APPENDICES

APPENDIX 1	PREFERRED RATINGS, IMPEDANCES AND VOLTAGES	27
APPENDIX 2	DIMENSIONS OF HV CABLE CONNECTING BOXES	28
APPENDIX 3	ANNUITY TABLE.....	29
APPENDIX 4	SUMMARY OF TESTS.....	31

PART I INTRODUCTION

1.1 SCOPE

This DEP specifies requirements and gives recommendations for power transformers.

This DEP is based on the following parts of IEC 60076, and provides amendments and supplements to the relevant IEC standard where indicated:

- IEC 60076-1:2011, as amended/supplemented by this DEP in (Part III);
- IEC 60076-2:2011
- IEC 60076-3:2000
- IEC 60076-4:2002
- IEC 60076-5:2006
- IEC 60076-7:2005
- IEC 60076-8:1997
- IEC 60076-10:2001
- IEC 60076-11:2004, as amended/supplemented by this DEP in (Part IV).
- IEC 60076-12:2008

Part III of this DEP covers oil-immersed power transformers and is written as amendments/supplements to IEC 60076-1:2000.

Part IV covers the additional requirements for dry-type transformers, and is written as amendments/supplements to IEC 60076-11:2004. These transformers are also required to comply with the relevant parts of Part III.

Part V covers the requirements for Korndorfer starting transformers.

Part VI covers the documentation requirements.

Part VII contains references.

For ease of reference, the clause (or paragraph) numbering of the relevant IEC standard has been used throughout (Part III) and (Part IV). Clauses not mentioned apply as written.

The corresponding Requisition is provided in DEP 33.65.40.93-Gen.

This DEP is a revision of the DEP of the same number, dated September 2011; see (1.5) regarding the main changes.

1.2 DISTRIBUTION, INTENDED USE AND REGULATORY CONSIDERATIONS

Unless otherwise authorised by Shell GSI, the distribution of this DEP is confined to Shell companies and, where necessary, to Contractors and Manufacturers/Suppliers nominated by them. Any authorised access to DEPs does not for that reason constitute an authorisation to any documents, data or information to which the DEPs may refer.

This DEP is intended for use in facilities related to oil and gas production, gas handling, oil refining, chemical processing, gasification, distribution and supply/marketing. This DEP may also be applied in other similar facilities.

When DEPs are applied, a Management of Change (MOC) process shall be implemented; this is of particular importance when existing facilities are to be modified.

If national and/or local regulations exist in which some of the requirements could be more stringent than in this DEP, the Contractor shall determine by careful scrutiny which of the requirements are the more stringent and which combination of requirements will be acceptable with regards to the safety, environmental, economic and legal aspects. In all cases, the Contractor shall inform the Principal of any deviation from the requirements of this DEP which is considered to be necessary in order to comply with national and/or local

regulations. The Principal may then negotiate with the Authorities concerned, the objective being to obtain agreement to follow this DEP as closely as possible.

1.3 DEFINITIONS

1.3.1 General definitions

The **Contractor** is the party that carries out all or part of the design, engineering, procurement, construction, commissioning or management of a project or operation of a facility. The Principal may undertake all or part of the duties of the Contractor.

The **Manufacturer/Supplier** is the party that manufactures or supplies equipment and services to perform the duties specified by the Contractor.

The **Principal** is the party that initiates the project and ultimately pays for it. The Principal may also include an agent or consultant authorised to act for, and on behalf of, the Principal.

The word **shall** indicates a requirement.

The word **should** indicates a recommendation.

The **Requisition** sheet is DEP 33.65.40.93-Gen.

1.3.2 Specific definitions

Term	Definition
Off-Circuit tap-changer:	A device for changing the voltage ratio of the transformer only after the transformer has been isolated from the high voltage and low voltage sources.

1.4 CROSS-REFERENCES

Where cross-references to other parts of this DEP are made, the referenced section or clause number is shown in brackets (). Other documents referenced by this DEP are listed in (Part VII).

1.5 SUMMARY OF MAIN CHANGES

This DEP is a revision of the DEP of the same number dated September 2011. The following are the main, non-editorial changes.

Section	Change
Part I; 1.6	Updated feedback submission process with the latest forms.
Part III; 8.4.5	Reference to revised nomenclature in IEC 60296 added.
Part III; 8.4.19.1 c)	Requirement added: "A clear warning notice shall be displayed to warn the operator not to manually operate the drive mechanism with the transformer energised."
Part III; 10.9	Requirement for soap or vacuum test added.
Part IV	Added DEP Feedback Form - DEP 00.00.05.80-Gen.

1.6 COMMENTS ON THIS DEP

Comments on this DEP may be submitted to the Administrator using one of the following options:

Shell DEPs Online (Users with access to Shell DEPs Online)	Enter the Shell DEPs Online system at https://www.shelldeps.com Select a DEP and then go to the details screen for that DEP. Click on the "Give feedback" link, fill in the online form and submit.
DEP Feedback System (Users with access to Shell Wide Web)	Enter comments directly in the DEP Feedback System which is accessible from the Technical Standards Portal http://swwww.shell.com/standards . Select "Submit DEP Feedback", fill in the online form and submit.
DEP Standard Form (Other users)	Use DEP Standard Form 00.00.05.80-Gen. to record feedback and email the form to the Administrator at standards@shell.com .

Feedback that has been registered in the DEP Feedback System by using one of the above options will be reviewed by the DEP Custodian for potential improvements to the DEP.

PART II GENERAL REQUIREMENTS

1.1 GENERAL

Transformers shall comply with the following parts of IEC 60076:

- a) IEC 60076-1:2011, as amended/supplemented by this DEP in (Part III);
- b) IEC 60076-2:2011
- c) IEC 60076-3:2000
- d) IEC 60076-4:2002
- e) IEC 60076-5:2006
- f) IEC 60076-7:2005
- g) IEC 60076-8:1997
- h) IEC 60076-10:2001
- i) IEC 60076-11:2004, as amended/supplemented by this DEP in (Part IV).
- j) IEC 60076-12:2008

(Part III) of this DEP is written as amendments and supplements to IEC 60076-1:2011. Wherever reference is made to IEC 60076-1, it shall be understood to mean IEC 60076-1:2011 as amended/supplemented by this DEP.

(Part IV) covers the additional requirements for dry-type transformers, and is written as amendments and supplements to IEC 60076-11:2004. Wherever reference is made to IEC 60076-11, it shall be understood to mean IEC 60076-11:2004 as amended/supplemented by this DEP. These transformers shall also comply with the relevant parts of (Part III).

For ease of reference, the clause (or paragraph) numbering of the relevant IEC standard has been used throughout (Part III) and (Part IV). Clauses not mentioned shall apply as written. Clauses in the relevant IEC standard which are not mentioned in this DEP shall remain valid as written.

(Part V) of this DEP covers the requirements for Korndorfer starting transformers, and shall be read in conjunction with all relevant clauses elsewhere in this DEP.

Documentation for all transformers shall be in accordance with (Part VI).

The corresponding Requisition, DEP 33.65.40.93-Gen. has been extended to cover more project-specific transformer requirements. The requisition shall be completed and returned by the Manufacturer as part of the quotation.

PART III REQUIREMENTS FOR OIL-IMMERSED POWER TRANSFORMERS (AMENDMENTS/SUPPLEMENTS TO IEC 60076-1)

1. SCOPE AND SERVICE CONDITIONS

1.2 SERVICE CONDITIONS

Add to this clause:

Transformers shall have a design lifetime of at least 25 years, when delivering rated output under the service conditions specified and maintained according to the Manufacturer's recommendation.

Transformers shall be suitable for continuous operation at full load for at least 40,000 hours without maintenance requiring the transformer to be de-energised.

The system supply voltage and frequency will not vary more than:

Voltage : plus or minus 5 %

Frequency : plus or minus 2 %

The Requisition identifies the maximum site ambient temperature, for either outdoor or indoor transformer installations. Unless otherwise specified in the Requisition, the maximum average daily temperature shall be 10 °C less than the maximum site ambient temperature, and the maximum average annual temperature shall be 20 °C less than the maximum site ambient temperature. The relative humidity shall be taken to be 90 % maximum.

The atmosphere shall be regarded as dusty, sulphurous, salty and corrosive, as commonly encountered in petrochemical installations in close proximity to the sea.

Transformers for outdoor operation shall be designed to operate without protective shelter. The effect of rapid changes in ambient temperature shall also be incorporated in the design.

4. RATING

Add to this clause:

The Requisition identifies the duty of the transformer, e.g. generator transformer.

All "general service" transformers may be used to feed groups of motors and shall be capable of withstanding infrequent restarting loads of up to 1.8 times the transformer's rated current. Five such restarts may take place in succession at 5-second intervals.

Motor unit transformers, i.e., transformers supplying individual motors and Korndorfer starting transformers shall be capable of withstanding three successive motor starts and a further two successive starts after a half-hour cooling-off period. Motor data are stated on the Requisition.

The transformer shall be capable of delivering rated current at applied voltages up to 105 % of rated voltage continuously.

NOTE: Preferred ratings are given in (Appendix 1).

7. RATING PLATE

Add to this clause:

Rating plates shall be of stainless steel or other corrosion resistant metal. They shall be permanently fixed to a readily accessible and non-removable part of the transformer.

7.1 INFORMATION TO BE GIVEN IN ALL CASES

Add to this clause:

The Principal's purchase order number shall be stated on the rating plate.

7.2 INFORMATION TO BE GIVEN IN CERTAIN CASES

Add to this clause:

The CT ratios shall be stated on the rating plate.

8. MISCELLANEOUS REQUIREMENTS

8.1 DIMENSIONS OF NEUTRAL CONNECTION

Add to this clause:

The LV neutral conductor and terminal of polyphase, general service transformers shall be located next to the phase terminals and be dimensioned to carry not less than 50 % of the load of the phase conductors and terminals.

Add this clause:

8.4 CONSTRUCTIONAL REQUIREMENTS

8.4.1 General

Tanks shall be constructed of steel.

Oil-immersed transformers rated 1600 kVA and below shall be hermetically sealed. Transformers rated above 1600 kVA and up to 3150 kVA may be either hermetically sealed or of the conservator type. However, hermetically sealed transformers above 3150 kVA shall be subject to the Principal's approval.

For sealed transformers, the space in the tank above the liquid shall be filled with either dry air or dry inert gas.

Transformers with conservators shall be fitted with Buchholz relays, having both alarm and trip contacts.

If required by the Manufacturer, pressure relief devices shall be fitted to transformers above 1600 kVA. If installed, pressure relief devices having a trip contact shall be fitted on the tank cover.

8.4.2 Windings and tappings

Windings shall be uniformly insulated. Transformer windings rated ≤ 5 MVA shall be copper or aluminium. The design and construction of transformers with a power rating > 5 MVA having aluminium windings shall be subject to the Principal's approval.

Full-power tappings shall be provided in the high voltage windings.

Winding connections inside transformers shall be brazed or crimped.

The winding arrangement shall be Dyn11, unless otherwise stated in the Requisition.

Transformers for VSDS and Generator step-up applications shall not be equipped with foil windings.

8.4.3 Core construction

For three-phase transformers, in-line, three-limb cores shall be used.

8.4.4 Core earthing

All metal parts of the core, frame and tank etc. shall be maintained at earth potential.

The magnetic circuit of conservator type transformers exceeding 10 MVA shall be bonded to the clamping structure through one removable core-insulation-test link or strap only. The