



UL 10C

STANDARD FOR SAFETY

Positive Pressure Fire Tests of Door Assemblies

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

This document is only permissible for use by User of . 8/23/2016 1:13:31 PM

UL Standard for Safety for Positive Pressure Fire Tests of Door Assemblies, UL 10C

Third Edition, Dated June 9, 2016

Summary of Topics

The Third Edition of the Standard for Safety for Positive Pressure Fire Tests of Door Assemblies, UL 10C, has been issued to reflect the latest ANSI approval date, and to incorporate the proposal dated April 15, 2016. This proposal includes the following:

- ***Oxygen percentage readings.***

The new requirements are substantially in accordance with Proposal(s) on this subject dated April 15, 2016.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

This document is only permissible for use by User of . 8/23/2016 1:13:31 PM

No Text on This Page

This document is only permissible for use by User of . 8/23/2016 1:13:31 PM

JUNE 9, 2016

1



ANSI/UL 10C-2016

UL 10C

Standard for Positive Pressure Fire Tests of Door Assemblies

Prior to the first edition, the requirements for the products covered by this standard were included in the Standard for Fire Tests of Door Assemblies, UL 10B.

First Edition – February, 1998
Second Edition – January, 2009

Third Edition

June 9, 2016

This ANSI/UL Standard for Safety consists of the Third Edition.

The most recent designation of ANSI/UL 10C as an American National Standard (ANSI) occurred on June 9, 2016. ANSI approval for a standard does not include the Cover Page, Transmittal Pages and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2016 UNDERWRITERS LABORATORIES INC.



Documents

Document Sharing Hub

No Text on This Page

This document is only permissible for use by User of . 8/23/2016 1:13:31 PM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	4
2 General	5
2.1 Units of measurement	5
2.2 Undated references	5

CONTROL OF FIRE TESTS

3 Furnace Construction	5
3.1 Furnace size	5
3.2 Furnace construction materials	5
3.3 Furnace burners	5
4 Time-Temperature Curve	6
4.1 General	6
4.2 Uniformity of temperature distribution	6
5 Furnace Temperatures	7
6 Unexposed Surface Temperatures and Cotton Pad Test	8
7 Furnace Pressure	9

TEST ASSEMBLIES

8 Construction and Size	12
9 Mounting for Test Purposes	12

CONDUCT OF TESTS

10 Supporting Construction	13
11 Fire Endurance Test	13
12 Hose Stream Test	13

REPORT

13 General	14
------------------	----

CONDITIONS OF ACCEPTANCE

14 General	15
15 Specific	15

APPENDIX A

A1 Standard Time-Temperature Curve for Control of Fire Tests	A1
--	----

APPENDIX B

B1 Hose Stream Pattern	B1
------------------------------	----

INTRODUCTION

1 Scope

1.1 These methods of fire tests are applicable to swinging door assemblies, including door frames with lights and panels, of various materials and types of construction for use in wall openings to retard the passage of fire. The method does not provide an evaluation of a swinging door assembly when that assembly is part of a larger assembly (e.g. sliding fire door assembly), or when it is intended to be used as an elevator entrance.

1.2 Tests made in conformity with these test methods are intended to register performance during the test exposure; but such tests shall not be construed as determining suitability for use after exposure to fire.

1.3 It is the intent that tests made in conformity with these test methods allow for the development of data to enable regulatory bodies to determine the suitability of door assemblies for use in locations where fire resistance of a specified duration is required.

1.4 These methods are intended to evaluate the ability of a door assembly to remain in an opening during a predetermined test exposure.

1.5 The tests expose a specimen to a standard fire exposure controlled to achieve specified temperatures throughout a specified time period, followed by the application of a specified standard fire hose stream. The exposure, however, is not representative of all fire conditions, which vary with changes in the amount, nature, and distribution of fire loading, ventilation, compartment size and configuration, and heat sink characteristics of the compartment. It does, however, provide a relative measure of fire performance of door assemblies under these specified fire exposure conditions.

1.6 Any variation from the construction or conditions that are tested is capable of substantially changing the performance characteristics of the assembly.

1.7 The methods do not provide the following:

- a) Full information as to performance of all door assemblies in walls constructed of materials other than those tested.
- b) Evaluation of the degree by which the door assembly contributes to the risk of fire by generation of smoke, toxic gases, or other products of combustion.
- c) A temperature limit on the unexposed side of the door assembly.
- d) A limit on the number of openings allowed in glazed areas or of the number and size of lateral openings between the door and frame.
- e) Measurement of the degree of control or limitation of the passage of smoke or products of combustion through the door assembly. Note: See limitations for the passage of smoke detailed in the Standard for the Installation of Smoke Door Assemblies and Other Opening Protectives, NFPA 105.

2 General

2.1 Units of measurement

2.1.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2 Undated references

2.2.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

CONTROL OF FIRE TESTS

3 Furnace Construction

3.1 Furnace size

3.1.1 The furnace shall be able to accommodate the full-sized sample. Small-scale size furnaces are capable of being used for testing small but full-sized samples or representative features of full-sized samples. The furnace face shall be greater in area than the exposed face of the sample by at least 20 percent. The additional area between the sample and the furnace shall be filled by wall or partition construction.

3.1.2 The furnace shall have a chamber depth, i.e. the distance between the exposed face of the specimen and the face of the furnace lining immediately opposite the specimen, of not less than 23 in (584 mm) and not more than 51 in (1296 mm).

3.2 Furnace construction materials

3.2.1 The furnace shall be constructed of materials which have a greater resistance to heat flow through the other three sides than through the sample.

3.3 Furnace burners

3.3.1 The furnace shall be heated with burners that are fired using either natural gas or liquefied petroleum gases.

3.3.2 The heat output of the burners shall be controllable and shall expose the specimen to a uniform heating as specified in 4.1.1.

3.3.3 The burners shall function so that the fuel gas is introduced into the furnace where the gas mixes with air present in the furnace and then burns; or, as an alternate, the fuel gas is mixed with air prior to its ignition in the furnace.

This document is only permissible for use by User of . 8/23/2016 1:13:31 PM