



UL 1277

STANDARD FOR SAFETY

Electrical Power and Control Tray Cables with
Optional Optical-Fiber Members

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

UL Standard for Safety for Electrical Power and Control Tray Cables with Optional Optical-Fiber Members, UL 1277

Sixth Edition, Dated September 12, 2018

SUMMARY OF TOPICS:

This new edition of ANSI/UL 1277 includes the following changes in requirements:

Addition of 1000 V Rating to UL 1277 for Tray Cable

Addition of ST1 Limited Smoke Surface Marking

Alternate Aging Time and Temperature for 60°C Oil Rating

Durability of Ink Printing Test

The new and/or revised requirements are substantially in accordance with Proposal(s) on this subject dated March 2, 2018 and July 6, 2018.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
Document Sharing Hub

No Text on This Page

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

SEPTEMBER 12, 2018



ANSI/UL 1277-2018

1

UL 1277

Standard for Electrical Power and Control Tray Cables with Optional

Optical-Fiber Members

First Edition – January, 1986
Second Edition – March, 1989
Third Edition – March, 1996
Fourth Edition – November, 2001
Fifth Edition – April, 2010

Sixth Edition

September 12, 2018

This ANSI/UL Standard for Safety consists of the Sixth Edition.

The most recent designation of ANSI/UL 1277 as an American National Standard (ANSI) occurred on September 12, 2018. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2018 UNDERWRITERS LABORATORIES INC.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	5
2 Units of Measurement	6
3 References	6

CONSTRUCTION

4 Materials	6
5 General	6
6 All Conductors	7
7 Compact-Stranded, Sector Conductors	8
8 Grounding Conductors	8
9 Circuit Conductors	11
9.1 General	11
9.2 NEC types	11
9.3 Other insulated conductors	12
9.4 Thermocouple-extension wires	13
9.5 Insulated sector conductors	13
10 Optical-Fiber Member(s)	13
11 Assembly	14
11.1 Optical-fiber member(s) and circuit conductors	14
11.2 Fillers	16
11.3 Binders	16
11.4 Shield(s)	17
11.5 Metal sheath or armor	18
12 Overall Jacket	18
12.1 Material and application	18
12.2 Properties	18
12.3 Thicknesses	20

PERFORMANCE

13 Continuity Test of Conductors	20
14 Dielectric Voltage-Withstand Test	21
15 Vertical-Tray Flame Test	22
16 Limited Smoke	22
17 Cold Bend Test of Complete Cable	22
18 Cold-Impact Test	23
19 Crushing Test – Cable Marked for Direct Burial	23
20 Sunlight-Resistance Test	25
21 Deformation Test of Overall Thermoplastic or XL Jacket	25
22 Heat Shock Test of Overall Thermoplastic Jacket	25
23 Impact Test	26
24 Crushing Test	28
25 Test for Durability of Ink Printing	29
26 Pulling-Through-Joists Test	29

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

MARKINGS

27	Color of Insulated Grounding Conductor	32
28	Identification of Ungrounded Circuit Conductor(s)	33
29	Identification of Grounded Circuit Conductor(s)	33
30	Information on the Cable	34
31	Information on the Tag, Reel, or Carton	37
32	Date of Manufacture	40
33	Insulated Equipment-Grounding Conductors	40
34	Isolated-Grounding Conductors	42
35	Additional Conductor Information	42
36	Compact-Stranded Copper Conductors	43
37	Copper-Clad Aluminum	43
38	Aluminum	44
39	Responsibility for the Insulated Conductors	44
39.1	No identification needed	44
39.2	Only factory identification needed	44
39.3	Organization and factory identification needed	44

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

INTRODUCTION

1 Scope

1.1 These requirements cover electrical power and control cables consisting of either two or more current-carrying copper, aluminum, or copper-clad aluminum circuit conductors, or one or more pairs of thermocouple-extension wires. Thermocouple-extension wires and circuit conductors shall not be mixed in the same cable. These cables are constructed with or without either or both:

- a) One bare or one or more insulated grounding conductor(s), and
- b) One or more individually jacketed optical-fiber members, all under an overall jacket.

These electrical and composite electrical/optical-fiber cables are intended for use (optical and electrical functions associated in the case of a composite cable) in accordance with Article 336 and other applicable parts of the National Electrical Code (NEC), ANSI/NFPA 70 in cable trays, in raceways, and where supported in outdoor locations by a messenger wire.

1.2 The conductors for these cables are described in Sections 9.2 (NEC types) and 9.3 (other conductors). Cables are surface marked with the conductor type letters and/or with the temperature and “wet”, “dry”, or “wet or dry” ratings applicable to the insulation. Cables for direct burial are so marked on the surface. Cables that have a sunlight-resistant jacket are surface marked “sun res” or “sunlight resistant”. Cables may include one or more optical-fiber member(s) and are surface marked to so indicate. Cables that are surface marked “oil resistant II” have a jacket that is for exposure to oil at temperatures not in excess of 75°C (167°F). Cables that are surface marked “oil resistant I” have a jacket that is for exposure to oil at temperatures not in excess of 60°C (140°F). Each insulated conductor that is oil resistant II, oil resistant I, VW-1, gasoline-resistant, or has another individual conductor use is individually so marked. Cables that are surface marked “-ER” are for use as exposed runs between a cable tray and utilization equipment where the cables are continuously supported and protected against physical damage using mechanical protection such as struts, angles, or channel.

1.3 The overall jacket on these cables is a “gas/vapor-tight continuous sheath” in the sense discussed in Sections 501.15(D) and 501.15(E) of the NEC (see 12.1.1). However, these requirements do not cover investigation of these cables for transmission of gases or vapors through the core so, when these cables are used in a hazardous location, they may need to be sealed as described in the NEC.

1.4 These cables may contain one or more metal shields but do not have a metal sheath or armor. Electrical cables with a metal sheath or armor are covered as Type MC in the Standard for Metal-Clad Cables, UL 1569.

1.5 Connectors and other fittings for these cables are covered in the Standard for Conduit, Tubing, and Cable Fittings, UL 514B.

1.6 These requirements do not cover the optical or other performance of any optical-fiber member or group of such members.

2 Units of Measurement

2.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

3 References

3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3.2 Wherever the designation "UL 1581" is used in this wire standard, reference is to be made to the designated part(s) of the Reference Standard for Electrical Wires, Cables, and Flexible Cords, UL 1581. Wherever the designation "UL 2556" is used in this wire standard, reference is to be made to the designated part(s) of the Standard for Wire and Cable Test Methods, UL 2556.

CONSTRUCTION

4 Materials

4.1 Only materials that are acceptable for the particular use shall be employed in a cable.

4.2 Each material used in a cable shall be compatible with all of the other materials used in the cable.

5 General

5.1 Power and control tray cable shall be designated as Type TC and shall comply in all respects with the applicable requirements for construction details, test performance, and markings.

5.2 The electrical insulation in each of the following cables shall be of a material that is acceptable for use in wet locations:

- a) Cable that is marked for direct burial.
- b) Cable that is intended for use in wet locations.

6 All Conductors

6.1 Except for the thermocouple alloy for thermocouple-extension cables, only copper, copper-clad aluminum, or an acceptable aluminum alloy shall be used for the conductors in a cable. Soft-annealed copper shall comply with ASTM B 3. Solid aluminum conductors in sizes 12 – 8 AWG shall comply with the requirements for aluminum-wire stock (aluminum-alloy conductor material). All other aluminum conductors shall comply with the requirements for semi-annealed 8000 series aluminum conductors in Requirements for Aluminum Conductors of an 8000 Series Alloy, Section 10, of the Reference Standard for Electrical Wires, Cables, and Flexible Cords, UL 1581. Copper-Clad aluminum conductors shall comply with the requirements in Requirements for Copper-Clad Aluminum Conductors, Section 11 of UL 1581.

6.2 A copper conductor shall not be smaller than 18 AWG and shall not be larger than 1000 kcmil. An aluminum or copper-clad aluminum conductor shall not be smaller than 12 AWG and shall not be larger than 1000 kcmil.

6.3 Each 6 – 4/0 AWG and 250 – 1000 kcmil conductor shall be stranded. An 18 or 16 AWG copper conductors shall comply with the requirements for fixture wire conductors in the Standard for Fixture Wire, UL 66. A 14 AWG or larger copper, or 12 AWG or larger aluminum conductor shall comply with the requirements in the Standard for Thermoset-Insulated Wires and Cables, UL 44, or in the Standard for Thermoplastic-Insulated Wires and Cables, UL 83, except as modified in this section.

6.4 Any joint in a conductor shall comply with the applicable standard indicated in 9.2, except that a splice is acceptable in an 18 – 10 AWG stranded conductor as a whole if the splice (butt splice) is made by machine brazing or welding such that the resulting solid section of the stranded conductor is not longer than 1/2 inch or 13 mm, the splice does not increase the diameter of the conductor, there are no sharp points, and the distance between splices in a single conductor does not average less than 3000 ft or 915 m in any reel length of that single insulated conductor. A butt splice shall be made before insulating or after insulating and prior to further processing. Butt splices of stranded conductors made after insulating and splices of insulated solid conductors made with other than the original insulation shall be the subject of an investigation that includes tests to determine that all electrical, physical, and mechanical properties of the original system of insulation and any jacket on the conductor have been restored at the point of each splice. All finished, insulated stranded conductors containing a butt splice or splice made with other than the original insulation shall not be marked as an NEC type but, for polarity identification, color coding and/or surface printing of hash marks, numbers, color names, or the like are acceptable.

7 Compact-Stranded, Sector Conductors

7.1 Compact-stranded, sector conductors shall be shaped as a 120° segment of a circle.

7.2 Compact-stranded, sector conductors shall comply with all of the requirements specified for All Conductors, Section 6, with the following exceptions:

- a) Sector conductors shall be limited to sizes 1/0 AWG – 750 kcmil.
- b) The conductor size shall be determined by the test, DC resistance in UL 2556.
- c) For purposes of calculating lay length, the effective diameter of the conductor shall be determined by adding the lengths of the conductor's major and minor axes and dividing by 2. The major axis is defined as the distance from top of the arc to bottom tip, and the minor axis is defined as the distance from left tip to right tip.
- d) Sector conductors are limited to copper only.

8 Grounding Conductors

8.1 The cable may contain one or more grounding conductors. Each grounding conductor that is provided shall be of copper, aluminum, or copper-clad aluminum and shall not be smaller than indicated in the applicable Table 8.1 (90°C or 194°F conductors), Table 8.2 (75°C or 167°F conductors), or Table 8.3 (60°C or 140°F conductors). See 11.4.2(b) (shield as grounding conductor).

8.2 One grounding conductor (bare or insulated) in a flat cable (see 11.1.6 for round cable) may be in one location or in several sections (see size limits in 8.3) or may be distributed helically (concentric – see size limits in 8.4) over all of the conductors in the cable. Every other grounding conductor in a flat cable shall not be sectioned or distributed helically.

8.3 A grounding conductor smaller than 14 AWG shall not be sectioned. A sectioned grounding conductor shall not have any part (section) smaller than 18 AWG. See 6.2.

8.4 A copper grounding conductor smaller than 14 AWG shall not be distributed helically (concentric). A helically distributed grounding conductor shall not have any of its wires smaller than 26 AWG (15.9 mils or 0.404 mm in diameter) if of copper or 22 AWG (25.3 mils or 0.643 mm in diameter) if of aluminum.

8.5 One grounding conductor may be bare. All others shall be insulated. Grounding-conductor insulation and any individual covering over that insulation shall comply with Circuit Conductors, Section 9, as if the insulated grounding conductor were a circuit conductor and shall comply with 11.1.2 (insulation ratings) and 11.1.3 (assembly limits). See 11.1.4 (placement in a flat cable), 11.1.6 (placement in a round cable), 27.1 (color), and Insulated Equipment-Grounding Conductors, Section 33 and Isolated-Grounding Conductors, Section 34, (differentiation).

8.6 Any or all insulated grounding conductors may be designated as isolated-grounding conductors, with the outer surface of each such conductor marked as indicated in Isolated-Grounding Conductors, Section 34. See 11.1.4, 11.1.6 (cabling), 27.1 (color), and 31.1(l) (tag marking).

8.7 Cables marked “-ER” as indicated in 30.1 and 31.1 shall contain one or more grounding conductors, except that a grounding conductor is not required in a cable with three or more circuit conductors and no conductor larger than 6 AWG.

Table 8.1
Smallest grounding conductor in cable containing 90°C (194°F) circuit conductors

Size of largest ungrounded circuit conductor in cable		Grounding conductor		Maximum D-C resistance of sectioned or concentric grounding conductor			
		Copper	Aluminum or copper-clad aluminum	20°C (68°F)		25°C (77°F)	
Copper	Aluminum or copper-clad aluminum	Smallest AWG size of unsectioned grounding conductor	Smallest AWG size of unsectioned grounding conductor	Ohms based on 1000 feet	Ohms based on 1000 meters	Ohms based on 1000 feet	Ohms based on 1000 meters
18 AWG	—	18	—	7.06	23.2	7.19	23.6
17	—	17	—	5.59	18.3	5.70	18.7
16	—	16	—	4.45	14.6	4.53	14.9
15	—	15	—	3.44	11.3	3.51	11.5
14	12 AWG	14	12	2.73	8.96	2.78	9.14
13	11	13	11	2.16	7.10	2.20	7.24
12	10	12	10	1.72	5.64	1.75	5.75
11	9	11	9	1.37	4.48	1.39	4.56
10 – 8	8 – 6	10	8	1.080	3.546	1.102	3.615
7 – 4	5 – 2	8	6	0.6795	2.230	0.6929	2.274
3 – 2/0	1 – 3/0	6	4	0.4276	1.403	0.4359	1.430
3/0 AWG – 250 kcmil	4/0 AWG – 350 kcmil	4	2	0.2689	0.8820	0.2742	0.8993
300 – 400	400 – 600	3	1	0.2132	0.6996	0.2175	0.7133
450 – 650	700 – 1000	2	1/0	0.1691	0.5548	0.1724	0.5657
700 – 900	—	1	2/0	0.1340	0.4398	0.1367	0.4485
1000	—	1/0	3/0	0.1063	0.3487	0.1084	0.3556

Table 8.2
Smallest grounding conductor in cable containing 75°C (167°F) circuit conductors

Size of largest ungrounded circuit conductor in cable		Grounding conductor		Maximum D-C resistance of sectioned or concentric grounding conductor			
		Copper	Aluminum or copper-clad aluminum	20°C (68°F)		25°C (77°F)	
Copper	Aluminum or copper-clad aluminum	Smallest AWG size of unsectioned grounding conductor	Smallest AWG size of unsectioned grounding conductor	Ohms based on 1000 feet	Ohms based on 1000 meters	Ohms based on 1000 feet	Ohms based on 1000 meters
18 AWG	—	18	—	7.06	23.2	7.19	23.6
17	—	17	—	5.59	18.3	5.70	18.7
16	—	16	—	4.45	14.6	4.53	14.9
15	—	15	—	3.44	11.3	3.51	11.5
14	12 AWG	14	12	2.73	8.96	2.78	9.14
13	11	13	11	2.16	7.10	2.20	7.24
12	10	12	10	1.72	5.64	1.75	5.75

Table 8.2 Continued

Size of largest ungrounded circuit conductor in cable		Grounding conductor		Maximum D-C resistance of sectioned or concentric grounding conductor			
		Copper	Aluminum or copper-clad aluminum				
Copper	Aluminum or copper-clad aluminum	Smallest AWG size of unsectioned grounding conductor	Smallest AWG size of unsectioned grounding conductor	20°C (68°F)		25°C (77°F)	
				Ohms based on 1000 feet	Ohms based on 1000 meters	Ohms based on 1000 feet	Ohms based on 1000 meters
11	9	11	9	1.37	4.48	1.39	4.56
10 – 7	8 – 5	10	8	1.080	3.546	1.102	3.615
6 – 3	4 – 1	8	6	0.6795	2.230	0.6929	2.274
2 – 3/0	1/0 – 4/0	6	4	0.4276	1.403	0.4359	1.430
4/0 AWG – 300 kcmil	250 – 450 kcmil	4	2	0.2689	0.8820	0.2742	0.8893
350 – 550	500 – 800	3	1	0.2132	0.6996	0.2175	0.7133
600 – 800	900 – 1000	2	1/0	0.1691	0.5548	0.1724	0.5657
900 – 1000	–	1	2/0	0.1340	0.4398	0.1367	0.4485

Table 8.3
Smallest grounding conductor in cable containing 60°C (140°F) circuit conductors

Size of largest ungrounded circuit conductor in cable		Grounding conductor		Maximum D-C resistance of sectioned or concentric grounding conductor			
		Copper	Aluminum or copper-clad aluminum				
Copper	Aluminum or copper-clad aluminum	Smallest AWG size of unsectioned grounding conductor	Smallest AWG size of unsectioned grounding conductor	20°C (68°F)		25°C (77°F)	
				Ohms based on 1000 feet	Ohms based on 1000 meters	Ohms based on 1000 feet	Ohms based on 1000 meters
18 AWG	–	18	–	7.06	23.2	7.19	23.6
17	–	17	–	5.59	18.3	5.70	18.7
16	–	16	–	4.45	14.6	4.53	14.9
15	–	15	–	3.44	11.3	3.51	11.5
14	12 AWG	14	12	2.73	8.96	2.78	9.14
13	11	13	11	2.16	7.10	2.20	7.24
12	10	12	10	1.72	5.64	1.75	5.75
11	9	11	9	1.37	4.48	1.39	4.56
10 – 6	8 – 4	10	8	1.080	3.546	1.102	3.615
4 – 2	3 – 1/0	8	6	0.6795	2.230	0.6929	2.274
1 – 4/0	2/0 AWG – 300 kcmil	6	4	0.4276	1.403	0.4359	1.430
250 – 400 kcmil	350 – 600	4	2	0.2689	0.8820	0.2742	0.8993
500 – 750	700 – 800	3	1	0.2132	0.6996	0.2175	0.7133
800 – 1000	900 – 1000	2	1/0	0.1691	0.5548	0.1724	0.5657

9 Circuit Conductors

9.1 General

9.1.1 Each power and control circuit conductor shall be insulated.

9.2 NEC types

9.2.1 Each power and control circuit conductor that is available as a National Electrical Code type shall comply with this standard and shall be of one of the following types:

a) 14 – 4/0 AWG and 250 – 1000 kcmil branch-circuit types complying with the Standard for Thermoset-Insulated Wires and Cables, UL 44, the Standard for Thermoplastic-Insulated Wires and Cables, UL 83, or the Standard for Fluoropolymer Insulated Wire, UL 83A:

Type(s)	Ratings for Type TC application	Standard
FEP and FEPB	200°C (392°F) dry 600 V special applications or 90°C (194°F) dry 600 V	83A 83A
RHH	90°C (194°F) dry 600 V, 1000 V or 2 kV	44
SA	200°C (392°F) dry 600 V, 1000 V special applications or 90°C (194°F) dry 600 V, 1000 V	44 44
RHW-2	90°C (194°F) wet or dry 600 V, 1000 V or 2 kV	44
RHW	75°C (167°F) wet or dry 600 V, 1000 V or 2 kV	44
RHH or RHW	90°C (194°F) dry 75°C (167°F) wet 600 V, 1000 V or 2 kv	44
XHHW-2	90°C (194°F) wet or dry 600 V or 1000 V	44
XHHW	90°C (194°F) dry 75°C (167°F) wet 600 V or 1000 V	44
THHN	90°C (194°F) dry 600 V	83
THHW	90°C (194°F) dry 75°C (167°F) wet 600 V	83
THWN-2	90°C (194°F) wet or dry 600 V	83
THWN	75°C (167°F) wet or dry 600 V	83
THHN or THWN	90°C (194°F) dry 75°C (167°C) wet 600 V	83
THW-2	90°C (194°F) wet or dry 600 V	83
THW	75°C (167°F) wet or dry 600 V	83
TW	60°C (140°F) wet or dry	83
Z	150°C (302°F) dry 600 V special applications or	83A

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL

Table Continued on Next Page



Documents

Document Sharing Hub