



ULC Standards
Normes ULC



ANSI/CAN/UL/ULC 1369:2025

JOINT CANADA-UNITED STATES
NATIONAL STANDARD

STANDARD FOR SAFETY

Aboveground Piping for Flammable and Combustible Liquids



ANSI/UL 1369-2025



Documents

Document Sharing Hub

SCC FOREWORD

National Standard of Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

UL Standard for Safety for Aboveground Piping for Flammable and Combustible Liquids,
ANSI/CAN/UL/ULC 1369

Second Edition, Dated October 8, 2025

Summary of Topics

This Second new edition of ANSI/CAN/UL/ULC 1369 dated October 8, 2025 incorporates editorial changes including renumbering and reformatting to align with current style.

The new requirements are substantially in accordance with Proposal(s) on this subject dated May 16, 2025.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page



ANSI/UL 1369-2025

OCTOBER 8, 2025



1

ANSI/CAN/UL/ULC 1369:2025

Standard for Aboveground Piping for Flammable and Combustible Liquids

First Edition – August, 2018

Second Edition

October 8, 2025

This ANSI/UL Standard for Safety consists of the Second Edition.

The most recent designation of ANSI/UL 1369 as an American National Standard (ANSI) occurred on October 8, 2025. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page, Preface or SCC Foreword.

This Standard has been designated as a National Standard of Canada (NSC) on October 8, 2025.

© 2025 ULSE Inc. All rights reserved.

No Text on This Page

CONTENTS

Preface	5
---------------	---

INTRODUCTION

1 Scope	7
2 Units of measurement	9
3 Referenced publications	9
4 Components	10
5 Glossary	11

CONSTRUCTION

6 General	12
-----------------	----

PERFORMANCE

7 General	13
8 Pressure Tests	16
8.1 General	16
8.2 Leakage test	16
8.3 Hydrostatic test	17
8.4 Breakdown test	17
9 Mechanical Tests	17
9.1 Interstitial communication test	17
9.2 Design pressure tests	18
9.3 Design vacuum tests	19
10 Physical Abuse Tests	19
10.1 General	19
10.2 Drop test	20
10.3 Impact test	20
10.4 Puncture test	21
10.5 Fitting torque test	21
10.6 Pipe torque test	21
10.7 Tension test	22
10.8 Compression test	22
10.9 Bending test	23
10.10 Support bracket test	23
11 Tests for Optional Special Use Ratings	24
11.1 General	24
11.2 Corrosion resistance tests	24
11.3 Tide cycle test	24
12 Short-Term Compatibility Tests	25
12.1 General	25
12.2 UV exposure test	25
12.3 Metallic stress crack test	25
12.4 Nonmetallic stress crack test	26
13 Long-Term Compatibility Tests	26
14 Fire Test	28

MANUFACTURING AND PRODUCTION TESTS

15 General	29
------------------	----

MARKINGS AND INSTRUCTIONS

16	Markings.....	30
17	Manufacturer's Instructions	31

ANNEX A (Normative) – TEST FUEL FORMULATIONS

A1	Representative Aggressive Combustible Test Fuel Mixtures and UL-B100	33
A2	Representative Aggressive Flammable Test Fuels and Mixtures	33

Preface

This is the Second Edition of the ANSI/CAN/UL/ULC 1369, Standard for Aboveground Piping for Flammable and Combustible Liquids.

ULSE is accredited by the American National Standards Institute (ANSI) and the Standards Council of Canada (SCC) as a Standards Development Organization (SDO). ULC Standards is accredited by the Standards Council of Canada (SCC) as a Standards Development Organization (SDO).

This Standard has been developed in compliance with the requirements of ANSI and SCC for accreditation of a Standards Development Organization.

This ANSI/CAN/UL/ULC 1369 Standard is under continuous maintenance, whereby each revision is approved in compliance with the requirements of ANSI and SCC for accreditation of a Standards Development Organization. In the event that no revisions are issued for a period of four years from the date of publication, action to revise, reaffirm, or withdraw the standard shall be initiated.

Annex [A](#) is identified as Normative, as such, form mandatory parts of this Standard.

In Canada, there are two official languages, English and French. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require additional markings and/or installation instructions to be in both official languages.

This Second Edition joint American National Standard and National Standard of Canada is based on, and now supersedes, the First Edition of UL 1369.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

Comments or proposals for revisions on any part of the Standard may be submitted at any time. Proposals should be submitted via a Proposal Request in the Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

This Edition of the Standard has been formally approved by the Technical Committee (TC) on Aboveground Piping for Flammable and Combustible Liquids, TC 1369.

This list represents the TC 1369 membership when the final text in this Standard was balloted. Since that time, changes in the membership may have occurred.

TC 1369 Membership

Name	Representing	Interest Category	Region
Dennis Boyd	BP America Inc	Commercial / Industrial User	USA
Kelly Crellin	Brugg Pipe Systems North America (BPNA)	Non-Voting	USA

TC 1369 Membership Continued on Next Page

TC 1369 Membership Continued

Name	Representing	Interest Category	Region
Andrew Dye	CAL Fire/California Office of the State Fire Marshall	Government	USA
Laura Fisher	State Water Resources Control Board – Sacramento	Authorities Having Jurisdiction	USA
Bill Hickman	CO Division of Oil and Public Safety	Authorities Having Jurisdiction	USA
Pierre Legault	Integrated Review Services – Consulting	General Interest	Canada
Jeanne Murphy Meyer	Core Engineered Solutions, Inc	Supply Chain	USA
Brian Orr	UL Solutions	Testing & Standards Org.	USA
Jeffrey Prusko	UL Standards & Engagement	TC Project Manager – Non-voting	USA
Dean Rivest	Omegaflex, Inc	Producer	USA
Darren Sanderson	Hall Tank Co	Producer	USA
Meik Schubert	Brugg Pipesystems GMBH	Producer	Germany
Raphael Sumabat	Technical Standards & Safety Authority	Authorities Having Jurisdiction	Canada
Jamie Thompson	Association For Petroleum & Explosives Administration	Authorities Having Jurisdiction	United Kingdom
Andrea Ticci	Franklin Fueling Systems Ltd	Producer	United Kingdom
Laura Werner	UL Standards & Engagement	TC Chair – Non-voting	Canada
Brian Wiegert	Fiberglass Tank & Pipe Institute	Producer	USA

International Classification for Standards (ICS): 75.160.20, 75.200

For information on ULSE Standards, visit <https://www.shopulstandards.com>, call toll free 1-888-853-3503 or email us at ClientService@shopULStandards.com.

This Standard is intended to be used for conformity assessment.

The intended primary application of this Standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

INTRODUCTION

1 Scope

1.1 These requirements cover primary, secondary, and coaxial types of aboveground pipes intended for transfer and containment of specific flammable and combustible liquids and fuels or fuel components (and vapors thereof) identified in this Standard, at their manufacturing, processing and distribution facilities, commercial (public) or fleet (private) motor vehicle fueling stations or similar fuel dispensing applications, and piping systems for fuel supply of generators, burners or similar equipment.

1.2 These pipes may be flexible or rigid types constructed with metallic, nonmetallic, or composite materials in single continuous or multiple joined lengths with integral end fittings in nominal sizes from 12.7 mm – 152.4 mm (0.5 inch – 6.0 inch) diameters, and are typically intended for use in the following applications:

- a) General aboveground use either directly on or suspended above the ground, such as piping between tanks and dispensers or within buildings, such as fuel supply lines to rooftop generators or basement boilers, which may include short lengths routed in below grade containment sumps and underground chase pipe where accessible, but not where directly buried; or
- b) Special aboveground uses that requires an additional evaluation for a specific purpose, such as marinas, and where specific liquids or extreme environments are not represented by the general test liquids and expected exposures conditions.

1.3 These pipes are intended for commercially available fuels and fuel components, and similar flammable and combustible liquids under the expected use conditions, and exposures that have similar chemical, physical and material compatibility properties as represented in these requirements.

1.4 Products covered by this Standard are intended to be installed and used in accordance with the applicable Codes and Regulations as determined by the Authority Having Jurisdiction (AHJ), such as, but not limited to:

In the United States:

- a) Standard for the Installation of Stationary Pumps for Fire Protection, NFPA 20;
- b) Flammable and Combustible Liquids Code, NFPA 30;
- c) Code for Motor Fuel Dispensing Facilities and Garages, NFPA 30A;
- d) Standard for the Installation of Oil-Burning Equipment, NFPA 31;
- e) Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines, NFPA 37;
- f) Standard for Aircraft Fuel Servicing, NFPA 407;
- g) Uniform Fire Code, NFPA 1;
- h) International Fire Code published by the International Fire Council; and/or
- i) Other applicable federal and state regulations for piping.

In Canada:

- a) The National Fire Code of Canada;

- b) CSA B139, Installation Code for Oil Burning Equipment;
- c) CCME PN 1326, Environmental Code of Practice for Aboveground and Underground Storage Tank Systems Containing Petroleum and Allied Petroleum Products; and/or
- d) Provincial or other Regulations.

1.5 The following Recommended Practices may be used as determined by the Authority Having Jurisdiction (AHJ):

- a) Recommended Practices for Installation of Aboveground Storage Systems for Motor Vehicle Fueling, PEI/RP 200;
- b) Recommended Practices for Installation of Bulk Storage Plants, PEI/RP 800;
- c) Recommended Practices for the Installation of Marina Fueling Systems (2014 Edition), PEI/RP 1000;
- d) Recommended Practices for the Design, Installation, Service, Repair and Maintenance of Aviation Fueling Systems (2013 Edition), PEI/RP 1300; and
- e) Recommended Practices For The Design And Installation Of Fueling Systems For Emergency Generators, Stationary Diesel Engines And Oil Burner Systems (2014 Edition), PEI/RP 1400.

1.6 These products are factory manufactured and intended for on-site field assembly, inspection, and leak testing for the specified applications and use conditions by qualified persons in accordance with the manufacturer's instructions and local requirements.

1.7 These products are intended to be periodically inspected and maintained for continued service, or taken out of service if necessary, by qualified persons in accordance with industry recommended practices and/or the manufacturer's instructions.

1.8 These products have not been evaluated for use after natural disasters, fires or exposures to chemicals not representative of the test liquids, or excessive physical damage beyond the expected assembly, installation and uses as identified in these requirements.

1.9 These products have not been evaluated for applications where exposed to heavy or continuous physical abuses, excessive mechanical stresses; and environments that are highly corrosive; or operate outside of the expected ambient use temperature range for significant times.

1.10 These requirements do not cover aboveground piping products for liquid fuels, which are within the scope of UL/ULC 180, Standard for Combustible Liquid Tank Accessories or underground piping products which are found in ULC S679, Standard for Metallic and Nonmetallic Underground Piping for Flammable and Combustible Liquids; UL 971, Standard for Nonmetallic Underground Piping For Flammable Liquids; and UL 971A, Outline of Investigation for Metallic Underground Fuel Pipe.

1.11 These requirements do not cover aboveground piping products for gaseous fuels (such as natural gas, liquefied petroleum gas, propane, butane, etc.), which are found in UL 536, Standard for Flexible Metallic Hose.

1.12 These requirements do not cover flexible metal connector piping or flexible elastomeric fuel dispensing and vapor recovery hose, which are found in UL/ULC 2039, Standard for Flexible Connector Piping for Flammable and Combustible Liquids; UL 330A, Standard for Hose and Hose Assemblies for Use With Dispensing Devices Dispensing Gasoline and Gasoline/Ethanol Blends With Nominal Ethanol Concentrations Up To 85 Percent (E0 – E85); UL 330B, Standard for Hose and Hose Assemblies for Use