

UL 1446

ISBN 0-7629-1290-1

Systems of Insulating Materials – General

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

Underwriters Laboratories Inc. (UL)
333 Pfingsten Road
Northbrook, IL 60062-2096

UL Standard for Safety for Systems of Insulating Materials – General, UL 1446

Sixth Edition, Dated February 8, 2007

Summary of Topics

The New Sixth Edition of UL 1446 reflects its Recognition as an ANSI Standard and includes the following changes:

- a) Revise Section 2, Reference Publications, to remove date from ASTM D2307 reference;**
- b) Clarify that the results obtained from the testing of round magnet wires also represents rectangular versions of the same wire;**
- c) Revise 5.2.5 to indicate that a magnet wire whose Thermal Rating has been reduced as a result of poor heat-shock performance is not suitable for use in an insulation system Aging Program;**
- d) Clarify that catalysts can be added to varnishes without additional testing;**
- e) Remove option for substituting bondable wire for a non-bondable wire in systems where varnish was part of the original aging system;**
- f) Revise Section 9 Heading to remove "Thermal Aging" since other tests are covered in that section;**
- g) Revision of paragraphs 9.1 and 9.1.1 to consolidate the requirements for thermal aging of magnet wires and magnet wire coatings;**
- h) Delete reference to Annex A2 of ASTM D2307;**
- i) Editorial deletion of Footnote in Table 10.1;**
- j) Clarify 14.4.1 to indicate that, for sealed tube testing, the number of Dielectric Breakdowns is what is important rather than the number of samples;**
- k) Revise 14.4.2 to clarify that, as part of a sealed tube test, only the results for wires of the same type are to be compared;**
- l) Revise 14.5.3 to clarify requirements for sealed tube testing of an insulation system where a bondable wire is to replace a non-bondable magnet wire;**
- m) Revise Appendix A to replace the temporary MW## type designation with the newly assigned ANSI MW37C and MW38C designations; and**
- n) Editorial deletion of duplicate requirement formerly in 8.3.2.1.1.**

The following table lists the future effective dates with the corresponding reference:

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM**



Documents

Document Sharing Hub

Future Effective Dates	References
July 29, 2007	Paragraphs 5.2.4, 9.2, 10.3, and the Reference Publication ANSI/NEMA MW1000 in Clause 2

The new and revised requirements are substantially in accordance with UL's Proposal(s) on this subject dated September 22, 2006.

As indicated on the title page (page 1), this UL Standard for Safety is an American National Standard. Attention is directed to the note on the title page of this Standard outlining the procedures to be followed to retain the approved text of this ANSI/UL Standard.

The UL Foreword is no longer located within the UL Standard. For information concerning the use and application of the requirements contained in this Standard, the current version of the UL Foreword is located on ULStandardsInfoNet at: <http://ulstandardsinfo.net/ulforeword.html>

The master for this Standard at UL's Northbrook Office is the official document insofar as it relates to a UL service and the compliance of a product with respect to the requirements for that product and service, or if there are questions regarding the accuracy of this Standard.

UL's Standards for Safety are copyrighted by UL. Neither a printed copy of a Standard, nor the distribution diskette for a Standard-on-Diskette and the file for the Standard on the distribution diskette should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

Revisions of UL Standards for Safety are issued from time to time. A UL Standard for Safety is current only if it incorporates the most recently adopted revisions.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

UL will attempt to answer support requests concerning electronic versions of its Standards. However, this support service is offered on a reasonable efforts basis only, and UL may not be able to resolve every support request. UL supports the electronic versions of its Standards only if they are used under the conditions and operating systems for which it is intended. UL's support policies may change from time-to-time without notification.

UL reserves the right to change the format, presentation, file types and formats, delivery methods and formats, and the like of both its printed and electronic Standards without prior notice.

Purchasers of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgement (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

If a single-user version electronic Standard was purchased, one copy of this Standard may be stored on the hard disk of a single personal computer, or on a single LAN file-server or the permanent storage device of a multiple-user computer in such a manner that this Standard may only be accessed by one user at a time and for which there is no possibility of multiple concurrent access.

If a multiple-user version electronic Standard was purchased, one copy of the Standard may be stored on a single LAN file-server, or on the permanent storage device of a multiple-user computer, or on an Intranet server. The number of concurrent users shall not exceed the number of users authorized.

Electronic Standards are intended for on-line use, such as for viewing the requirements of a Standard, conducting a word search, and the like. Only one copy of the Standard may be printed from each single-user version of an electronic Standard. Only one copy of the Standard may be printed for each authorized user of a multiple-user version of an electronic Standard. Because of differences in the computer/software/printer setup used by UL and those of electronic Standards purchasers, the printed copy obtained by a purchaser may not look exactly like the on-line screen view or the printed Standard.

An employee of an organization purchasing a UL Standard can make a copy of the page or pages being viewed for their own fair and/or practical internal use.

The requirements in this Standard are now in effect, except for those paragraphs, sections, tables, figures, and/or other elements of the Standard having future effective dates as indicated in the note following the affected item. The prior text for requirements that have been revised and that have a future effective date are located after the Standard, and are preceded by a "SUPERSEDED REQUIREMENTS" notice.

New product submittals made prior to a specified future effective date will be judged under all of the requirements in this Standard including those requirements with a specified future effective date, unless the applicant specifically requests that the product be judged under the current requirements. However, if the applicant elects this option, it should be noted that compliance with all the requirements in this Standard will be required as a condition of continued Recognition and Follow-Up Services after the effective date, and understanding of this should be signified in writing.

Copyright © 2007 Underwriters Laboratories Inc.

This Standard consists of pages dated as shown in the following checklist:

Page	Date
1-40.....	February 8, 2007
A1-A2.....	February 8, 2007
SR1-SR2.....	February 8, 2007

No Text on This Page

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

FEBRUARY 8, 2007



ANSI/UL 1446-2006

1

UL 1446

Standard for Systems of Insulating Materials – General

First Edition – June, 1978
Second Edition – June, 1980
Third Edition – January, 1991
Fourth Edition – December, 1994
Fifth Edition – May, 1997

Sixth Edition

February 8, 2007

The most recent designation of ANSI/UL 1446 as an American National Standard (ANSI) occurred on December 1, 2006.

This ANSI/UL Standard for Safety, which consists of the Sixth edition is under continuous maintenance, whereby each revision is ANSI approved upon publication.

An effective date included as a note immediately following certain requirements is one established by Underwriters Laboratories Inc.

Revisions of this Standard will be made by issuing revised or additional pages bearing their date of issue. A UL Standard is current only if it incorporates the most recently adopted revisions, all of which are itemized on the transmittal notice that accompanies the latest set of revised requirements. Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

ISBN 0-7629-1290-1

COPYRIGHT © 2007 UNDERWRITERS LABORATORIES INC.

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

No Text on This Page

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	5
2 Reference Publications	5
3 Units of Measurement	7
4 Glossary	7

PERFORMANCE CRITERIA

5 Magnet Wire	11
5.1 Magnet wire coatings	11
5.2 Magnet wire evaluation	11
6 Varnishes	12
7 Insulation Systems	13
7.1 General	13
7.2 System components	13
8 Substitutions or Modification to an Insulation System	14
8.1 General	14
8.2 Minor components	15
8.3 Magnet wire	15
8.4 Varnish	17
8.5 Encapsulants, ground, and interwinding insulation	19

PERFORMANCE TESTS

9 Magnet Wire Coatings/Magnet Wires	21
10 Varnishes – Thermal Aging	22
11 Insulation Systems – Full Thermal Aging	23
11.1 General	23
11.2 Samples	23
11.3 Exposures	24
11.4 Diagnostic tests – determination of end of test-life	26
11.5 Analysis and evaluation	27
12 Insulation Systems – One Temperature Thermal Aging	31
12.1 General	31
12.2 Samples, exposures, and tests	31
12.3 Analysis and evaluation	32
13 Insulation Systems – Two Temperature Thermal Aging	34
13.1 General	34
13.2 Samples, exposures, and tests	34
13.3 Analysis and evaluation	34
14 Sealed Tube Testing	36
14.1 General	36
14.2 Samples	36
14.3 Conditioning	37
14.4 Interpretation of results of non-bondable wire	37
14.5 Interpretation of results for bondable wire	38
15 Infrared Analysis Tests	39

UL COPYRIGHTED MATERIAL –

NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

MARKING

16 Details	39
------------------	----

Appendix A – Information for Magnet Wire Substitution

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL

**Documents**

Document Sharing Hub

INTRODUCTION

1 Scope

1.1 These requirements cover test procedures to be used in the evaluation of Class 120(E) or higher electrical insulation systems intended for connection to branch circuits rated 600 volts or less. These requirements also cover the investigation of the substitution of minor components of insulation in a previously evaluated insulation system and also the test procedures to be used in the evaluation of magnet wire coatings, magnet wires, and varnishes.

1.2 These requirements do not cover a single insulating material or a simple combination of materials, such as a laminate or a varnished cloth, printed circuit boards, or planar transformers.

1.3 These requirements do not cover insulation systems exposed to radiation or operating in oils, refrigerants, soaps, or other media that potentially degrade insulating materials.

1.4 These requirements shall be modified or supplemented as determined by the applicable requirements in the end-product standard covering the device, appliance, or equipment in which the insulation system is used.

2 Reference Publications

2.1 This Standard refers to the following publications and where such reference is made it shall be to the edition listed below. Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

Reference to ANSI/NEMA MW1000-2003 effective July 29, 2007

ANSI Standards

ANSI/NEMA MW1000-2003,
Standard for Magnet Wire

ASTM Standards

ASTM D1676,
Test Methods for Film-Insulated Magnet Wire

ASTM D1932,
Test Method for Thermal Endurance of Flexible Electrical Insulating Varnishes

ASTM D2307,
Test Method for Relative Thermal Endurance of Film-Insulated Round Magnet Wire
Exception – Specimens shall be thermal aged in ASTM D5423 Type II ovens

ASTM D2519,
Standard Method of Test for Bond Strength of Electrical Insulating Varnishes by Helical Coil Test

ASTM D3145,
Test Method for Thermal Degradation/Endurance by Helical Coil Method

ASTM D3251,
Test Method for Thermal-Aging Characteristics of Electrical Insulating Varnishes Applied Over Film-Insulated Magnet Wire

ASTM D5642,
Test Method for Sealed Tube Chemical Compatibility Test

ASTM E178,
Standard Practice for Dealing with Outlying Observations

IEC Standards

IEC 61857 (All Parts),
Electrical Insulation Systems – Procedures for Thermal Evaluation

IEEE Standards

IEEE No. 1,
General Principles for Temperature Limits in the Rating of Electrical Equipment

IEEE No. 99,
Guide for the Preparation of Test Procedures for the Thermal Evaluation of Insulation Systems for Electric Equipment

IEEE No. 101,
Guide for the Statistical Analysis of Thermal Life Test Data

IEEE No. 117,
Standard Test Procedure for Evaluation of Systems of Insulating Materials for Random-Wound AC Electrical Machinery

IEEE No. 259,
Standard Test Procedure for Evaluation of Systems of Insulation for Dry-Type Specialty and General-Purpose Transformers

Document Was Downloaded By Rice, Shi SHIMISHENG
For Use By KUANTECH CO LTD
12039 : 8/3/2007 - 1:35 AM
UL COPYRIGHTED MATERIAL –

NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents
Document Sharing Hub

3 Units of Measurement

3.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

4 Glossary

4.1 For the purpose of this standard, the following definitions apply:

4.2 APPARENT THERMAL INDEX – The unadjusted thermal index of an insulation system derived from a regression analysis of that system's thermal aging data, usually higher in value than the system's rated temperature class. For Class 105(A) systems used as controls, the temperature 105.0°C is to be used in place of an apparent thermal index.

4.3 CATALYST – A substance that alters (usually increases) the rate at which a reaction occurs without being consumed into the reaction.

4.4 CURING AGENT – A substance or mixture of substances that promote or control the reaction process and is consumed in the reaction.

4.5 CYCLE – A period of heat aging, typically one-tenth of the estimated total time required, to induce deterioration at the specific aging temperature, followed by a sequence of exposures to vibration, cold shock (when applicable), humidity, and voltage stress.

4.6 DEAD METAL – Metallic part that is at no electrical potential. With respect to the requirements in this Standard, dead metal parts are to be considered the same as if they were at ground potential.

4.7 GEOMETRIC MEAN – The antilogarithm of the data set logarithmic average.

4.8 INSULATION SYSTEM – A unique intimate combination of two or more insulating materials used in electrical equipment. One example of this is the combination of magnet wire, ground insulation, varnish, lead wire insulations, and outer wrapping of a coil. These intimate combinations are evaluated as unique groups. When multiple groups exist, either within a given insulation system or a different insulation system, components of one unique group shall not be added to another unique group. However, more than one group is able to be used within a single device when at least a 3.05 mm (0.125 inch) air space is used to separate them. Any material or component existing outside the outer wrap of the device or not in contact with the windings is not determined to be part of the insulation system.

4.9 INSULATION SYSTEM CLASS – A temperature class of an insulation system that is numerically equal to a maximum hot-spot operating temperature. Hot-spot temperatures for various insulation systems are specified in Table 4.1. The methods of measuring temperatures and determining hot-spot temperature allowances are specified in end-use standards.

UL COPYRIGHTED MATERIAL –

NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

Table 4.1
Maximum hot-spot temperatures of insulation systems

System class	Maximum hot-spot temperature,	
	°C	(°F)
120(E)	120	(248)
130(B)	130	(266)
155(F)	155	(311)
180(H)	180	(356)
200(N)	200	(392)
220(R)	220	(428)
240(S)	240	(464)
Over 240(C)	Over 240	(Over 464)

4.10 MOTORETTE – A unit constructed in accordance with the specifications in IEEE No. 117, Standard Test Procedure for Evaluation of Systems of Insulating Materials for Random-Wound AC Electrical Machinery, except that:

a) The slot assembly, comprised of both inner and outer slot plates, shall be constructed of stainless steel; and

Exception: When stainless steel is not able to be used due to difficulty in material adhesion, such as an epoxy coating, or similar problem, cold rolled steel is able to be used.

b) The magnet wire shall be 18 AWG (0.82 mm²) unless unavailable, in which case any wire size 18 AWG – 24 AWG (0.20 mm²) is able to be used.

4.11 SAMPLE – Actual electrotechnical products, components thereof, or non-functional models representing the product, e.g. motorette, used in the evaluation of an insulation system.

4.12 SYSTEM – An insulation system. See 4.8.

4.13 SYSTEM COMPONENTS – Grouped as follows:

a) MAJOR COMPONENTS – The components of an insulation system that are relied upon to prevent a risk of electric shock or fire. Examples of this type of insulation include ground, interwinding, turn, encapsulant, and varnish. See Table 4.2.

b) MINOR COMPONENTS – The components of an insulation system that are used typically in mechanical or thermal conduction capacities, and are not relied upon to prevent risk of fire or electric shock. See Table 4.2.

UL COPYRIGHTED MATERIAL –

NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

Table 4.2
Major and minor components

Component	Major	Minor	Definition/[Comments]
Balancing Compound (Motor Term)	–	X	A material applied to a rotor to reduce vibration.
Bobbin or Core Tube (Transformer Term)	X	X	The form around which the conductor is wound. [It is major when it is the sole insulation between windings and grounded or dead metal. It is minor when it is always provided with a supplemental (major) insulation between isolated windings and grounded or dead metal.]
Crossover Insulation	–	X	Component providing isolation between the magnet wire at the point where it enters the coil and all subsequent layers in the same winding. This insulation is made of either a separate dielectric material, or is integral to the bobbin construction.
Enameled Magnet Wire	X	–	Winding wire that relies on its enamel coating for turn insulation. With respect to dead or grounded metal enameled magnet wire is considered to be a bare conductor and can not be relied upon for ground insulation.
Encapsulant	X	–	A molding material which is typically cast or injection molded around the electrical insulation system and is intended to insulate and protect the winding wires. Encapsulated devices do not employ supplementary surrounding shells hence the encapsulant may function as an electrical enclosure.
End Spider (Motor Term)	X	X	The material provided between rotor laminations and the winding as it passes from slot to slot. [It is major when no supplemental (major) insulation is provided between conductors and ground. It is minor when provided with required ground insulation or a 1/32-inch (0.8-mm) minimum air space between conductors and the end spider.]
Filament Winding	X	–	Windings constructed of the type of wire typically used as lead wires.
Ground Insulation	X	–	The electrical insulation between the conductor and grounded or dead metal.
Integral Ground	X	–	A coating, such as epoxy, that is fused directly to the grounded or dead metal core and serves as ground insulation.
Interwinding Insulation (Transformer Term)	X	–	The electrical insulation between individual windings. [Does not apply to material used between series-parallel windings in multi-voltage devices.]
Layer Insulation (Transformer Term)	–	X	The material interleaved between successive layers of an insulated conductor in the same winding. [Used in a mechanical application only, and does not serve as electrical insulation.]
Lead Wire	–	X	The insulated wire attached to the end of a winding to connect the device to a circuit. [It is identified as part of the system when its insulation enters the confines of the winding or outer wrap. When used to form a magnetic winding, it is identified as a filament winding.]
Litz wire (Transformer Term)	X	X	A bundle of magnet wire bound together by a strand of magnet wire or another material (dacron, fiberglass, aramid fiber, or similar materials). The magnet wire portion of a Litz wire is considered a Major component. The non-wire portion wrapped or extruded around the bundle and/or core material is considered a Minor component. Typically used in high frequency transformers.
Magnet Wire	X		A conductor insulated with turn insulation.

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM

Table 4.2 Continued on Next Page



Documents

Document Sharing Hub