



UL 162

STANDARD FOR SAFETY

Foam Equipment and Liquid Concentrates

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM*



Documents
Document Sharing Hub

UL Standard for Safety for Foam Equipment and Liquid Concentrates, UL 162

Seventh Edition, Dated March 30, 1994

Summary of Topics

This edition of ANSI/UL 162 is being revised to reflect the first time ANSI approval of the Standard. No changes in the requirements are involved.

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin. Changes in requirements are marked with a vertical line in the margin and are followed by an effective date note indicating the date of publication or the date on which the changed requirement becomes effective.

The revisions are substantially in accordance with Proposal(s) on this subject dated April 25, 2014.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

The requirements in this Standard are now in effect, except for those paragraphs, sections, tables, figures, and/or other elements of the Standard having future effective dates as indicated in the note following the affected item. The prior text for requirements that have been revised and that have a future effective date are located after the Standard, and are preceded by a "SUPERSEDED REQUIREMENTS" notice.

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

MARCH 30, 1994
(Title Page Reprinted: October 10, 2014)



ANSI/UL 162-2014

1

UL 162

Standard for Foam Equipment and Liquid Concentrates

The first through fourth editions were titled Air-Foam Equipment and Liquid Concentrates.

First Edition – May, 1960
Second Edition – August, 1969
Third Edition – March, 1974
Fourth Edition – June, 1975
Fifth Edition – June, 1983
Sixth Edition – March, 1989

Seventh Edition

March 30, 1994

This ANSI/UL Standard for Safety consists of the Seventh Edition including revisions through October 10, 2014.

The most recent designation of ANSI/UL 162 as an American National Standard (ANSI) occurred on October 8, 2014. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page, or effective date information.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2014 UNDERWRITERS LABORATORIES INC.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents
Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	5
2 General	5
2.1 Units of measurement	5
2.2 Components	5
2.3 Undated references	6
3 Glossary	6

CONSTRUCTION

4 Foam Equipment	10
4.1 Assembly	10
4.2 Materials	11
4.3 Working pressure	12
5 Foam Liquid Concentrates	12
5.1 Induction methods	12
5.2 Containers	12

PERFORMANCE

6 Film Forming Test	12A
7 Hydraulic Characteristics Test	13
7.1 General	13
7.2 Foam chambers	13
7.3 Foam-water sprinklers	13
8 Foam Quality Tests	14
8.1 General	14
8.2 Twenty-five percent drain time test	15
8.3 Expansion Test	16A
8.4 Verification of liquid-concentrate concentration	16B
9 Class B Fire Tests – Sprinklers and Spray Nozzles	16B
9.1 General	16B
9.2 Fuel	17
9.3 Test method	19
9.4 Application density and sprinkler or spray nozzle arrangement	19
9.5 Fuel ignition and foam discharge	20
10 Class B Fire Tests – Topside Discharge Devices	21
10.1 General	21
10.2 Fuel	21
10.3 Test method	22
10.4 Application density and nozzle positioning	22
10.5 Fuel ignition and foam discharge	22
11 Class B Fire Tests – Subsurface Injection	24
11.1 General	24
11.2 Fuel	24
11.3 Test Method	24
12 Induction Rate Tests	25

13	Minimum Storage Temperature Test	25
14	Hydrostatic Pressure Test	26
15	Equipment Pressurization Test	26
16	Mercurous Nitrate Immersion Test	26
16A	10-Day Moist Ammonia Air Stress Cracking Test	26A
17	Salt Spray Corrosion Test	27
18	Elastomeric Parts Tests Other Than Hose	28
18.1	General	28
18.2	Parts other than bladder parts	28
18.3	Non-reinforced bladder parts	29
18.4	Reinforced bladder parts	29
19	Rubber Materials Tests – Hose	29
19.1	General	29
19.2	Light and water test	30
19.3	Air-oven aging test	30
20	Exposure Tests for Polymeric Materials and Fiberglass Components Used in Parts Other Than Containers	30
20.1	Air-oven aging test	30
20.2	Liquid concentrate test	31
20.3	Light and water test	31
21	Drop Test	31
22	Nonmetallic Container Tests	32
22.1	Immersion test for cracking resistance	32
22.2	Air-oven aging test	32
22.3	Accelerated storage test	32
22.4	Light and water test	32

MARKING

23	Foam Equipment	33
24	Foam Liquid Concentrates	34
	Standards for Components.....	A1

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

No Text on This Page

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

This page intentionally left blank.

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

INTRODUCTION

1 Scope

1.1 These requirements cover foam producing equipment and liquid concentrates employed for the production and discharge of foam that has an expansion ratio of 20:1 or less and is used for fire extinguishment. These requirements are based on the premise that foam equipment and specified types of foam liquid concentrates with which they are intended to be used are to be investigated for use with each other.

1.2 If foam equipment covered by these requirements incorporate sprinklers, the sprinklers shall comply with the Standard for Automatic Sprinklers for Fire Protection Service, UL 199.

1.3 Requirements for the installation and use of foam equipment and liquid concentrates are included in the following standards of the National Fire Protection Association:

- a) Low Expansion Foam and Combined Agent Systems, NFPA 11;
- b) Deluge Foam-Water Sprinkler and Spray Systems, NFPA 16;
- c) Installation of Closed-Head Foam-Water Sprinkler Systems, NFPA 16A.

1.4 A product that contains features, characteristics, components, materials, or systems new or different from those covered by the requirements in this standard, and that involves a risk of fire, electric shock, or injury to persons shall be evaluated using the appropriate additional component and end-product requirements to determine that the level of safety as originally anticipated by the intent of this standard is maintained. A product whose features, characteristics, components, materials, or systems conflict with specific requirements or provisions of this standard shall not be judged to comply with this standard. Where appropriate, revision of requirements shall be proposed and adopted in conformance with the methods employed for development, revision, and implementation of this standard.

1.4 revised September 8, 1999

2 General

2.1 Units of measurement

2.1.1 If a value for measurement is followed by a value in other units in parentheses, the second value may be only approximate. The first stated value is the requirement.

2.2 Components

2.2.1 Except as indicated in 2.2.2, a component of a product covered by this standard shall comply with the requirements for that component.

2.2.2 A component need not comply with a specific requirement that:

- a) Involves a feature or characteristic not needed in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.2.3 A component shall be used in accordance with its recognized rating established for the intended conditions of use.

2.2.4 Specific components are recognized as being incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions for which they have been recognized.

2.3 Undated references

2.3.1 Deleted September 8, 1999

3 Glossary

3.1 For the purpose of this standard, the following definitions apply.

3.2 CLASS B FIRES – Fires in flammable and combustible liquids, gases, and greases.

3.3 CONTROL – A reduction in fire intensity of approximately 90 percent.

3.4 DISCHARGE COEFFICIENT "K" – Coefficient of discharge in the formula:

$$K = \frac{Q}{\sqrt{P}}$$

where:

Q = Flow in gallons per minute (L/s x 15.85),

p = Pressure in psi (6.89 kPa)

3.5 DISCHARGE DEVICE – Fixed, semifixed, or portable devices, such as foam chambers, fixed foam makers, monitors, nozzles, spray nozzles, and sprinklers, that direct the flow to the fire or flammable liquid surface.

3.6 FIRE TEST PAN – The fire test pan is to be square, straight sided, with a minimum area of 50 square feet (4.65 m²). The pan is to be of steel not less than 1/4 inch (6.4 mm) thick with liquid tight welded joints and provided with 3/16 inch (4.8 mm) thick angle to reinforce the upper edge. The reinforcement is to be continuous around the perimeter of the pan and is to form a turned-out edge flush with the top edge of the pan. The top edge surface so formed is to be 1-3/4 inch (44 mm). The reinforcing angle is to be continuously welded to the outside of the pan at the top edge and tackwelded at the edge of the lower lip of the angle.

3.7 FILM FORMING LIQUID CONCENTRATE – A foam solution that has a spreading coefficient greater than zero when tested in accordance with the Film Forming Test, Section 6.

3.7 effective July 6, 1995

3.8 FIXED FOAM MAKER – A device that generates foam and that is intended to be installed between the supply piping of foam solution and piping leading to discharge outlets.

3.9 FOAM – A fire fighting agent made by mechanically mixing air with a solution consisting of fresh or salt water to which a foam liquid concentrate has been added.

3.10 FOAM CHAMBER – A device that:

- a) May include an integral foam maker,
- b) Is intended for fixed installation on flammable or combustible liquid storage tanks, and
- c) Produces foam and introduces it into the storage tanks.

3.11 FOAM EXPANSION VALUE – The ratio of final foam volume to original foam solution volume before adding air.

3.12 FOAM QUALITY – A measure of a foam's physical characteristics, expressed as the foam's:

- a) 25 percent drain time, and
- b) Expansion value.

3.13 FOAM SOLUTION – A mixture of a proportioned or premixed foam liquid concentrate dissolved in either fresh or salt water.

3.14 FULL-SCALE EQUIPMENT – Field installed components, such as proportioners and foam makers, that are intended to extinguish fires.

3.15 INDUCTION – A method that uses the venturi principle to introduce a proportionate quantity of foam concentrate into a water stream.

a) Pressure Induction – This method employs the water supply to pressurize the foam concentrate storage tank. At the same time, water flowing through an adjacent venturi or orifice creates a pressure differential. The difference between the water supply pressure and this lower pressure area forces the foam concentrate to flow through a fixed or metering orifice into the water stream.

b) Vacuum Induction – This method utilizes the negative pressure created by water passing through a venturi to draw the liquid concentrate from the storage tank or container through a pick-up tube and mix it with the water stream.

c) Pump-and-Motor Induction – By means of an auxiliary pump, foam compound is injected into the water stream passing through an inductor. The resulting foam solution is then delivered to a foam maker. The proportioner may be inserted in the line at any point between the water source and foam maker.

3.16 LIQUID CONCENTRATE – A protein or synthetic based liquid that is intended to be diluted with fresh water, salt water, or a mixture of both fresh and salt water to a concentration (volume of concentrate/volume of water) of 1 percent or higher. Different types of low expansion liquid concentrates are designated as follows:

- a) Aqueous Film Forming (AFFF) – A liquid concentrate that has a fluorinated surfactant base plus stabilizing additives.
- b) Protein – A liquid concentrate that has a hydrolyzed protein base plus stabilizing additives.
- c) Fluoroprotein – A liquid concentrate that is similar to protein, but with one or more fluorinated surfactant additives.
- d) Film Forming Fluoroprotein (FFFP) – A liquid concentrate that has both a hydrolyzed protein and fluorinated surfactant base plus stabilizing additives.
- e) Synthetic – A liquid concentrate that has a base other than fluorinated surfactant or hydrolyzed protein.
- f) Alcohol Resistant – A liquid concentrate intended to extinguish both hydrocarbon and polar solvent (water miscible) fuel fires. To be identified as alcohol resistant, a liquid concentrate shall comply with the fire tests indicated in Class B Fire Tests – Sprinklers and Spray Nozzles, Section 14, or Class B Fire Tests – Topside Discharge Devices, Section 15, using both heptane and isopropyl alcohol test fuels.

3.16 effective July 6, 1995

3.17 MONITOR – A device that includes a nozzle and is intended to deliver a large foam stream and is mounted on:

- a) A stationary support at grade level or on an elevated platform, or
- b) A vehicle.

3.18 NOZZLE – A portable device intended to discharge foam solution. A nozzle may be either aspirating or nonaspirating and may pick up foam liquid concentrate directly from a container (self-inducting) or utilize a foam solution produced at some point before introduction into the nozzle.

3.19 PROPORTIONER – A device intended to provide continuous introduction of foam liquid concentrate at the recommended ratio into a water stream to form a foam solution.

3.20 SALT WATER – Synthetic seawater complying with the Standard Specification for Substitute Ocean Water, ASTM D1141-90 or the equivalent.

3.21 SPECIAL FIRE EQUIPMENT (SMALL SCALE EQUIPMENT) – Foam nozzles or foam makers, used for the Class B Fire Tests, that produce foam:

- a) At the flow rate required for the Class B Fire Tests and
- b) Having a foam quality approximating that produced using full-scale equipment.

Special fire equipment may be provided by the manufacturer to produce a range of foam quality.

3.22 SPRAY NOZZLE – A device attached to piping intended to discharge foam in a fixed spray pattern.

3.23 SPRINKLER, FOAM-WATER TYPE – An air aspirating, open type sprinkler, constructed to discharge water or foam-water solutions.

3.24 STANDARD SPRINKLER – A nonair aspirating type sprinkler that complies with the Standard for Automatic Sprinklers for Fire Protection Service, UL 199, and discharges water or foam solutions.

3.25 STOVE PIPE – A device intended to provide an open area for the 1 minute free burn during the burnback test. The stove pipe shall be constructed of 28-18 gauge (.015 – .048 inch thickness) sheet steel. The stove pipe is to be cylindrical in shape with an inside diameter not less than 12 inch (305 mm) and length not greater than 14 inch (356 mm).

3.26 SUBSURFACE FOAM INJECTION – Discharge of foam into a storage tank below the liquid surface near the tank bottom.

3.27 TEST FUELS –

a) HEPTANE – Commercial grade hydrocarbon having the following characteristics:

Distillation –	
Initial boiling point	190°F (92°C)
50 percent	201°F (94°C)
Dry point	208°F (98°C)
Specific Gravity (60°F/60°F) (15.6°C/15.6°C)	0.702 (not critical)
Gravity°API	70.2 (not critical)

b) POLAR SOLVENT FUELS – Standard Polar Test fuels are as follows:

Polar Solvent Group	Standard Test Fuel
Alcohol	Isopropyl Alcohol
Ketones	Dimethyl Ketone
Esters	N-Butyl Acetate
Carboxylic Acids	Glacial Acetic Acid
Amines	Ethylene Diamine
Aldehydes	Propionaldehyde
Ethers, except Diethyl and Methyl Tertiary Butyl Ether	Isopropyl ether
Impurities for any polar test fuel is not to exceed 1.0 percent.	

Table B effective July 6, 1995

3.28 TOPSIDE APPLICATION – A method of foam discharge wherein the foam is applied onto the top of a burning fuel surface.