

Subject 1995

July 13, 2018

SUMMARY OF TOPICS

The following topics for the Standard for Heating and Cooling Equipment, UL 1995, are being recirculated:

1. Clarification of the Scope of UL 1995.

COMMENTS DUE: July 27, 2018

For your convenience in review, proposed additions to the previously proposed requirements dated June 6, 2018 are shown underlined and proposed deletions are shown ~~lined-out~~.

1. Clarification of the Scope of UL 1995.

RATIONALE

Responses to comments have been posted within the Subject 1995 Proposal Review Work Area dated June 6, 2018.

PROPOSAL

1.11 These requirements apply to equipment designed to be used in nonhazardous locations in accordance with the rules of CSA C22.1, ANSI/NFPA No. 70, CSA B52, ANSI/ASHRAE 15, NFPA 90A, and NFPA 90B, ~~and employ refrigerants that comply with the requirements of UL 2182.~~

Note: Requirements for the installation of units designed to be connected to air duct systems are also included in codes such as the BOCA Basic National Mechanical Code, the ICC's Standard Mechanical Code, and the ICC's Uniform Mechanical Code.

1.14 The following Clauses of CAN/CSA-C22.2 No. 0 are superseded by the requirements of this Standard:

- a) "General Requirements", Clause 3, and "Construction Details", Clause 4 (refer to Clauses 2 through ~~35~~36 of this standard);
- b) "Marking", Clause 5 (refer to Clauses ~~36, 37, and 38~~ 43, 44, and 45 of this standard);
- c) "Tests", Clause 6 (refer to Clauses ~~39 through 72~~ 46 through 79 of this standard).

Copyright © 2018 Underwriters Laboratories Inc.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub