



UL 310

STANDARD FOR SAFETY

Electrical Quick-Connect Terminals

UL Standard for Safety for Electrical Quick-Connect Terminals, UL 310

Tenth Edition, Dated November 30, 2023

Summary of Topics

This new edition of ANSI/UL 310 dated November 30, 2023 includes the following changes:

- Dimensions for double-ended test tab; [Figure 5.5](#)***
- Alternate information means; [7.11](#)***
- Editorial changes; [6.5.1.9](#) and [6.6.3.1](#)***

The requirements are substantially in accordance with Proposal(s) on this subject dated July 14, 2023.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of ULSE Inc. (ULSE).

ULSE provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will ULSE be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if ULSE or an authorized ULSE representative has been advised of the possibility of such damage. In no event shall ULSE's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold ULSE harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page



CSA Group
CSA C22.2 No. 153:23
Fourth Edition



ULSE Inc.
UL 310
Tenth Edition

Electrical Quick-Connect Terminals

November 30, 2023



ANSI/UL 310-2023



Documents

Document Sharing Hub

Commitment for Amendments

This Standard is issued jointly by the Canadian Standards Association (operating as “CSA Group”) and ULSE Inc. (ULSE). Comments or proposals for revisions on any part of the standard may be submitted to CSA Group or ULSE at any time. Revisions to this Standard will be made only after processing according to the standards development procedures of CSA Group and ULSE. CSA Group and ULSE will issue revisions to this Standard by means of a new edition or revised or additional pages bearing their date of issue.

ISBN 978-1-4883-4934-8 © 2023 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line: Standard designation (number); relevant clause, table, and/or figure number; wording of the proposed change; and rationale for the change.

To purchase CSA Group Standards and related publications, visit CSA Group's Online Store at www.csagroup.org/store/ or call toll-free 1-800-463-6727 or 416-747-4044.

Copyright © 2023 ULSE INC.

Our Standards for Safety are copyrighted by ULSE Inc. Neither a printed nor electronic copy of a Standard should be altered in any way. All of our Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of ULSE Inc.

This ANSI/UL Standard for Safety consists of the Tenth Edition.

The most recent designation of ANSI/UL 310 as an American National Standard (ANSI) occurred on November 30, 2023. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface.

Comments or proposals for revisions on any part of the Standard may be submitted to ULSE at any time. Proposals should be submitted via a Proposal Request in ULSE's Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

To purchase UL Standards, visit ULSE's Standards & Publications Site at <http://www.shopulstandards.com> or call toll-free 1-888-853-3503.

CONTENTS

Preface	5
1 Scope	7
2 Definitions	7
3 Units of measurement	8
4 Normative references	8
5 Construction	8
5.1 General	8
5.2 Materials	9
5.3 Dimensions	9
5.4 Insulation	16
6 Tests	17
6.1 General	17
6.2 Preparation of specimens	18
6.3 Crimp pull-out test	21
6.4 Insertion-withdrawal test	22
6.5 Temperature and current cycling tests	22
6.6 Dielectric withstand tests	25
6.7 Secureness of insulation test	26
7 Markings	27
8 Installation instructions	28

ANNEX A (Informative) – MILLIVOLT DROP TEST

A1 General	29
A2 Millivolt drop measurement	29

No Text on This Page

Preface

This is the harmonized CSA Group and ULSE standard for Electrical Quick-Connect Terminals. It is the Fourth edition of CSA C22.2 No. 153 and the Tenth edition of UL 310. This edition of CSA C22.2 No. 153 supersedes the previous edition published in 2014. This edition of UL 310 supersedes the previous edition published October 17, 2014.

This harmonized standard was prepared by the CSA Group and ULSE. The efforts and support of the CANENA Technical Harmonization Subcommittee 99, Electrical Quick-Connect Terminals, are gratefully acknowledged.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was reviewed by the CSA Integrated Committee on Electrical Connectors, under the jurisdiction of the CSA Technical Committee on Wiring Products and the CSA Strategic Steering Committee on Requirements for Electrical Safety, and has been formally approved by the CSA Technical Committee. This Standard has been developed in compliance with the Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

This Standard was reviewed by ULSE's Standards Technical Committee (TC) for Electrical Quick-Connect Terminals, TC 310.

Application of Standard

Where reference is made to a specific number of samples to be tested, the specified number is considered a minimum quantity.

Note: Although the intended primary application of this Standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

Level of harmonization

This Standard uses the IEC format but is not based on, nor is it considered equivalent to, an IEC standard.

This Standard is published as an identical standard for CSA Group and ULSE.

An identical standard is a standard that is exactly the same in technical content except for national differences resulting from conflicts in codes and governmental regulations. Presentation is word for word except for editorial changes.

Reasons for differences from IEC

This Standard provides requirements for electrical quick-connect terminals for use in accordance with the electrical installation codes of Canada and the United States. At present there is no IEC Standard for electrical quick-connect terminals for use in accordance with these codes. Therefore, this Standard does not employ any IEC Standard for base requirements.

Interpretations

The interpretation by the standards development organization of an identical or equivalent standard is based on the literal text to determine compliance with the standard in accordance with the procedural rules of the standards development organization. If more than one interpretation of the literal text has been identified, a revision is to be proposed as soon as possible to each of the standards development organizations to more accurately reflect the intent.

Electrical Quick-Connect Terminals

1 Scope

1.1 This standard applies to quick-connect terminals, both connectors and tabs, having nominal widths of 2.8, 3.2, 4.8, 5.2, and 6.3 mm (0.110, 0.125, 0.187, 0.205, and 0.250 in). They are intended for internal wiring connections in electrical equipment and for the field termination of conductors to electrical equipment in accordance with Part I of the *Canadian Electrical Code*, CSA C22.1, in Canada, and the *National Electrical Code*, NFPA 70, in the United States of America.

1.2 These requirements apply to quick-connect terminals intended for use with one or two 26 – 10 AWG (0.13 - 5.3 mm²) copper conductors.

1.3 These requirements do not apply to terminals for use with aluminum conductors.

1.4 These requirements do not apply to multi-pole devices. Multi-pole devices are covered by UL 1977 and CSA C22.2 No. 182.3.

1.5 In Canada, general requirements applicable to this standard are given in CSA C22.2 No. 0.

2 Definitions

For the purpose of this standard, the following definitions apply.

2.1 BURR – An extraneous protrusion in the stock, not considered an integral functional part of the connector or tab.

2.2 CONNECTOR (female connector) – That portion of a quick-connect termination which is pushed onto the male tab.

2.3 C26000 ALLOY – A copper-zinc alloy consisting of approximately 70 percent copper and 30 percent zinc (cartridge brass) as specified by the *Copper Development Association's Copper Development Alloy (CDA) Standards Handbook, Wrought Copper and Copper Alloy Mill Products, Part 2 – Alloy Data*.

2.4 DETENT – A dimple (depression) or hole in the male tab that engages a raised portion on the female connector, thus providing a latch for the mating parts.

2.5 PRODUCTION TAB (male tab) – That portion of a quick-connect termination which receives the female connector.

2.6 QUICK-CONNECT TERMINATION – An electrical connection consisting of a male tab and female connector that can be readily inserted or withdrawn without the use of a tool.

2.7 REFERENCE POINT – A specially marked point on a connector or tab that is used when making electrical test measurements.

2.8 TERMINAL – An electrical connecting device; may be either a female connector or male tab.

2.9 TEST TAB (male test tab) – A male tab, manufactured to close tolerances and with specific materials, used for the purpose of conducting tests with production female connectors.