

Subject 330B

June 22, 2018

SUMMARY OF TOPICS

The following change in requirements to the Standard for Hose and Hose Assemblies for Use With Dispensing Devices Dispensing Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends With Nominal Biodiesel Concentrations Up To 20 Percent (B20), Kerosene, and Fuel Oil, UL 330B, is being proposed:

1. Revision to construction section regarding threads and couplings

STP BALLOTS AND ALL COMMENTS DUE: July 23, 2018

For your convenience in review, proposed additions to existing requirements are shown underlined.

1. Revision to construction section regarding threads and couplings

RATIONALE

Proposal submitted by: Edgar Wolff-Klammer, UL, LLC

Industry has identified other types of threads suitable for use on the couplings.

PROPOSAL

CONSTRUCTION

9 Couplings

9.3 When the threads of the couplings of a single-line hose assembly or vapor recovery hose assembly are not as specified in 9.2, the installation instructions which accompany each assembly shall indicate the specific equipment which can be connected to the fitting or shall be marked in accordance with 31.8.

MARKING

31 Details

31.8 Hoses constructed using pipe thread in accordance with 9.3 shall be provided with a tag, label, or similar marking on the product or smallest unit package, identifying the pipe thread type. This marking is not required to be permanent.

Copyright © 2018 Underwriters Laboratories Inc.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents
Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub