

Subject 347A

October 26, 2018

SUMMARY OF TOPICS

The following topics for the Standard for Medium Voltage Power Conversion Equipment, UL 347A, are being recirculated:

1. Power Conversion Equipment with Low Voltage Input and Medium Voltage Output

COMMENTS DUE: November 26, 2018

For your convenience in review, proposed additions to the previously proposed requirements dated July 13, 2018 are shown underlined and proposed deletions are shown ~~lined-out~~.

1. Power Conversion Equipment with Low Voltage Input and Medium Voltage Output

RATIONALE

Responses to comments have been posted within the UL 347A Proposal Review Work Area opened July 13, 2018.

PROPOSAL

1.2 These requirements cover equipment ~~with output voltage ratings~~ rated above 1500 volts to 38kV. This ~~The~~ equipment may have input voltage ratings greater than 1500 V, output ratings greater than 1500 V, or both in the range of 0-1000 V, or above 1000 V to 38 kV.

Copyright © 2018 Underwriters Laboratories Inc.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents
Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub