

SUMMARY OF TOPICS

The following topics for the Standard for Meter Sockets, UL 414, are being recirculated:

- 1. Revision to the Heating Test Conductor Requirement from Aluminum to Copper***
- 2. Revision to Address Meter Socket Adapters Provided with Means for Connection to Alternative Energy Systems***

COMMENTS DUE: June 18, 2018

For your convenience in review, proposed additions to the previously proposed requirements dated (2017-10-13) are shown underlined and proposed deletions are shown ~~lined-out~~.

1. Revision to the Heating Test Conductor Requirement from Aluminum to Copper

Responses to comments have been posted within the UL 414 Proposal Review Work Area dated (2017-10-13). No changes have been made to the previously proposed revision. Note that the purpose of a recirculation of comments only is intended solely to provide STP members the opportunity to review the comments and responses, and to either reconsider their vote or cast a first-time vote. New comments on the previously proposed revision for this Topic will not be provided with a specific response. Any additionally desired changes should be submitted as a new proposal request via CSDS.

2. Revision to Address Meter Socket Adapters Provided with Means for Connection to Alternative Energy Systems

RATIONALE

Responses to comments have been posted within the UL 414 Proposal Review Work Area dated (2017-10-13).

PROPOSAL

1.6 Except as indicated in 1.10, A ~~as~~ covered by these requirements, a meter socket does not include:

- a) A meter,
- b) An overcurrent device,
- c) An instrument transformer,
- d) An arcing or switching part, or

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

e) A similar component.

A meter socket does not have provision for installation of instrument transformers within the meter socket enclosure.

1.10 This Standard contains requirements in Supplement SA that cover meter socket adapters, including adapters with provisions for connection of alternative energy sources, that may contain overcurrent protection.

Copyright © 2018 Underwriters Laboratories Inc.