

Subject 567

June 9, 2017

SUMMARY OF TOPICS

The following change in requirements to the Standard for Emergency Breakaway Fittings, Swivel Connectors and Pipe-Connection Fittings for Petroleum Products and LP-Gas, UL 567, is being recirculated:

1. Revision to the hydrostatic-strength test – single-break emergency breakaway fittings

COMMENTS DUE: July 10, 2017

For your convenience in review, proposed additions to the previously proposed requirements dated 2017-02-10 are shown underlined and proposed deletions are shown ~~lined-out~~.

1. Revision to the hydrostatic-strength test – single-break emergency breakaway fittings

RATIONALE

Responses to comments have been posted within the UL 567 Proposal Review Work Area dated 2017-02-10.

PROPOSAL

18 Hydrostatic-Strength Test

18.2 Three samples of swivel connectors, emergency breakaway fittings and pipe-connecting fittings are to be tested. Emergency breakaway fittings shall be tested as follows:

- a) For reconnectable emergency breakaway fittings both halves of the fitting are to be tested separately and then tested as a completely assembled unit; or
- b) For single-break emergency breakaway, ~~fittings they are tested as a completely assembled unit and then both halves of the fitting are to be tested separately. It is acceptable if the assembled unit separates during the test as long as each half meets the requirement.~~

Copyright © 2017 Underwriters Laboratories Inc.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

No Text on This Page

