



UL 60079-0

Underwriters Laboratories Inc.

Standard for Safety

Explosive atmospheres – Part
0: Equipment – General
requirements



.....

UL Standard for Safety for Explosive atmospheres – Part 0: Equipment – General requirements, UL 60079-0

Fifth Edition, Dated October 21, 2009

Summary of Topics

This revision to ANSI/UL 60079-0, the Standard for Safety for Explosive Atmospheres – Part 0: Equipment – General Requirements is issued to note the November 16, 2009 ANSI approval date of ANSI/ISA 60079-0.

As noted in the Commitment for Amendments statement located on the back side of the title page, UL and ISA are committed to updating this bi-national standard jointly. However, the revision pages dated December 8, 2009 will not be issued by ISA as revision pages but as an update to their standard.

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

The requirements in this Standard are now in effect, except for those paragraphs, sections, tables, figures, and/or other elements of the Standard having future effective dates as indicated in the preface. The prior text for requirements that have been revised and that have a future effective date are located after the Standard, and are preceded by a "SUPERSEDED REQUIREMENTS" notice.

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub



ISA – The International Society of Automation
ANSI/ISA 60079-0 (12.00.01)-2009
Fifth Edition



Underwriters Laboratories Inc.
ANSI/UL 60079-0
Fifth Edition

Explosive atmospheres – Part 0: Equipment – General requirements

October 21, 2009

(Title Page Reprinted: December 8, 2009)



ANSI/UL 60079-0-2009

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
Document Sharing Hub

Commitment for Amendments

This Standard is issued jointly by the International Society of Automation (ISA) and Underwriters Laboratories Incorporated (UL). Amendments to this Standard will be made only after processing according to the Standards writing procedures by ISA and UL. ***ISA and UL will issue revisions to this standard by means of a new edition or revised or additional pages bearing their date of issue.***

ISBN 978-1-936007-30-1

Copyright © 2009

ISA

These materials are subject to copyright claims of IEC, ANSI, and ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced in any form, including an electronic retrieval system, without the prior written permission of ISA. All requests pertaining to this Standard should be submitted to ISA.

The most recent designation of ANSI/ISA 60079-0 as an American National Standard (ANSI) occurred on November 16, 2009.

Copyright © 2009 Underwriters Laboratories Inc.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

This ANSI/UL Standard for Safety consists of the Fifth edition including revisions through December 8, 2009.

The most recent designation of ANSI/UL 60079-0 as an American National Standard (ANSI) occurred on October 21, 2009. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, Title Page (front and back), or the Preface. The National Difference Page and IEC Foreword are also excluded from the ANSI approval of IEC-based standards.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

To purchase UL Standards, visit Comm 2000 at http://www.comm-2000.com/help/how_to_order.aspx or call toll-free 1-888-853-3503.

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

CONTENTS

General Notes	7
Preface (ISA)	8
National Differences	12
FOREWORD	13
1 Scope	15
2 Normative references	18
3 Terms and definitions	26
4 Equipment grouping	34
4.1 Group I	34
4.2 Group II	35
4.3 Group III	35
4.4 Equipment for a particular explosive atmosphere	36
5 Temperatures	36
5.1 Environmental influences	36
5.2 Service temperature	37
5.3 Maximum surface temperature	38
6 Requirements for all electrical apparatus	41
6.1 General	41
6.2 Mechanical strength of equipment	42
6.3 Opening times	43
6.4 Circulating currents	43
6.5 Gasket retention	44
6.6 Electromagnetic and ultrasonic energy radiating equipment	44
7 Non-metallic enclosures and non-metallic parts of enclosures	46
7.1 General	46
7.2 Thermal endurance	48
7.3 Resistance to light	48
7.4 Electrostatic charges on external non-metallic materials	49
7.5 Threaded holes	52
8 Metallic enclosures and metallic parts of enclosures	52
8.1 Material composition	52
8.2 Threaded holes	55
9 Fasteners	55
9.1 General	55
9.2 Special fasteners	55
9.3 Holes for special fasteners	56
10 Interlocking devices	57
11 Bushings	57
12 Materials used for cementing	57
13 Ex components	58
13.1 General	58
13.2 Mounting	58
13.3 Internal mounting	58
13.4 External mounting	59
14 Connection facilities and termination compartments	59
14.1 General	59

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

14.2	Termination compartment	59
14.3	Type of protection	59
14.4	Creepage and clearance	59
15	Connection facilities for earthing or bonding conductors	59
15.1	Equipment requiring earthing	59
15.2	Equipment not requiring earthing	60
15.3	Size of conductor connection	61
15.4	Protection against corrosion	62
15.5	Secureness of electrical connections	62
16	Entries into enclosures	62
16.1	General	62
16.2	Identification of entries	63
16.3	Cable glands	63
16.4	Blanking elements	63
16.5	Temperature at branching point and entry point	64
16.6	Electrostatic charges of cable sheaths	64
17	Supplementary requirements for rotating electrical machines	66
17.1	Fans and fan hoods	66
17.2	Ventilation openings for external fans	66
17.3	Construction and mounting of the ventilating systems	66
17.4	Clearances for the ventilating system	67
17.5	Materials for external fans and fan hoods	67
17.6	Equipotential bonding conductors	67
18	Supplementary requirements for switchgear	67
18.1	Flammable dielectric	67
18.2	Disconnectors	68
18.3	Group I – Provisions for locking	68
18.4	Doors and covers	69
19	Supplementary requirements for fuses	69
20	Supplementary requirements for plugs, socket outlets and connectors	69
20.1	Interlocking	69
20.2	Energized plugs	71
21	Supplementary requirements for luminaires	71
21.1	General	71
21.2	Covers for luminaires of EPL Gb or EPL Db	71
21.3	Covers for luminaires of EPL Gc or EPL Dc	72
21.4	Special lamps	72
22	Supplementary requirements for caplights and handlights	72
22.1	Group I caplights	72
22.2	Group II and Group III caplights and handlights	73
23	Equipment incorporating cells and batteries	73
23.1	General	73
23.2	Batteries	73
23.3	Cell types	73
23.4	Cells in a battery	74
23.5	Ratings of batteries	74
23.6	Interchangeability	75
23.7	Charging of primary batteries	75
23.8	Leakage	75
23.9	Connections	75
23.10	Orientation	75
23.11	Replacement of cells or batteries	75
23.12	Replaceable battery pack	76

UL COPYRIGHTED MATERIAL –
 NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
 DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
 Document Sharing Hub

24	Documentation	76
25	Compliance of prototype or sample with documents	76
26	Type tests	76
26.1	General	76
26.2	Test configuration	77
26.3	Tests in explosive test mixtures	77
26.4	Tests of enclosures	77
26.5	Thermal tests	82
26.6	Torque test for bushings	85
26.7	Non-metallic enclosures or non-metallic parts of enclosures	86
26.8	Thermal endurance to heat	87
26.9	Thermal endurance to cold	87
26.10	Resistance to light	88
26.11	Resistance to chemical agents for Group I electrical equipment	88
26.12	Earth continuity	89
26.13	Surface resistance test of parts of enclosures of non-metallic materials	91
26.14	Charging tests	92
26.15	Measurement of capacitance	96
27	Routine tests	97
28	Manufacturer's responsibility	97
28.1	Conformity with the documentation	97
28.2	Certificate	98
28.3	Responsibility for marking	98
29	Marking	98
29.1	Location	98
29.2	General	99
29.3	Ex marking for explosive gas atmospheres	100
29.4	Ex marking for explosive dust atmospheres	103
29.5	Combined types of protection	106
29.6	Multiple types of protection	106
29.7	Ga using two independent Gb types of protection	107
29.8	Ex components	107
29.9	Small equipment and small Ex components	108
29.10	Extremely small equipment and extremely small Ex components	109
29.11	Warning markings	109
29.12	Alternate marking of equipment protection levels (EPLs)	110
29.13	Cells and batteries	112
29.14	Examples of marking ³	113
29.15DV.1	External grounding or bonding terminals	119
29.16DV.1	Class I, Division 2, Equivalency Marking	119
29.16DV.2	Class I, Division 2, Group C	120
29.16DV.3	Class I, Division 2, Group B	120
29.16DV.4	Class I, Division 2, Group A	120
29.17DV.1	Class I, Division 1, Equivalency Marking	120
29.17DV.2	Class I, Division 1, Group C	120
29.17DV.3	Class I, Division 1, Group B	121
29.17DV.4	Class I, Division 1, Group A	121
29.18DV.1	Abbreviated Markings	121
30	Instructions	121
30.1	General	121
30.2	Cells and batteries	122

UL COPYRIGHTED MATERIAL –
 NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
 DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

Annex A (normative) Supplementary requirements for cable glands

A.1	General	123
A.2	Constructional requirements	123
A.2.1	Cable sealing	123
A.2.2	Filling compounds	124
A.2.3	Clamping	124
A.2.4	Lead-in of cable	125
A.2.5	Release by a tool	126
A.2.6	Fixing	126
A.2.7	Degree of protection	126
A.3	Type tests	126
A.3.1	Tests of clamping of non-armoured and braided cables	126
A.3.2	Tests of clamping of armoured cables	129
A.3.3	Type test for resistance to impact	130
A.3.4	Test for degree of protection (IP) of cable glands	130
A.4	Marking	130
A.4.1	Marking of cable glands	130
A.4.2	Marking of cable-sealing rings	131

Annex B (normative) Requirements for Ex components

Annex C (informative) Example of rig for resistance to impact test

Annex D (informative) Introduction of an alternative risk assessment method encompassing “equipment protection levels” for Ex equipment

D.1	Historical background	136
D.2	General	137
D.2.1	Mines susceptible to firedamp (Group I)	137
D.2.2	Gases (Group II)	137
D.2.3	Dusts (Group III)	138
D.3	Risk of ignition protection afforded	139
D.4	Implementation	139

Annex E (informative) Motors supplied by converters

Annex DVF (Informative) Common Standards – Safety Requirements for Electrical Equipment

Annex DVG (informative) Equipment grounding

Bibliography

General Notes

This is the common ISA and UL Standard for Explosive atmospheres – Part 0: Equipment – General requirements. It is the Fifth edition of ANSI/ISA 60079-0 and the Fifth edition of ANSI/UL 60079-0. This document is a modification of the IEC document and includes U.S. deviations encompassing both additions and deletions of information.

ISA 60079-0 and UL 60079-0 contain identical requirements, and identical publication dates. The presentation and format of the standards material may differ between the two published standards.

This common standard was prepared by International Society of Automation (ISA) and Underwriters Laboratories Inc. (UL).

Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.

Note: Although the intended primary application of this standard is stated in its scope, it is important to note that it remains the responsibility of the users of the standard to judge its suitability for their particular purpose.

Level of harmonization

This standard adopts the IEC text with deviations.

The requirements are presented in different formats. The ISA version of the standard illustrates the national differences from the IEC text through the use of legislative text (strike-out and underline). The UL version of the standard illustrates national differences immediately following the IEC text. National differences between the UL version and the ISA version shall be word for word except for editorial changes.

Interpretations

The interpretation by the SDO of an identical or equivalent standard shall be based on the literal text to determine compliance with the standard in accordance with the procedural rules of the SDO. If more than one interpretation of the literal text has been identified, a revision shall be proposed as soon as possible to each of the SDOs to more accurately reflect the intent.

UL Effective Date

As of October 21, 2009 all products Listed or Recognized by UL must comply with the requirements in this standard except for clauses in the following list, which are effective December 31, 2012.

Clauses 6.6, 7.2.2, 7.3, 9.2 – 9.3, 26.4.1.2.2, 29.2 c)

Between October 21, 2009 and December 31, 2012, new product submittals to UL may be evaluated under all requirements in this standard or, if requested in writing, evaluated under presently effective requirements only. The presently effective requirements are contained in the Fourth edition of UL 60079-0.

A UL effective date is one established by Underwriters Laboratories Inc. and is not part of the ANSI approved standard.

Preface (ISA)

This ISA standard is based on the Fifth edition of IEC Publication 60079-0. It is the intention of the ISA12 Committee to develop an ANSI Standard that is harmonized with IEC 60079-0 to the fullest extent possible. This preface is included for informational purposes and is not part of ISA 60079-0. The document is a modification of the IEC document and includes U.S. deviations encompassing both additions and deletions of information.

The significant changes with respect to the previous edition are listed below:

- Requirements for explosive dust atmospheres transferred from IEC 61241.0.
- The marking Group “II” along has been replaced by “IIA”, “IIB”, or “IIC” as many of the enclosure requirements are now aligned with a specific sub-group.
- Dust groups defined in Group IIIA, IIIB and IIIC.
- Limits for ultrasonic and electromagnetic radiation introduced.
- Remainder of “electrostatic” requirements transferred from IEC 60079-26.
- Equipment protection levels (EPL) introduced.
- Transition of term from “apparatus” to “equipment” (where appropriate).

The standards referenced within this document may contain provisions which, through reference in this text, constitute requirements of this document. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this document are encouraged to investigate the possibility of applying the most recent editions of the standards indicated within this document. Members of IEC and ISO maintain registers of currently valid International Standards. ANSI maintains registers of currently valid U.S. National Standards.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavour to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION – ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA’S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER’S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following people served as members of ISA12.0:

NAME

W. Lawrence, Chair
 M. Coppler, Managing Director
 D. Ankele
 S. Arnold
 A. Ballard
 K. Boegli
 S. Czaniecki
 J. Dolphin
 A. Engler
 D. Jagger
 J. Jonscher
 P. Kovscek
 G. Kozinski
 J. Kuczka
 C. Kurtzman
 D. Lombard
 N. Ludlam
 R. Masek
 E. Massey
 O. Murphy
 J. Neagle
 A. Page
 R. Seitz
 J. Thomas
 D. Wechsler
 R. Wigg

COMPANY

FM Approvals LLC
 Ametek Inc
 Underwriters Laboratories Inc.
 Ametek Drexelbrook
 Consultant
 Phoenix Contact Inc.
 Intrinsic Safety Concepts Inc.
 PSC Solutions
 Det Norske Veritas DNV
 Bifold-Fluid Power
 Adalet PLM
 Industrial Scientific Corp.
 GE Infrastructure Sensing
 Killark
 Rosemount Inc.
 Vantage Technology LLC
 FM Approvals Ltd.
 CSA International
 Baldor Electric Co
 Brooks Instruments LLC
 Intertek ETL SEMKO
 Consultant
 Artech Engineering
 Schlumberger
 Dow Chemical Co.
 E-x Solutions International Pty. Ltd.

The following people served as members of ISA Committee ISA12:

NAME

T. Schnaare, Chair
 W. Lawrence, Vice Chair
 M. Coppler, Managing Director
 D. Ankele
 A. Ballard
 K. Boegli
 D. Burns
 C. Casso
 S. Czaniecki
 J. Dolphin
 M. Dona
 T. Dubaniewicz
 U. Dugar
 A. Engler
 W. Fiske
 G. Garcha
 C. Huntley
 D. Jagger
 F. Kent
 P. Kovscek
 J. Kuczka

COMPANY

Rosemount Inc.
 FM Approvals LLC
 Ametek Inc.
 Underwriters Laboratories Inc.
 Consultant
 Phoenix Contact Inc.
 Shell Exploration & Production Company
 Nabors Industries
 Intrinsic Safety Concepts Inc.
 PSC Solutions
 Santos Ltd.
 NIOSH
 Mobil Chemical Company
 Det Norske Veritas DNV
 Intertek
 GE Energy
 MSHA A&CC
 Bifold-Fluid Power
 Honeywell Inc.
 Industrial Scientific Corporation
 Killark

UL COPYRIGHTED MATERIAL –
 NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
 DISTRIBUTION WITHOUT PERMISSION FROM UL

Table Continued on Next Page



Documents

Document Sharing Hub

NAME

E. Leubner
S. Leverington
N. Ludlam
K. Mansoor
R. Masek
E. Massey
J. Miller
A. Page
R. Seitz
R. Sierra
M. Spencer
J. Thomas
D. Wechsler
R. Wigg

COMPANY

Cooper Crouse-Hinds
Zone Safety Solutions
FM Approvals Ltd.
Siemens Industry Inc.
CSA International
Baldor Electric Company
Detector Electronics Corporation
Consultant
Artech Engineering
USCG
Columbia Gas Transmission
Schlumberger
Dow Chemical Company
E-x Solutions International Pty. Ltd.

This document was approved for publication by the ISA Standards and Practices Board on 14 October 2009.

NAME

J. Tatera
P. Brett
M. Coppler
E. Cosman
B. Dumortier
D. Dunn
R. Dunn
J. Gilsinn
E. Icayan
J. Jamison
D. Kaufman
K. P. Lindner
V. Maggioli
T. McAviney
G. McFarland
R. Reimer
N. Sands
H. Sasajima
T. Schnaare
I. Verhappen
R. Webb
W. Weidman
J. Weiss
M. Widmeyer
M. Zielinski

COMPANY

Tatera & Associates Inc.
Honeywell Inc. E I Du Pont Company
Ametek Inc.
The Dow Chemical Company
Schneider Electric
Aramco Services Co.
DuPont Engineering
NIST/MEL
ACES Inc
Huskey Energy Inc.
Honeywell
Endress + Hauser Process Solutions AG
Feltronics Corp.
Jacobs Engineering Group
Emerson Process Mgmt. Power & Water Sol.
Rockwell Automation
DuPont
Yamatake Corp.
Rosemount Inc.
MTL Instrument Group
ICS Secure LLC
Worley Parsons
Applied Control Solutions LLC
Consultant
Emerson Process Management

National Differences

National Differences from the text of International Electrotechnical Commission (IEC) Publication 60079-0, Explosive Atmospheres – Part 0: Equipment – General Requirements, copyright 2007, are indicated by notations (differences) and are presented in bold text.

In the ISA publication of this standard, National Differences are presented using legislative text (strike-out and underline). The national difference type is identified in an informative annex.

There are five types of National Differences as noted below. The difference type is noted on the first line of the National Difference in the standard. The standard may not include all types of these National Differences.

The UL printed standard includes the national difference types within the body of the text. The ISA printed standard includes the national difference types in an annex at the back of the standard.

D1 – These are National Differences which are based on **basic safety principles and requirements**, elimination of which would compromise safety for consumers and users of products.

D2 – These are national differences from IEC requirements based on existing **safety practices**. These requirements reflect national safety practices, where empirical substantiation (for the IEC or national requirement) is not available or the text has not been included in the IEC standard.

DC – These are National Differences based on the **component standards** and will not be deleted until a particular component standard is harmonized with the IEC component standard.

DE – These are National Differences based on **editorial comments or corrections**.

DR – These are National Differences based on the **national regulatory requirements**.

Each national difference contains a description of what the national difference entails. Typically one of the following words is used to explain how the text of the national difference is to be applied to the base IEC text:

Addition / Add - An addition entails adding a complete new numbered clause, subclause, table, figure, or annex. Addition is not meant to include adding select words to the base IEC text.

Deletion / Delete - A deletion entails complete deletion of an entire numbered clause, subclause, table, figure, or annex without any replacement text.

Modification / Modify - A modification is an altering of the existing base IEC text such as the addition, replacement or deletion of certain words or the replacement of an entire clause, subclause, table, figure, or annex of the base IEC text.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES – Part 0: Equipment – General requirements

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and nongovernmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.

2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.

3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.

4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.

5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.

6) All users should ensure that they have the latest edition of this publication.

7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.

8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fifth edition cancels and replaces the fourth edition, published in 2004, and constitutes a full technical revision.

The significant changes with respect to the previous edition are listed below:

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM  **Documents**
Document Sharing Hub

- Requirements for explosive dust atmospheres transferred from IEC 61241-0.
- The marking Group “II” alone has been replaced by “IIA”, “IIB”, or “IIC” as many of the enclosure requirements are now aligned with a specific sub-group.
- Dust groups defined as Group IIIA, IIIB and IIIC.
- Limits for ultrasonic and electromagnetic radiation introduced.
- Remainder of “electrostatic” requirements transferred from IEC 60079-26.
- Equipment protection levels (EPL) introduced.
- Transition of term from “apparatus” to “equipment” (where appropriate).

The text of this standard is based on the following documents:

FDIS	Report on voting
31/708/FDIS	31/718/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title Explosive atmospheres, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of a new edition.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under “<http://webstore.iec.ch>” in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

EXPLOSIVE ATMOSPHERES – Part 0: Equipment – General Requirements

1 Scope

This part of IEC 60079 specifies the general requirements for construction, testing and marking of electrical equipment and Ex components intended for use in explosive atmospheres.

1DV.1 DR Modification of Clause 1 first paragraph to replace with the following:

1DV.1.1 This standard specifies the general requirements for construction, testing and marking of electrical equipment and Ex components to use in explosive atmospheres. Explosive atmospheres are identified by the National Electrical Code®, NFPA 70 as hazardous (classified) locations and include the following specified locations.

- Class I, Zone 0;
- Class I, Zone 1;
- Class I, Zone 2;
- Zone 20;
- Zone 21; and
- Zone 22.

Unless modified by one of the standards supplementing this standard, electrical equipment complying with this standard is intended for use in hazardous areas in which explosive atmospheres exist under normal atmospheric conditions of

- temperature -20°C to $+60^{\circ}\text{C}$;
- pressure 80 kPa (0,8 bar) to 110 kPa (1,1 bar); and
- air with normal oxygen content, typically 21 % v/v.

The application of electrical equipment in atmospheric conditions outside this range requires special consideration and may require additional assessment and testing.

NOTE 1 Although the normal atmospheric conditions above give a temperature range for the atmosphere of -20°C to $+60^{\circ}\text{C}$, the normal ambient temperature range for the equipment is -20°C to $+40^{\circ}\text{C}$, unless otherwise specified and marked. See 5.1.1.

NOTE 2 In designing equipment for operation in explosive atmospheres under conditions other than the atmospheric conditions given above, this standard may be used for guidance. However, additional testing related specifically to the intended conditions of use is recommended. This is particularly important when the types of protection 'flameproof enclosure "d"' (IEC 60079-1) and 'intrinsic safety "i"' (IEC 60079-11 or IEC 61241-11) are applied.

1DV.2 DR Modification of Clause 1 Note 2 as follows:

1DV.2.1 Delete "(IEC 60079-1) " and "(IEC 60079-11 or IEC 61241-11)".

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM  Documents
Document Sharing Hub

NOTE 3 Requirements given in this standard result from an ignition hazard assessment made on electrical equipment. The ignition sources taken into account are those found associated with this type of equipment, such as hot surfaces, mechanically generated sparks, thermite reactions, electrical arcing and static electric discharge in normal industrial environments.

NOTE 4 It is acknowledged that, with developments in technology, it may be possible to achieve the objectives of the IEC 60079 series of standards in respect of explosion prevention by methods that are not yet fully defined. Where a manufacturer wishes to take advantage of such developments, this International Standard, as well as other standards in the IEC 60079 series, may be applied in part. It is intended that the manufacturer prepare documentation that clearly defines how the IEC 60079 series of standards has been applied, together with a full explanation of the additional techniques employed. The designation "Ex s" has been reserved to indicate a type of protection that is not defined by the IEC 60079 series of standards, but may be referenced in national requirements.

1DV.3 DR Delete Clause 1 Note 4.

1DV.3.1 This Note does not apply.

NOTE 5 Where an explosive gas atmosphere and a combustible dust atmosphere are, or may be, present at the same time, the simultaneous presence of both should be considered and may require additional protective measures.

This standard does not specify requirements for safety, other than those directly related to the explosion risk. Ignition sources like adiabatic compression, shock waves, exothermic chemical reaction, self ignition of dust, naked flames and hot gases/liquids, are not addressed by this standard.

NOTE 6 Such equipment should be subjected to a hazard analysis that identifies and lists all of the potential sources of ignition by the electrical equipment and the measures to be applied to prevent them becoming effective.

This standard is supplemented or modified by the following standards concerning specific types of protection:

- IEC 60079-1: Gas – Flameproof enclosures "d";
- IEC 60079-2: Gas – Pressurized enclosures "p";
- IEC 60079-5: Gas – Powder filling "q";
- IEC 60079-6: Gas – Oil immersion "o";
- IEC 60079-7: Gas – Increased safety "e";
- IEC 60079-11: Gas – Intrinsic safety "i";
- IEC 60079-15: Gas – Type of protection "n";
- IEC 60079-18: Gas and Dust – Encapsulation "m";
- IEC 61241-1: Dust – Protection by enclosures "tD";
- IEC 61241-2 (IEC 61241-4): Dust – Pressurization "pD";
- IEC 61241-11: Dust – Intrinsic safety "iD".

1DV.4 DR Modification of Clause 1 fifth paragraph to replace with the following dashed items:

1DV.4.1 – ISA 60079-2 (12.04.01): Gas – Pressurized enclosures “p”;

– ISA 61241-1 (12.10.03): Dust – Protection by enclosures “tD”;

– ISA 61241-2 (12.10.06): Dust – Pressurization “pD”;

– ISA 61241-11 (12.10.04): Dust – Intrinsic safety “iD”.

– ISA 61241-18 (12.10.07): Dust – Encapsulation “mD”.

– UL 60079-1: Gas – Flameproof enclosures “d”;

– UL 60079-5: Gas – Powder filling “q”;

– UL 60079-6: Gas – Oil immersion “o”;

– UL 60079-7: Gas – Increased safety “e”;

– UL 60079-11: Gas – Intrinsic safety “i”;

– UL 60079-15: Gas – Type of protection “n”;

– UL 60079-18: Gas and Dust – Encapsulation “m”.

NOTE 7 The former requirements of IEC 61241-18, Encapsulation “mD”, have been incorporated in IEC 60079-18.

1DV.5 DR Delete Clause 1 Note 7.

1DV.5.1 This Note does not apply.

This standard is supplemented or modified by the following equipment standards:

IEC 60079-25: Electrical apparatus for explosive gas atmospheres – Part 25: Intrinsically safe systems

IEC 60079-26: Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga

IEC 60079-28: Explosive atmospheres – Part 28: Protection of equipment and transmission systems using optical radiation

IEC 62013-1: Caplights for use in mines susceptible to firedamp – Part 1: General requirements – Construction and testing in relation to the risk of explosion

IEC 60079-30-1: Explosive atmospheres – Part 30-1: Electrical resistance trace heating – General and testing requirements.

1DV.6 DR Modification of Clause 1 sixth paragraph to replace with the following and addition of Note.

1DV.6.1 ANSI/ISA 60079-26 (12.00.03): Electrical equipment for use in Class I, Zone 0 hazardous (classified) locations

ANSI/IEEE 515: Standard for Testing, Design, Installation, and Maintenance of Electrical Heat Tracing for Industrial Applications

NOTE Components such as power connections, splices, end terminations, as well as cable entries, fittings, and seals, are to be evaluated according to the type of protection employed.

This standard with the additional standards mentioned above, are not applicable to the construction of

- electromedical apparatus,
- shot-firing exploders,
- test devices for exploders, and
- shot-firing circuits.

1DV.7 DR Addition of 7DV:

1DV.7.1 The U.S. version of IEC 60079-0 does not include requirements for Group I electrical apparatus. Requirements for Group I electrical apparatus included in this document are to be considered omitted in all instances where they appear.

1DV.8 DR Addition of 8DV:

1DV.8.1 Where references are made to other IEC 60079 standards, the referenced requirements found in these standards shall apply as modified by any applicable U.S. National Differences.

2 Normative references

2DV.1 DR Modification of title in Clause 2 as follows:

Delete “Normative”.

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1,
Rotating electrical machines – Part 1: Rating and performance

IEC 60034-5,
Rotating electrical machines – Part 5: Classification of degrees of protection provided by the enclosures of rotating electrical machines (IP Code)

IEC 60050(426),
International Electrotechnical Vocabulary (IEV) – Chapter 426: Electrical apparatus for explosive atmospheres

IEC 60079-1,
Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"

IEC 60079-2,
Explosive atmospheres – Part 2: Equipment protection by pressurized enclosures "p"

IEC 60079-4,
Electrical apparatus for explosive gas atmospheres – Part 4: Method of test for ignition temperature

IEC 60079-5,
Explosive atmospheres – Part 5: Equipment protection by powder filling "q"

IEC 60079-6,
Explosive atmospheres – Part 6: Equipment protection by oil-immersion "o"

IEC 60079-7,
Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

IEC 60079-11,
Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"

IEC 60079-15,
Electrical apparatus for explosive gas atmospheres – Part 15: Construction, test and marking of type of protection "n" electrical apparatus

IEC 60079-18,
Electrical apparatus for explosive gas atmospheres – Part 18: Construction, test and marking of type of protection encapsulation "m" electrical apparatus

IEC 60079-25:
Electrical apparatus for explosive gas atmospheres – Part 25: Intrinsically safe systems

IEC 60079-26:
Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL)Ga

IEC 60079-28:
Explosive atmospheres – Part 28: Protection of equipment and transmission systems using optical radiation

IEC 60079-30-1:
Explosive atmospheres – Part 30-1: Electrical resistance trace heating – General and testing requirements

IEC 60079-31,
Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosures "tD"

IEC 60086-1,
Primary batteries – Part 1: General

IEC 60095-1,
Lead-acid starter batteries – Part 1: General requirements and methods of test

IEC 60192,
Low-pressure sodium vapour lamps – Performance specifications

IEC 60216-1,
Electrical insulating materials – Properties of thermal endurance – Part 1: Ageing procedures and evaluation of test results

IEC 60216-2,
Electrical insulating materials – Thermal endurance properties – Part 2: Determination of thermal endurance properties of electrical insulating materials – Choice of test criteria

IEC 60243-1,
Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies

IEC 60423,
Conduits for electrical purposes – Outside diameters of conduits for electrical installations and threads for conduits and fittings

IEC 60529,
Degrees of protection provided by enclosures (IP Code)

IEC 60622,
Secondary cells and batteries containing alkaline or other non-acid electrolytes – Sealed nickel-cadmium prismatic rechargeable single cells

IEC 60623,
Secondary cells and batteries containing alkaline or other non-acid electrolytes – Vented nickel-cadmium prismatic rechargeable single cells

IEC 60662,
High-pressure sodium vapour lamps

IEC 60664-1,
Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests

IEC 60947-1,
Low-voltage switchgear and controlgear – Part 1: General rules

IEC 61056-1,
General purpose lead-acid batteries (valve-regulated types) – Part 1: General requirements, functional characteristics – Methods of tests

IEC 61241-1,
Electrical apparatus for use in the presence of combustible dust – Part 1: Protection by enclosures “tD”

IEC 61241-4,
Electrical apparatus for use in the presence of combustible dust – Part 4: Type of protection “pD”

IEC 61241-11,
Electrical apparatus for use in the presence of combustible dust – Part 11: Protection by intrinsic safety “ID”

IEC 61951-1,
Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 1: Nickel-cadmium

IEC 61951-2,
Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 2: Nickel-metal hydride

IEC 62013-1,
Caplights for use in mines susceptible to firedamp – Part 1: General requirements – Construction and testing in relation to the risk of explosion

ISO 48,
Rubber, vulcanized or thermoplastic – Determination of hardness (hardness between 10 IRHD and 100 IRHD)

ISO 178,
Plastics – Determination of flexural properties

ISO 179 (all parts),
Plastics – Determination of Charpy impact properties

ISO 262,
ISO general-purpose metric screw threads – Selected sizes for screws, bolts and nuts

ISO 273,
Fasteners – Clearance holes for bolts and screws

ISO 286-2,
ISO system of limits and fits – Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts

ISO 527-2,
Plastics – Determination of tensile properties – Part 2: Test conditions for moulding and extrusion plastics

ISO 965-1,
ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data

ISO 965-3,
ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads

ISO 1817,
Rubber, vulcanized – Determination of the effect of liquids

ISO 4014,
Hexagon head bolts – Product grades A and B

ISO 4017,
Hexagon head screws – Product grades A and B

ISO 4026,
Hexagon socket set screws with flat point

ISO 4027,
Hexagon socket set screws with cone point

ISO 4028,
Hexagon socket set screws with dog point

ISO 4029,
Hexagon socket set screws with cup point

ISO 4032,
Hexagon nuts, style 1 – Product grades A and B

ISO 4762,
Hexagon socket head cap screws

ISO 4892-1,
Plastics – Methods of exposure to laboratory light sources – Part 1: General guidance

ANSI/UL 746B
Polymeric Materials – Long-Term Property Evaluations

2DV.2 DR Modification of Clause 2 references to replace with the following:

IEC 60034-1
Rotating electrical machines – Part 1: Rating and performance

IEC 60034-5
Rotating electrical machines – Part 5: Classification of degrees of protection provided by the enclosures of rotating electrical machines (IP Code)

IEC 60050(426)
International Electrotechnical Vocabulary (IEV) – Chapter 426: Electrical apparatus for explosive atmospheres

IEC 60079-4
Electrical apparatus for explosive gas atmospheres – Part 4: Method of test for ignition temperature

IEC 60086-1
Primary batteries – Part 1: General

IEC 60095-1
Lead-acid starter batteries – Part 1: General requirements and methods of test

IEC 60192
Low-pressure sodium vapour lamps – Performance specifications

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM**



Documents
Document Sharing Hub

IEC 60216-1

Electrical insulating materials – Properties of thermal endurance – Part 1: Ageing procedures and evaluation of test results

IEC 60216-2

Electrical insulating materials – Thermal endurance properties – Part 2: Determination of thermal endurance properties of electrical insulating materials – Choice of test criteria

IEC 60243-1

Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies

IEC 60423

Conduits for electrical purposes – Outside diameters of conduits for electrical installations and threads for conduits and fittings

IEC 60529

Degrees of protection provided by enclosures (IP Code)

IEC 60622

Secondary cells and batteries containing alkaline or other non-acid electrolytes – Sealed nickel-cadmium prismatic rechargeable single cells

IEC 60623

Secondary cells and batteries containing alkaline or other non-acid electrolytes – Vented nickel-cadmium prismatic rechargeable single cells

IEC 60662

High-pressure sodium vapour lamps

IEC 60664-1

Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests

IEC 61056-1

General purpose lead-acid batteries (valve-regulated types) – Part 1: General requirements, functional characteristics – Methods of tests

IEC 61951-1

Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 1: Nickel-cadmium

IEC 61951-2

Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 2: Nickel-metal hydride

ISA 60079-2

Explosive atmospheres – Part 2: Equipment protection by pressurized enclosures “p”

ISA 60079-2 (12.04.01)

Electrical Apparatus for Explosive Gas Atmospheres – Part 2 Pressurized Enclosures “p”

ISA 60079-26 (12.00.03)***Electrical Equipment for Use in Class I, Zone 0 Hazardous (Classified) Locations*****ISA 61241-1 (12.10.03)*****Electrical Apparatus for Use in Zone 21 and Zone 22 Hazardous (Classified) Locations – Protection by Enclosures “tD”*****ISA 61241-4 (12.10.06)*****Electrical Apparatus for Use in Zone 21 and Zone 22 Hazardous (Classified) Locations – Protection by Pressurization “pD”*****ISA 61241-11 (12.10.04)*****Electrical Apparatus for Use in Zone 20, 21, and 22 Hazardous (Classified) Locations – Protection by Intrinsic Safety “iD”*****ISA 61241-18 (12.10.07)*****Electrical Apparatus for Use in Zone 20, 21, and 22 Hazardous (Classified) Locations – Protection by Encapsulation “mD”*****ISO 179 (all parts)*****Plastics – Determination of Charpy impact properties*****ISO 262*****ISO general-purpose metric screw threads – Selected sizes for screws, bolts and nuts*****ISO 273*****Fasteners – Clearance holes for bolts and screws*****ISO 286-2*****ISO system of limits and fits – Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts*****ISO 527-2*****Plastics – Determination of tensile properties – Part 2: Test conditions for moulding and extrusion plastics*****ISO 965-1*****ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*****ISO 965-3*****ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads*****ISO 4014*****Hexagon head bolts – Product grades A and B*****ISO 4017*****Hexagon head screws – Product grades A and B*****ISO 4026*****Hexagon socket set screws with flat point***

ISO 4027

Hexagon socket set screws with cone point

ISO 4028

Hexagon socket set screws with dog point

ISO 4029

Hexagon socket set screws with cup point

ISO 4032

Hexagon nuts, style 1 – Product grades A and B

ISO 4762

Hexagon socket head cap screws

ISO 4892-1

Plastics – Methods of exposure to laboratory light sources – Part 1: General guidance

UL 157

Gaskets and Seals

UL 347

High Voltage Industrial Control Equipment

UL 486E

Equipment Wiring Terminals for use with Aluminum and/or Copper Conductors

UL 508

Industrial Control Equipment

UL 746B

Polymeric Materials – Long-Term Property Evaluations

UL 746C

Polymeric Materials – Use in Electrical Equipment Evaluations

UL 2225

Metal-Clad Cables and Cable-Sealing Fittings for Use in Hazardous (Classified) Location

UL 60079-1

Explosive atmospheres – Part 1: Equipment protection by flameproof enclosures "d"

UL 60079-5

Explosive atmospheres – Part 5: Equipment protection by powder filling "q"

UL 60079-6

Explosive atmospheres – Part 6: Equipment protection by oil-immersion "o"

UL 60079-7

Explosive atmospheres – Part 7: Equipment protection by increased safety "e"

UL 60079-11

Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM  **Documents**
Document Sharing Hub

UL 60079-15

Electrical apparatus for explosive gas atmospheres – Part 15: Construction, test and marking of type of protection "n" electrical apparatus

UL 60079-18

Electrical apparatus for explosive gas atmospheres – Part 18: Construction, test and marking of type of protection encapsulation "m" electrical apparatus

UL 60947-1

Low-voltage switchgear and controlgear – Part 1: General rules

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

For the definitions of any other terms, particularly those of a more general nature, reference should be made to IEC 60050(426) or other appropriate parts of the IEV (International Electrotechnical Vocabulary).

3.1 ambient temperature temperature of the air or other media, in the immediate vicinity of the equipment or component

NOTE This does not refer to the temperature of any process media, unless the equipment or component is totally immersed in the process media. See 5.1.1.

3.2 associated apparatus electrical apparatus which contains both energy-limited and non-energy-limited circuits and is constructed so that the non-energy-limited circuits cannot adversely affect the energy-limited circuits

NOTE Associated apparatus may be either:

- a) electrical apparatus which has an alternative type of protection included in this standard for use in the appropriate explosive atmosphere;
- b) electrical apparatus not so protected and which therefore is not to be used within an explosive atmosphere, for example, a recorder which is not of itself in an explosive atmosphere but is connected to a thermocouple situated within an explosive atmosphere where only the recorder input circuit is energy limited.

3.3 cells and batteries

3.3.1 battery assembly of two or more cells electrically connected to each other to increase the voltage or capacity

3.3.2 capacity quantity of electricity or electric charge, which a fully charged battery can deliver under specified conditions

3.3.3 cell assembly of electrodes and electrolyte which constitutes the smallest electrical unit of a battery

3.3.4 charging act of forcing current through a secondary cell or battery in the opposite direction to the normal flow to restore the energy

3.3.5 deep discharge event which reduces a cell voltage below that recommended by the cell or battery manufacturer

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM  **Documents**
Document Sharing Hub

3.3.6 inherently safe (ihs) cell (or battery) primary cell or battery in which the short-circuit current and maximum surface temperature are limited to a safe value by its internal resistance

3.3.7 maximum open-circuit voltage (of a cell or battery) maximum attainable voltage under normal conditions, that is, from either a new primary cell, or a secondary cell just after a full charge

NOTE See Tables 10 and 11 which show the maximum open-circuit voltage for acceptable cells.

3.3.8 nominal voltage (of a cell or battery) is that specified by the manufacturer

3.3.9 vented cell or battery secondary cell, or battery, having a cover provided with an opening through which gaseous products may escape

3.3.10 primary cell or battery electrochemical system capable of producing electrical energy by chemical reaction

3.3.11 reverse charging act of forcing current through either a primary cell or secondary cell in the same direction as the normal flow, for example, in an expired battery

3.3.12 sealed gas-tight cell or battery cell or battery which remains closed and does not release either gas or liquid when operated within the limits of charge or temperature specified by the manufacturer

NOTE 1 Such cells and batteries may be equipped with a safety device to prevent dangerously high internal pressure. The cell or battery does not require addition to the electrolyte and is designed to operate during its life in its original sealed state.

NOTE 2 The above definition is taken from IEC 60079-11. It differs from the definitions in IEC 486-01-20 and IEC 486-01-21 by virtue of the fact that it applies to either a cell or battery.

3.3.13 sealed valve-regulated cell or battery cell or battery which is closed under normal conditions but which has an arrangement which allows the escape of gas if the internal pressure exceeds a pre-determined value. The cell cannot normally receive an addition to the electrolyte

3.3.14 secondary cell or battery electrically rechargeable electrochemical system capable of storing electrical energy and delivering it by chemical reaction

3.3.15 container (battery) enclosure to contain the battery

NOTE The cover is a part of the battery container.

3.4 bushing insulating device carrying one or more conductors through an internal or external wall of an enclosure

3.5 cable gland device permitting the introduction of one or more electric and/or fibre optics cables into an electrical equipment so as to maintain the relevant type of protection

3.5.1 clamping device element of a cable gland for preventing tension or torsion in the cable from being transmitted to the connections

3.5.2 compression element element of a cable gland acting on the sealing ring to enable the latter to fulfil its function

3.5.3 **sealing ring** ring used in a cable gland or with a conduit entry to ensure the sealing between the entry and the cable or conduit

3.5.4 **ex cable gland** cable gland tested separately from the equipment enclosure but certified as equipment and which can be fitted to the equipment enclosure during installation

3.6 **certificate** document that assures the conformity of a product, process, system, person, or organization with specified requirements

NOTE The certificate may be either the supplier's declaration of conformity or the purchaser's recognition of conformity or certification (as a result of action by a third party) as defined in ISO/IEC 17000.

3.7 **conduit entry** means of introducing a conduit into electrical equipment so as to maintain the relevant type of protection

3.8 **connection facilities** terminals, screws or other parts, used for the electrical connection of conductors of external circuits

3.9 **continuous operating temperature COT** maximum temperature which ensures the stability and integrity of the material for the expected life of the equipment, or part, in its intended application

3.10 **degree of protection of enclosure IP** numerical classification according to IEC 60529 preceded by the symbol IP applied to the enclosure of electrical equipment to provide

- protection of persons against contact with, or approach to, live parts and against contact with moving parts (other than smooth rotating shafts and the like) inside the enclosure,
- protection of the electrical equipment against ingress of solid foreign objects, and
- where indicated by the classification, protection of the electrical equipment against harmful ingress of water

NOTE 1 The detailed test requirements for rotating electrical machines are in IEC 60034-5.

NOTE 2 The enclosure which provides the degree of protection IP is not necessarily identical to the equipment enclosure for the types of protection listed in the Foreword.

3.11 **dust** generic term including both combustible dust and combustible flyings

3.11.1 **combustible dust** finely divided solid particles, 500 µm or less in nominal size, which may be suspended in air, may settle out of the atmosphere under their own weight, may burn or glow in air, and may form explosive mixtures with air at atmospheric pressure and normal temperatures

NOTE 1 This includes dust and grit as defined in ISO 4225.

NOTE 2 The term solid particles is intended to address particles in the solid phase and not the gaseous or liquid phase, but does not preclude a hollow particle.

3.11.1.1 **conductive dust** combustible dust with electrical resistivity equal to or less than $10^3 \Omega \cdot m$

NOTE IEC 61241-2-2 contains the test method for determining the electrical resistivity of dusts.

3.11.1.1DV.1 DR Modification of Clause 3.11.1.1 to replace with the following and delete NOTE:

conductive dust – metal dust.

3.11.1.2 non-conductive dust combustible dust with electrical resistivity greater than $10^3 \Omega \cdot m$

3.11.1.2.1DV.1 DR Modification of Clause 3.11.1.2 to replace with the following:

non-conductive dust – dust other than metal dust.

3.11.2 combustible flyings solid particles, including fibres, greater than 500 μm in nominal size which may be suspended in air and could settle out of the atmosphere under their own weight

NOTE Examples of flyings include rayon, cotton (including cotton linters and cotton waste), sisal, jute, hemp, cocoa fibre, oakum, and baled waste kapok.

3.12 dust-tight enclosure enclosure capable of excluding the ingress of observable dust particle deposits

3.13 dust-protected enclosure enclosure in which the ingress of dust is not totally excluded, but is unlikely to enter in sufficient quantity to interfere with the safe operation of the equipment and does not accumulate in a position within the enclosure where it is liable to cause an ignition hazard

3.14 electrical equipment items applied as a whole or in part for the utilization of electrical energy

NOTE These include, amongst others, items for the generation, transmission, distribution, storage, measurement, regulation, conversion and consumption of electrical energy and items for telecommunications.

3.15 electrical parameters – apparatus with energy limitation

3.15.1 maximum external capacitance C_o maximum capacitance that can be connected to the connection facilities of the apparatus without invalidating the type of protection

3.15.2 maximum external inductance L_o maximum value of inductance that can be connected to the connection facilities of the apparatus without invalidating the type of protection

3.15.3 maximum input current I_i maximum current (peak a.c. or d.c.) that can be applied to the connection facilities of apparatus without invalidating the type of protection

3.15.4 maximum input power P_i maximum power that can be applied to the connection facilities of apparatus without invalidating the type of protection

3.15.5 maximum input voltage U_i maximum voltage (peak a.c. or d.c.) that can be applied to the connection facilities of apparatus without invalidating the type of protection

3.15.6 maximum internal capacitance C_i maximum equivalent internal capacitance of the apparatus which is considered as appearing across the connection facilities

3.15.7 maximum internal inductance L_i maximum equivalent internal inductance of the apparatus which is considered as appearing at the connection facilities

3.15.8 **maximum output current** I_o maximum current (peak a.c. or d.c.) in apparatus that can be taken from the connection facilities of the apparatus

3.15.9 **maximum output power** P_o maximum electrical power that can be taken from the apparatus

3.15.10 **maximum output voltage** U_o maximum voltage (peak a.c. or d.c.) that can appear at the connection facilities of the apparatus at any applied voltage up to the maximum voltage

3.15.11 **maximum r.m.s. a.c. or d.c. voltage** U_m maximum voltage that can be applied to the non energy-limited connection facilities of associated apparatus without invalidating the type of protection

3.16 **enclosure** all the walls, doors, covers, cable glands, rods, spindles, shafts, etc. which contribute to the type of protection and/or the degree of protection IP of the electrical equipment

3.17 **equipment (for explosive atmospheres)** general term including apparatus, fittings, devices, components, and the like used as a part of, or in connection with, an electrical installation in an explosive atmosphere

3.18 **equipment protection level EPL** level of protection assigned to equipment based on its likelihood of becoming a source of ignition and distinguishing the differences between explosive gas atmospheres, explosive dust atmospheres, and the explosive atmospheres in mines susceptible to firedamp

NOTE The equipment protection level may optionally be employed as part of a complete risk assessment of an installation, see IEC 60079-14.

3.18DV.1 DR Modification of Clause 3.18 Note to replace with the following:

3.18DV.1.1 Although the marking identifying the equipment protection level (EPL) may appear on equipment evaluated against this standard, the 2008 NEC does not recognize the concept of employing the equipment protection level in a complete risk assessment of an installation.

3.18.1 **EPL Ma** equipment for installation in a mine susceptible to firedamp, having a "very high" level of protection, which has sufficient security that it is unlikely to become an ignition source in normal operation, during expected malfunctions or during rare malfunctions, even when left energized in the presence of an outbreak of gas

3.18.2 **EPL Mb** equipment for installation in a mine susceptible to firedamp, having a "high" level of protection, which has sufficient security that it is unlikely to become a source of ignition in normal operation or during expected malfunctions in the time span between there being an outbreak of gas and the equipment being de-energized

3.18.3 **EPL Ga** equipment for explosive gas atmospheres, having a "very high" level of protection, which is not a source of ignition in normal operation, during expected malfunctions or during rare malfunctions

3.18.4 **EPL Gb** equipment for explosive gas atmospheres, having a "high" level of protection, which is not a source of ignition in normal operation or during expected malfunctions,

3.18.5 **EPL Gc** equipment for explosive gas atmospheres, having a "enhanced" level of protection, which is not a source of ignition in normal operation and which may have some additional protection to ensure that it remains inactive as an ignition source in the case of regular expected occurrences (for example failure of a lamp)

3.18.6 **EPL Da** equipment for explosive dust atmospheres, having a "very high" level of protection, which is not a source of ignition in normal operation, during expected malfunctions, or during rare malfunctions

3.18.7 **EPL Db** equipment for explosive dust atmospheres, having a "high" level of protection, which is not a source of ignition in normal operation or during expected malfunctions

3.18.8 **EPL Dc** equipment for explosive dust atmospheres, having a "enhanced" level of protection, which is not a source of ignition in normal operation and which may have some additional protection to ensure that it remains inactive as an ignition source in the case of regular expected occurrences (for example failure of a lamp)

3.19 **Ex blanking element** threaded blanking element tested separately from the equipment enclosure but having an equipment certificate and which is intended to be fitted to the equipment enclosure without further consideration

NOTE 1 This does not preclude an Ex component certificate for blanking elements

NOTE 2 Non-threaded blanking elements are not equipment.

3.20 **Ex component** part of electrical equipment or a module (other than an Ex cable gland), marked with the symbol "U", which is not intended to be used alone and requires additional consideration when incorporated into electrical equipment or systems for use in explosive atmospheres

3.20DV.1 DR Modification of Clause 3.20 as follows:

Delete "marked with the symbol "U","

3.21 **Ex thread adapter** thread adapter tested separately from the enclosure but having an equipment certificate and which is intended to be fitted to the equipment enclosure without further consideration

NOTE This does not preclude an Ex component certificate for thread adapters.

3.22 **explosive atmosphere** mixture with air, under atmospheric conditions, of flammable substances in the form of gas, vapour, dust, fibres, or flyings which, after ignition, permits self-sustaining propagation

3.23 **explosive dust atmosphere** mixture with air, under atmospheric conditions, of flammable substances in the form of dust, or flyings which, after ignition, permits self-sustaining propagation

3.24 **explosive gas atmosphere** mixture with air, under atmospheric conditions, of flammable substances in the form of gas or vapour, which, after ignition, permits self-sustaining flame propagation

3.25 **explosive test mixture** specified explosive mixture used for the testing of electrical equipment for explosive gas atmospheres

3.26 ignition temperature of an explosive gas atmosphere lowest temperature of a heated surface which, under specified conditions according to IEC 60079-4, will ignite a flammable substance in the form of a gas or vapour mixture with air

3.27 ignition temperature of a dust layer lowest temperature of a hot surface at which ignition occurs in a dust layer of specified thickness on a hot surface

NOTE The ignition temperature of a dust layer may be determined by the test method given in IEC 61241-2-1.

3.28 ignition temperature of a dust cloud lowest temperature of the hot inner wall of a furnace at which ignition occurs in a dust cloud in air contained therein

NOTE The ignition temperature of a dust cloud may be determined by the test method given in IEC 61241-2-1.

3.29 malfunction equipment or components which do not perform their intended function with respect to explosion protection

NOTE For the purposes of this standard this can happen due to a variety of reasons, including:

- failure of one (or more) of the component parts of the equipment or components;
- external disturbances (e.g. shocks, vibration, electromagnetic fields);
- design error or deficiency (e.g. software errors);
- disturbance of the power supply or other services;
- loss of control by the operator (especially for handheld equipment).

3.29.1 expected malfunction disturbances or equipment faults which normally occur in practice

3.29.2 rare malfunction type of malfunction, which is known to happen, but only in rare instances. Two independent foreseeable malfunctions which, separately, would not create a source of ignition, but which, in combination, do create a source of ignition, are regarded as a single rare malfunction

3.30 maximum surface temperature highest temperature which is attained in service under the most adverse conditions (but within the specified tolerances) by any part or surface of electrical equipment

NOTE 1 For electrical equipment in an explosive gas atmosphere, this temperature may occur on an internal component or on the external surface of the enclosure, depending upon the type of protection employed.

NOTE 2 For electrical equipment in an explosive dust atmosphere, this temperature occurs on the external surface of the enclosure and may include a defined dust layer condition.

3.31 normal operation operation of equipment conforming electrically and mechanically with its design specification and used within the limits specified by the manufacturer

NOTE 1 The limits specified by the manufacturer may include persistent operational conditions, e.g. operation of a motor on a duty cycle.

NOTE 2 Variation of the supply voltage within stated limits and any other operational tolerance is part of normal operation.

3.32 radio frequencies

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM*

Documents
Document Sharing Hub

3.32.1 **averaging time** time over which the threshold power is averaged

3.32.2 **continuous transmission** transmission where the duration of the pulse is greater than the half of the thermal initiation time

3.32.3 **pulsed transmission** transmission where the duration of the pulse is shorter than the half of the thermal initiation time, but the time between two consecutive pulses, however, is longer than three times the thermal initiation time

3.32.4 **thermal initiation time** time during which energy deposited by the spark accumulates in a small volume of gas around it without significant thermal dissipation

NOTE For times shorter than the thermal initiation time the total energy deposited by the spark will determine whether or not ignition occurs. For increasingly longer times, the power or rate at which energy is deposited becomes the determining factor for ignition.

3.32.5 **threshold energy** Z_{th} for a pulsed radio-frequency discharge, the maximum energy of the single pulse which can be extracted from the receiving body

3.32.6 **threshold power** P_{th} product of the effective output power of the transmitter multiplied by the antenna gain

3.33 **rated value** quantity value, assigned generally by the manufacturer, for a specified operating condition of a component, device or apparatus

3.34 **rating** set of rated values and operating conditions

3.35 **replaceable battery pack** assembly consisting of one or more interconnected cells, along with any integrated protective components, which form a complete replaceable battery

3.36 **service temperature** temperature reached when the equipment is operating at rated conditions

NOTE Each equipment may reach different service temperatures in different parts.

3.37 **symbol “U”** symbol used to denote an Ex component

NOTE The symbol “U” is used to identify that the equipment is incomplete and is not suitable for installation without further evaluation.

3.37DV.1 DR Delete Clause 3.37.

This clause does not apply.

3.38 **symbol “X”** symbol used to denote specific conditions of use

NOTE The symbol “X” is used to provide a means of identifying that essential information for the installation, use, and maintenance of the equipment is contained within the certificate.

3.38DV.1 DR Delete Clause 3.38.

This clause does not apply.

3.39 **termination compartment** separate compartment, or part of a main enclosure, communicating or not with the main enclosure, and containing connection facilities

3.40 **test, routine** test to which each individual device is subjected during or after manufacture to ascertain whether it complies with certain criteria

3.41 **test, type** test of one or more devices made to a certain design to show that the design meets certain specifications

3.42 **type of protection** specific measures applied to electrical equipment to avoid ignition of a surrounding explosive atmosphere

3.43 **working voltage** highest r.m.s. value of the a.c. or d.c. voltage across any particular insulation which can occur when the equipment is supplied at rated voltage

NOTE 1 Transients are disregarded.

NOTE 2 Both open-circuit conditions and normal operating conditions are taken into account.

4 Equipment grouping

Electrical equipment for explosive atmospheres is divided into the following groups:

4.1 Group I

Electrical equipment of Group I is intended for use in mines susceptible to firedamp.

NOTE The types of protection for Group I take into account the ignition of both firedamp and coal dust along with enhanced physical protection for equipment used underground.

Electrical equipment intended for mines where the atmosphere, in addition to firedamp, may contain significant proportions of other flammable gases (i.e. other than methane), shall be constructed and tested in accordance with the requirements relating to Group I and also to the subdivision of Group II corresponding to the other significant flammable gases. This electrical equipment shall then be marked appropriately (for example, "Ex d I/IIB T3" or "Ex d I/II (NH₃)").

4.1DV.1 DR Delete Clause 4.1.

This clause does not apply.

4.2 Group II

Electrical equipment of Group II is intended for use in places with an explosive gas atmosphere other than mines susceptible to firedamp.

Electrical equipment of Group II is subdivided according to the nature of the explosive gas atmosphere for which it is intended.

Group II subdivisions

- IIA, a typical gas is propane
- IIB, a typical gas is ethylene
- IIC, a typical gas is hydrogen

NOTE 1 This subdivision is based on the maximum experimental safe gap (MESG) or the minimum ignition current ratio (MIC ratio) of the explosive gas atmosphere in which the equipment may be installed. (See IEC 60079-12 and IEC 60079-20).

4.2DV.1 DR Modification of Clause 4.2 Note 1 as follows:

4.2DV.1.1 Replace “IEC 60079-12 and IEC 60079-20” with “IEC 60079-12, IEC 60079-20 and NFPA 497”.

NOTE 2 Equipment marked IIB is suitable for applications requiring Group IIA equipment. Similarly, equipment marked IIC is suitable for applications requiring Group IIA or Group IIB equipment.

4.3 Group III

Electrical equipment of Group III is intended for use in places with an explosive dust atmosphere other than mines susceptible to firedamp.

Electrical equipment of Group III is subdivided according to the nature of the explosive dust atmosphere for which it is intended.

Group III subdivisions:

- IIIA: combustible flyings
- IIIB: non-conductive dust
- IIIC: conductive dust

NOTE Equipment marked IIIB is suitable for applications requiring Group IIIA equipment. Similarly, equipment marked IIIC is suitable for applications requiring Group IIIA or Group IIIB equipment.

4.3DV.1 DR Modification of Clause 4.3 Note to replace with the following:

NOTE 1 Equipment marked IIIB is suitable for applications requiring Group IIIA equipment. Similarly, equipment marked IIIC is suitable for applications requiring Group IIIA or Group IIIB equipment.

NOTE 2 The 2008 NEC does not recognize the identification of locations or equipment as “Group IIIA, IIIB, or IIIC”, but identifies equipment suitable for Zone 20, 21, or 22 by the use of equipment marking where a “D” is appended to the type of protection, for example “iaD” and no separate differentiation is made of combustible dusts or ignitable fibers.

4.4 Equipment for a particular explosive atmosphere

The electrical equipment may be tested for a particular explosive atmosphere. In this case, the information shall be recorded on the certificate and the electrical equipment marked accordingly.

5 Temperatures

5.1 Environmental influences

5.1.1 Ambient temperature

Electrical equipment designed for use in a normal ambient temperature range of -20°C to $+40^{\circ}\text{C}$ does not require marking of the ambient temperature range. However, electrical equipment designed for use in other than this normal ambient temperature range is considered to be special. The marking shall then include either the symbol T_a or T_{amb} together with both the upper and lower ambient temperatures or, if this is impracticable, the symbol “X” shall be used to indicate specific conditions of use that include the upper and lower ambient temperatures. See item d) of 29.2 and Table 1.

5.1.1DV.1 DR Modification of Clause 5.1.1 to replace as follows:

5.1.1DV.1.1 Replace “in other than” with “outside” and delete “or, if this is impracticable, the symbol “X” shall be used to indicate specific conditions of use that include the upper and lower ambient temperatures.” and replace “See item d) of 29.2 and Table 1” with “ See Table 1”.

NOTE The ambient temperature range may be a reduced range, e.g. $-5^{\circ}\text{C} \leq T_{\text{amb}} \leq 15^{\circ}\text{C}$.

5.1.1DV.2 DR Modification of Clause 5.1.1 Note to replace with the following:

5.1.1DV.2.1 The ambient temperature range may be an expanded range, e.g. $-55^{\circ}\text{C} \leq T_{\text{amb}} \leq 150^{\circ}\text{C}$.

Table 1 – Ambient temperatures in service and additional marking

Electrical equipment	Ambient temperature in service	Additional marking
Normal	Maximum: +40 °C Minimum: -20 °C	None
Special	Specified by the manufacturer	T_a or T_{amb} with the special range, for example, $-30\text{ °C} \leq T_a \leq +40\text{ °C}$ or the symbol "X"

Table 1DV DR Modification of Table 1 as follows:

Delete "or the symbol "X" ".

5.1.2 External source of heating or cooling

Where the electrical equipment is intended to be physically connected to a separate external source of heating or cooling, such as a heated or cooled process vessel or pipeline, the ratings of the external source shall be specified in the manufacturer's instructions.

NOTE 1 The way in which these ratings are expressed will vary according to the nature of the source. For sources generally larger than the equipment, the maximum or minimum temperature will usually be sufficient. For sources generally smaller than the equipment, or for heat conduction through thermal insulation, the rate of heat flow may be appropriate.

NOTE 2 The influence of radiated heat may need to be considered on the final installation. See IEC 60079-14.

5.2 Service temperature

Where this standard, or the standard for the specific type of protection, requires the service temperature to be determined at any place in the equipment, the temperature shall be determined for the rating of the electrical equipment when the equipment is subjected to maximum or minimum ambient temperature and, where relevant, the maximum rated external source of heating or cooling. Service temperature testing, when required, shall be in accordance with 26.5.1.

NOTE The rating of the electrical equipment includes the ambient temperature, characteristics of the electrical supply and load, duty cycle or duty type, as assigned by the manufacturer.

5.3 Maximum surface temperature

5.3.1 Determination of maximum surface temperature

Maximum surface temperature shall be determined according to 26.5.1 or the specific requirement of the standard for the type of protection, and when the equipment is subjected to maximum ambient temperature and, where relevant, the maximum rated external source of heating.

5.3.2 Limitation of maximum surface temperature

5.3.2DV.1 DR Delete Clause 5.3.2.

This clause does not apply.

5.3.2.1 Group I electrical equipment

For electrical equipment of Group I, the maximum surface temperature shall be specified in relevant documentation according to Clause 24.

This maximum surface temperature shall not exceed

- 150 °C on any surface where coal dust can form a layer,
- 450 °C where coal dust is not likely to form a layer (i.e., inside of a dust-protected enclosure).

NOTE When choosing Group I electrical equipment, the user should take into account the influence and the smouldering temperature of coal dusts if they are likely to be deposited in a layer on surfaces with temperatures above 150 °C.

5.3.2.1DV.1 DR Delete Clause 5.3.2.1.

5.3.2.1DV.1.1 This clause does not apply.

5.3.2.2 Group II electrical equipment

The maximum surface temperature determined (see 26.5.1) shall not exceed:

- the temperature class assigned (see Table 2), or
- the maximum surface temperature assigned, or
- if appropriate, the ignition temperature of the specific gas for which it is intended.

Table 2 – Classification of maximum surface temperatures for Group II electrical equipment

Temperature class	Maximum surface temperature °C
T1	450
T2	300
T3	200
T4	135
T5	100
T6	85

NOTE More than one temperature class may be established for different ambient temperatures and different external sources of heating and cooling.

5.3.2.3 Group III electrical equipment

5.3.2.3.1 Maximum surface temperature determined without a dust layer

5.3.2.3.1DV.1 DR Modification of Clause 5.3.2.3.1 title as follows:

5.3.2.3.1DV.1.1 Delete “determined without a dust layer”.

The maximum surface temperature determined (see 26.5.1) shall not exceed:

- the maximum surface temperature assigned;
- the layer or cloud ignition temperature of the specific combustible dust for which it is intended.

5.3.2.3.2 Maximum surface temperature with respect to dust layers

In addition to the maximum surface temperature required in 5.3.2.3.1, the maximum surface temperature may also be determined for a given depth of layer, T_L , of dust surrounding all sides of the apparatus, unless otherwise specified in the documentation, and marked with the symbol “X” to indicate this specific condition of use in accordance with item d) of 29.4.

NOTE 1 A maximum depth of layer, T_L , may be specified by the manufacturer.

NOTE 2 Additional information on the application of equipment where dust layers up to 50 mm may accumulate on the equipment is given in IEC 61241-14.

5.3.2.3.2DV.1 DR Delete Clause 5.3.2.3.2.

This clause does not apply.

5.3.3 Small component temperature for Group I or Group II electrical equipment

The maximum surface temperature shall not exceed the temperature class unless subjected to the following.

Small components, for example transistors or resistors, whose temperature exceeds that permitted for the temperature classification, shall be acceptable providing that they conform to one of the following:

a) when tested in accordance with 26.5.3, small components shall not cause ignition of the flammable mixture and any deformation or deterioration caused by the higher temperature shall not impair the type of protection; or

b) for T4 and Group I classification, small components shall conform to Table 3a and Table 3b; or

5.3.3DV.1 DR Modification of Clause 5.3.3 item b) as follows:

5.3.3DV.1.1 Add “where no catalytic or other chemical reactions can result,” before “for T4” and delete “and Group I”.

c) for T5 classification, the surface temperature of a component with a surface area smaller than 1 000 mm² (excluding lead wires) shall not exceed 150 °C.

5.3.3DV.2 DR Modification of Clause 5.3.3 item c) as follows:

5.3.3DV.2.1 Add “where no catalytic or other chemical reactions can result,” before “for T5”.

Table 3a – Assessment of temperature classification according to component size at 40°C ambient temperature

Total surface area excluding lead wires	Group II T4		Group I	
			Dust excluded	
	Maximum surface temperature	Maximum power dissipation	Maximum surface temperature	Maximum power dissipation
	°C	W	°C	W
<20 mm ²	275		950	
≥20 mm ² ≤1 000 mm ²	200, or	1,3		3,3
>1 000 mm ²		1,3		3,3

Table 3b – Assessment of temperature classification according to component size – Variation in maximum power dissipation with ambient temperature

Maximum ambient temperature	°C	Apparatus group	40	50	60	70	80
Maximum power dissipation	W	Group II	1,3	1,25	1,2	1,1	1,0
		Group I	3,3	3,22	3,15	3,07	3,0

For potentiometers, the surface to be considered shall be that of the resistance element and not the external surface of the component. The mounting arrangement and the heat-sinking and cooling effect of the overall potentiometer construction shall be taken into consideration during the test. Temperature shall be measured on the track with that current which flows under the test conditions required by the standard for the specific type of protection. If this results in a resistance value of less than 10 % of the track resistance value, the measurements shall be carried out at 10 % of the track resistance value.

For surface areas of not more than 1 000 mm², the surface temperature may exceed that for the temperature class marked on the Group II electrical equipment or the corresponding maximum surface temperature for Group I electrical equipment, if there is no risk of ignition from these surfaces, with a safety margin of

5.3.3DV.3 DR Modification of Clause 5.3.3 fourth paragraph as follows:

5.3.3DV.3.1 Delete “or the corresponding maximum surface temperature for Group I electrical equipment”.

- 50 K for T1, T2 and T3,
- 25 K for T4, T5 and T6 and Group I.

5.3.3DV.4 DR Modification of Clause 5.3.3 second bullet item as follows:

5.3.3DV.4.1 Delete “and Group I”.

This safety margin shall be ensured by experience of similar components or by tests of the electrical equipment itself in representative explosive mixtures.

NOTE During the tests, the safety margin may be provided by increasing the ambient temperature.

6 Requirements for all electrical apparatus

6.1 General

Electrical equipment and Ex Components shall

a) comply with the requirements of this standard, together with one or more of the specific standards listed in Clause 1, and

NOTE 1 These specific standards may vary the requirements of this standard.

NOTE 2 All of the requirements for cable glands marked as type of protection “e” are located in IEC 60079-0.

6.1DV.1 DR Modification of Clause 6.1 NOTE 2 to replace with the following:

6.1DV.1.1 All of the requirements for cable glands or cord connectors marked as type of protection “e” are located in UL 2225.

b) be constructed in accordance with the applicable safety requirements of the relevant industrial standards.

6.1DV.2 DR Modification of Clause 6.1 item b) to replace with the following:

6.1DV.2.1 comply with the applicable requirements for similar apparatus for use in unclassified locations.

NOTE 3 It is not a requirement of this standard that a certification body check compliance with this requirement. The manufacturer should indicate compliance by marking the equipment or component in accordance with Clause 29 (and by stating the basis of compliance in the documentation, see Clause 28).

6.1DV.3 DR Modification of Clause 6.1 NOTE 3 as follows:

6.1DV.3.1 Add after the first sentence “Requirements for safety of electrical equipment in ordinary (unclassified) locations can be found in ANSI Standards, NEMA Standards, Federal Regulations, etc. Equipment listed by a Nationally Recognized Testing Laboratory is considered to meet the applicable requirements found in these standards. A list of commonly applied standards is shown in informative Annex D”.

NOTE 4 If the electrical equipment or Ex component is intended to withstand particularly adverse service conditions (for example, rough handling, humidity effects, ambient temperature variations, effects of chemical agents, corrosion), these should be specified to the manufacturer by the user. If certification is sought, it is not a requirement of this standard that the certification body confirm suitability for the adverse conditions. Special precautions should be taken when vibration effects on terminals, fuse holders, lampholders and current-carrying connections in general may impair safety, unless they comply with specific standards.

6.2 Mechanical strength of equipment

The equipment shall be subjected to the tests of 26.4. Guards relied upon to provide protection from impact shall be removable only by the use of a tool and shall remain in place for the required impact tests.