

Subject 635

August 8, 2006

SUMMARY OF TOPICS

The following changes in requirements are being proposed:

1. Editorial Revision of Paragraph 4.4

ALL COMMENTS DUE: September 7, 2006

For your convenience in review, proposed additions to existing requirements are shown underlined and proposed deletions are shown ~~lined-out~~.

1. Editorial Revision of Paragraph 4.4

RATIONALE

Proposal submitted by: Thomas Mayerhofer, UL.

After the renumbering of the paragraphs in UL 635 (which occurred when some of the requirements of UL 635 were revised on November 14, 2005) the reference to Paragraph 12.5(d) in Paragraph 4.4 became inaccurate.

PROPOSAL

4.4 A strain-relief bushing shall be constructed so that it performs its intended function without damage to the flexible cord or insulated wire. An anti-rotation feature shall be provided. See ~~12.3~~ 15.3(d).

Copyright © 2006 Underwriters Laboratories Inc.

**FOR INTERNAL UL OR CSDS USE ONLY –
NOT FOR OUTSIDE DISTRIBUTION**



Documents

Document Sharing Hub

No Text on This Page

Copyright © 2006 by the American Veterinary Medical Association

*FOR INTERNAL UL OR CSDS USE ONLY –
NOT FOR OUTSIDE DISTRIBUTION*



Documents

Document Sharing Hub