

Subject 705

August 17, 2018

SUMMARY OF TOPICS

The following topics for the Standard for Power Ventilators, UL 705, are being recirculated:

- 1. Addition of a new marking requiring a disconnect for each power supply ventilator employing more than one power source.**

BALLOTS AND COMMENTS DUE: September 17, 2018

For your convenience in review, proposed additions to the previously proposed requirements dated June 29, 2018 are shown underlined and proposed deletions are shown ~~lined-out~~.

- 1. Addition of a new marking requiring a disconnect for each power supply ventilator employing more than one power source.**

RATIONALE

Responses to comments have been posted within the UL 705 Proposal Review Work Area dated June 29, 2018.

PROPOSAL

36.21 A ventilator employing more than one power source shall be provided with a disconnect for each power supply and the following warning; "WARNING: RISK OF ELECTRIC SHOCK. CAN CAUSE INJURY OR DEATH: FOR UNITS SUPPLIED BY MULTIPLE SOURCES, DISCONNECT ALL REMOTE ELECTRIC POWER SUPPLIES BEFORE SERVICING", in letters not less than 3.2 mm (1/8 in) high, or the equivalent. This marking shall be located on all panels providing access to hazardous voltage uninsulated live parts.

Copyright © 2018 Underwriters Laboratories Inc.

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub