

Subject 842B

September 15, 2017

## **SUMMARY OF TOPICS**

*The following change in requirements to the Standard for Valves for Diesel Fuel, Biodiesel Fuel, Diesel/Biodiesel Blends with Nominal Biodiesel Concentrations up to 20 Percent (B20), Kerosene, and Fuel Oil, UL 842B, is being proposed:*

### **1. Clarification of valves subjected to the fire test**

**STP BALLOTS AND ALL COMMENTS DUE: October 16, 2017**

For your convenience in review, proposed additions to existing requirements are shown underlined.

### **1. Clarification of valves subjected to the fire test**

## **RATIONALE**

Proposal submitted by: Edgar Wolff-Klammer, Underwriters Laboratories, LLC

There has been confusion on which valves need to have a fire test. This proposal is to clarify which valve shall be subjected to the fire test.

## **PROPOSAL**

## **PERFORMANCE**

### **11 General**

11.9 A valve provided with a fusible element or other device that will close the valve automatically when subjected to heat or fire shall be subjected to the Fire Test.

Copyright © 2017 Underwriters Laboratories Inc.

No Text on This Page

**UL COPYRIGHTED MATERIAL –  
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR  
DISTRIBUTION WITHOUT PERMISSION FROM UL**



**Documents**

Document Sharing Hub