



UL 870

STANDARD FOR SAFETY

Wireways, Auxiliary Gutters, and Associated Fittings

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

UL Standard for Safety for Wireways, Auxiliary Gutters, and Associated Fittings, UL 870

Ninth Edition, Dated March 3, 2016

Summary of Topics

The ninth edition has been issued for UL 870 to update the Title Page to indicate the latest approval date as an American National Standard and to include the following proposal that was balloted January 22, 2016:

1. Protection from Sharp Edges.

The new and revised requirements are substantially in accordance with Proposal(s) on this subject dated January 22, 2016.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

No Text on This Page

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

MARCH 3, 2016

1



ANSI/UL 870-2016

UL 870

Standard for Wireways, Auxiliary Gutters, and Associated Fittings

First Edition – October, 1943

Second Edition – July, 1968

Third Edition – May, 1973

Fourth Edition – August, 1977

Fifth Edition – June, 1985

Six Edition – January, 1991

Seventh Edition – June, 1995

Eighth Edition – June, 2008

Ninth Edition

March 3, 2016

This ANSI/UL Standard for Safety consists of the Ninth Edition.

The most recent designation of ANSI/UL 870 as an American National Standard (ANSI) occurred on March 3, 2016. ANSI approval for a standard does not include the Cover Page, Transmittal Pages and Title Page.

The Department of Defense (DoD) has adopted UL 870 on April 14, 1987. The publication of revised pages or a new edition of this Standard will not invalidate the DoD adoption.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2016 UNDERWRITERS LABORATORIES INC.

No Text on This Page

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	4
2 Glossary	4
3 Units of Measurement	4
4 Undated References	5

CONSTRUCTION

5 General	5
6 Design	5
7 Conductor Size	7
8 Material	7
8.1 Metal wireways, auxiliary gutters, and associated fittings	7
8.2 Nonmetallic wireways, auxiliary gutters, and associated fittings	8
9 Thickness of Metal – Metal Wireways, Auxiliary Gutters, and Associated Fittings	8
10 Flanges and Reinforcing Strips – Metal Wireways, Auxiliary Gutters, and Associated Fittings	8
11 Openings in Enclosure – Metal Wireways, Auxiliary Gutters, and Associated Fittings	10
11.1 Connections for wiring systems	10
11.2 Other openings	10
12 Covers – Metal Wireways, Auxiliary Gutters, and Associated Fittings	10
13 Hinges and Latches – Metal Wireways, Auxiliary Gutters, and Associated Fittings	11
14 Expansion Joints and Telescoping Sections – Metal Wireways, Auxiliary Gutters, and Associated Fittings	12
15 Supports	13
15.1 General	13
15.2 Metal wireways	14
15.3 Nonmetallic wireways	14
16 Protection Against Corrosion – Metal Wireways, Auxiliary Gutters, and Associated Fittings	14
17 Raintight Wireways	16

PERFORMANCE

18 General	16
19 Electrical Continuity Test – Metal Wireways, Auxiliary Gutters, Covers, and Associated Fittings	17
20 Raintightness Test	17
20.1 General	17
20.2 Gaskets	20
21 Metallic Coating Thickness Test – Metal Wireways, Auxiliary Gutters, and Associated Fittings	20
22 Support Test	21
23 Ultraviolet Light Exposure – Nonmetallic Wireways, Auxiliary Gutters, and Associated Fittings	22

MARKING

24 General	22
25 Details	22

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents
Document Sharing Hub

INTRODUCTION

1 Scope

1.1 These requirements cover wireways, auxiliary gutters, and associated fittings to be employed in accordance with the National Electrical Code, NFPA 70.

1.2 These requirements do not cover rigid or flexible conduit, surface raceways, underfloor raceways, nor other products of a similar nature that are covered by individual requirements.

2 Glossary

2.1 For the purpose of this standard the following definitions apply.

2.2 ACCESSIBLE EDGES – Edges that are subject to contact by persons installing, using or maintaining the product.

2.3 ASSOCIATED FITTING – A part that is used in the assembly of a complete wireway system, such as an elbow, tee, cross, end closer, or hanger.

2.4 AUXILIARY GUTTER – A section of wireway used to supplement the wiring space at a distribution center, switchboard, or similar location in a wiring system.

2.5 WIREWAY, METAL – A sheet-metal trough with a hinged or removable cover for housing and protecting electric wires and cables and in which conductors are laid in place after the wireway system has been installed as a complete system.

2.6 WIREWAY, NONMETALLIC – A flame-retardant, nonmetallic trough with removable covers for housing and protecting electric wires and cables in which conductors are laid in place after the wireway has been installed as a complete system.

3 Units of Measurement

3.1 If a value for measurement is followed by a value in other units in parentheses, the first stated value is the requirement. The second value may be only approximate.

This document is only permissible for use by User of . 8/23/2016 1:20:08 PM

4 Undated References

4.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

CONSTRUCTION

5 General

5.1 Construction requirements identified for wireways, auxiliary gutters and associated fittings apply to both nonmetallic and metal devices, unless specifically noted.

5.2 Wireways, auxiliary gutters, and associated fittings shall employ materials that are acceptable for the particular use, and shall be made and finished with the degree of uniformity and grade of workmanship practicable in a well-equipped factory.

5.3 A wireway system shall include all wireways and fittings required to make a complete installation in accordance with the National Electrical Code, ANSI/NFPA 70.

5.4 Unless otherwise noted, auxiliary gutters and fittings shall comply with all of the requirements for wireways.

5.5 Nonmetallic wireways, auxiliary gutters and fittings shall additionally comply with construction requirements in the Standard for Nonmetallic Surface Raceways and Fittings, UL 5A.

5.6 Wireways, auxiliary gutters and fittings marked for use with an environmental rating, including enclosure types, shall comply with the applicable requirements specified in the Standard for Enclosures for Electrical Equipment, Environmental Considerations, UL 50E.

6 Design

6.1 A metal wireway shall be constructed, such that the interconnection of sections, covers, and fittings will provide a rigid mechanical assembly and provide electrical conductivity complying with the requirements for the Electrical Continuity Test – Metal Wireways, Auxiliary Gutters, Covers, and Associated Fittings, Section 19.

6.2 A wireway shall be formed and assembled so that it will have the strength and rigidity necessary to resist the abuses to which it is likely to be subjected, without resulting in a risk of fire, electric shock, or injury to persons due to total or partial collapse with resulting damage to conductors, loosening or displacement of parts, or other serious defects.

6.3 The wireway and associated fittings shall be free from burrs and sharp corners or edges that may abrade the insulation on conductors or otherwise damage wiring or constitute a risk of injury to persons. Screws and bolts, however used, shall not project into the wireway unless sharp ends and threaded sections are covered or otherwise prevented from coming in contact with wires.

Exception: A threaded section of a screw or bolt not having a sharp point need not be prevented from coming in contact with wires provided the screw or bolt does not project more than 1/32 in (0.8 mm) into the wireway.