

UL 916

ISBN 0-7629-0316-3

Energy Management Equipment

Underwriters Laboratories Inc. (UL)
333 Pfingsten Road
Northbrook, IL 60062-2096

UL Standard for Safety for Energy Management Equipment, UL 916

Third Edition, Dated December 23, 1998

Revisions: This Standard contains revisions through and including February 10, 2004.

Summary of Topics:

These revisions to UL 916 are being issued:

- 1. To incorporate a revised requirement for grounded conductors described in the Subject 916 bulletin dated September 30, 2003;***
- 2. To replace a reference to Standard UL 198G with Standards UL 248-1 and UL 248-14;***
- 3. To replace references to Standards UL 486A and UL 486B with Standard UL 486A-UL 486B: and***
- 4. To revise references to AWG wire sizes.***

Announcement Bulletin(s): This Standard contains the announcement bulletin(s) dated March 6, 1996. The announcement bulletin is located at the end of the Standard.

UL Standards for Safety are developed and maintained in the Standard Generalized Markup Language (SGML). SGML -- an international standard (ISO 8879-1986) -- is a descriptive markup language that describes a document's structure and purpose, rather than its physical appearance on a page. Due to formatting differences resulting from the use of UL's new electronic publishing system, please note that additional pages (on which no requirements have been changed) may be included in revision pages due to relocation of existing text and reformatting of the Standard.

Text that has been changed in any manner is marked with a vertical line in the margin. Changes in requirements are marked with a vertical line in the margin and are followed by an effective date note indicating the date of publication or the date on which the changed requirement becomes effective.

The new and revised requirements are substantially in accordance with UL's Bulletin(s) on this subject dated September 30, 2003. The bulletin(s) is now obsolete and may be discarded.

The revisions dated February 10, 2004 include a reprinted title page (page1) for this Standard.

The revisions dated February 10, 2004 were also issued to replace the reference to the Standard for Fuses for Supplementary Overcurrent Protection, UL 198G, in Appendix A with references to the Standard for Low Voltage Fuses – Part 1: General Requirements, UL 248-1 and the Standard for Low Voltage Fuses – Part 14: Supplemental Fuses, UL 248-14. In addition, the revisions dated February 10, 2004 were issued to replace references to the Standard for Wire Connectors and Soldering Lugs for Use with Copper Conductors, UL 486A, in Paragraph 13.1 and Appendix A and the Standard for Wire Connectors for Use with Aluminum Conductors – UL 486B, in Appendix A with the Standard for Wire Connectors, UL 486A-UL 486B. Revisions dated February 10, 2004 were also issued to delete "No." from references to AWG wire sizes located throughout the standard.

The master for this Standard at UL's Northbrook Office is the official document insofar as it relates to a UL service and the compliance of a product with respect to the requirements for that product and service, or if there are questions regarding the accuracy of this Standard.

UL's Standards for Safety are copyrighted by UL. Neither a printed copy of a Standard, nor the distribution diskette for a Standard-on-Diskette and the file for the Standard on the distribution diskette should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

Revisions of UL Standards for Safety are issued from time to time. A UL Standard for Safety is current only if it incorporates the most recently adopted revisions.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

UL will attempt to answer support requests concerning electronic versions of its Standards. However, this support service is offered on a reasonable efforts basis only, and UL may not be able to resolve every support request. UL supports the electronic versions of its Standards only if they are used under the conditions and operating systems for which it is intended. UL's support policies may change from time-to-time without notification.

UL reserves the right to change the format, presentation, file types and formats, delivery methods and formats, and the like of both its printed and electronic Standards without prior notice.

Purchasers of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgement (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

If a single-user version electronic Standard was purchased, one copy of this Standard may be stored on the hard disk of a single personal computer, or on a single LAN file-server or the permanent storage device of a multiple-user computer in such a manner that this Standard may only be accessed by one user at a time and for which there is no possibility of multiple concurrent access.

If a multiple-user version electronic Standard was purchased, one copy of the Standard may be stored on a single LAN file-server, or on the permanent storage device of a multiple-user computer, or on an Intranet server. The number of concurrent users shall not exceed the number of users authorized.

Electronic Standards are intended for on-line use, such as for viewing the requirements of a Standard, conducting a word search, and the like. Only one copy of the Standard may be printed from each single-user version of an electronic Standard. Only one copy of the Standard may be printed for each

authorized user of a multiple-user version of an electronic Standard. Because of differences in the computer/software/printer setup used by UL and those of electronic Standards purchasers, the printed copy obtained by a purchaser may not look exactly like the on-line screen view or the printed Standard.

An employee of an organization purchasing a UL Standard can make a copy of the page or pages being viewed for their own fair and/or practical internal use.

The requirements in this Standard are now in effect, except for those paragraphs, sections, tables, figures, and/or other elements of the Standard having future effective dates as indicated in the note following the affected item. The prior text for requirements that have been revised and that have a future effective date are located after the Standard, and are preceded by a "SUPERSEDED REQUIREMENTS" notice.

New product submittals made prior to a specified future effective date will be judged under all of the requirements in this Standard including those requirements with a specified future effective date, unless the applicant specifically requests that the product be judged under the current requirements. However, if the applicant elects this option, it should be noted that compliance with all the requirements in this Standard will be required as a condition of continued Listing and Follow-Up Services after the effective date, and understanding of this should be signified in writing.

Copyright © 2004 Underwriters Laboratories Inc.

This Standard consists of pages dated as shown in the following checklist:

Page	Date
1	February 10, 2004
2-3	November 5, 2001
4	April 3, 2002
4A-4B	February 10, 2004
5	November 5, 2001
6	February 10, 2004
7	April 3, 2002
8-8B	November 5, 2001
9-11	December 23, 1998
12-13	November 5, 2001
14-18	December 23, 1998
19-21	November 5, 2001
22-22B	February 10, 2004
23-24	November 5, 2001
25	December 23, 1998
26-30B	November 5, 2001
31-34	December 23, 1998
35-36B	February 10, 2004
37-39	December 23, 1998
40	February 10, 2004
41	December 23, 1998
42-44B	November 5, 2001
45-46B	February 10, 2004
47-51	December 23, 1998
52	February 10, 2004
53	December 23, 1998
54	November 5, 2001
55-64	December 23, 1998
65-66B	April 3, 2002
67-75	December 23, 1998
76-77	February 10, 2004
78-79	December 23, 1998
80	November 5, 2001
81-99	December 23, 1998
100-100B	February 10, 2004
101-106	December 23, 1998
107-108	November 5, 2001
109-118	December 23, 1998
119-120B	February 10, 2004
121	December 23, 1998
122	April 3, 2002
122A-124	February 10, 2004
125-128	December 23, 1998
129	November 5, 2001
130-131	December 23, 1998
132	February 10, 2004
133	April 3, 2002
134	November 5, 2001
135-136	December 23, 1998

A1	February 10, 2004
A2	November 5, 2001
CRG1-CRG4.....	November 5, 2001

No Text on This Page

DECEMBER 23, 1998

(Title Page Reprinted: February 10, 2004)

1

UL 916

Standard for Energy Management Equipment

First Edition – August, 1984

Second Edition – April, 1994

Third Edition

December 23, 1998

An effective date included as a note immediately following certain requirements is one established by Underwriters Laboratories Inc.

Revisions of this Standard will be made by issuing revised or additional pages bearing their date of issue. A UL Standard is current only if it incorporates the most recently adopted revisions, all of which are itemized on the transmittal notice that accompanies the latest set of revised requirements.

ISBN 0-7629-0316-3

COPYRIGHT © 1984, 2004 UNDERWRITERS LABORATORIES INC.

No Text on This Page

CONTENTS

FOREWORD	6
----------------	---

INTRODUCTION

1 Scope	7
2 General	7
2.1 Components	7
2.2 Units of measurement	8
2.3 Undated references	8
3 Glossary	8

CONSTRUCTION

4 General	10
5 Frame and Enclosure	10
5.1 General	10
5.2 Covers	11
5.3 Transformers	13
5.4 Cast metal	14
5.5 Sheet metal	14
5.6 Nonmetallic	16
5.7 Windows	18
5.8 Raintight and rainproof enclosures	18
6 Openings in Enclosures	19
6.1 Ventilating openings	19
6.2 Other openings	20
6.3 Screens and expanded metal	22
6.4 Wire openings	22
7 Mounting	24
8 Mechanical Assembly	24
9 Operating Mechanism	25
10 Accessibility of Uninsulated Live Parts, Film-Coated Wire, and Moving Parts	25
11 Protection Against Corrosion	30
12 Insulating Materials	33
13 Field Connections	33
13.1 General	33
13.2 Equipment permanently connected electrically	34
13.3 Terminals	36
13.4 Outlet-box-mounted devices	37
13.5 Portable equipment	37
13.6 Stationary equipment	37
13.7 Polarity	38
13.8 Strain relief	38
13.9 Bushings	38
14 Current-Carrying Parts	39
15 Switches	39
16 Internal Wiring	39
16.1 General	39
16.2 Interconnecting cords and cables	43
16.3 Interconnection of units	44

17	Grounding	44
17.1	General	44
17.2	Grounding means	44A
17.3	Terminals and leads	45
18	Bonding of Internal Parts	46
18.1	General	46
18.2	Construction and connection	47
19	Motors	49
20	Printed Wiring Boards	50
21	Transformers	50
22	Capacitors	50
22.1	General	50
22.2	Signal coupling capacitors	51
23	Fuseholders	51
24	Overcurrent Protection, Control-Circuit Conductors	51
25	Overload Relays, Thermal Protectors for Motors, and Impedance-Protected Motors	53
26	Coil Windings	53
27	Spacings	53
27.1	General	53
27.2	Line-voltage circuits	55
27.3	Magnet-coil windings	56
27.4	Low-voltage class 2 circuits	57
27.5	Isolated limited secondary circuits (100-volt-amperes or less)	57
27.6	Controlled environment circuits	58
28	Clearances and Creepage Distances	61
29	Controlled-Environment Secondary Circuits	62
30	Wiring Space	63
31	Separation of Circuits	65
32	Isolation Devices	66A
33	Connections to Separate Equipment	67
33.1	General	67
33.2	Fuel-control circuit	67
33.3	Circulator or auxiliary-control circuit	67
34	Interconnection of Class 2 Circuits	68
35	Barriers	68

PROTECTION AGAINST INJURY TO PERSONS

36	General	68
36.1	Scope	68
36.2	Sharp corners and edges	69
36.3	Moving parts	69
36.4	Enclosures and guards	69
36.5	Surface temperatures	70
36.6	Mounting devices	70
36.7	Strength of parts	70
37	Protection of Users and Service Personnel	71
37.1	General	71
37.2	Mechanical servicing	73
37.3	Electrical servicing	73

PERFORMANCE

38	General	75
39	Power Input Test	75
40	Temperature Test	75
41	Overvoltage and Undervoltage Tests	81
42	Leakage Current Test	81
43	Leakage Current Test Following Humidity Conditioning	83
44	Normal Operation Test	85
45	Abnormal Operation Test	85
45.1	General	85
45.2	Rectifier – capacitor combinations	85
45.3	Feedback sensing devices	86
45.4	Isolation devices	86
46	Component Breakdown Test	86
46.1	Effects on equipment	86
46.2	Effects on controlled load	87
47	Overload Test	87
47.1	General	87
47.2	Tungsten-filament-lamp load characteristics	92
48	Endurance Test	93
49	Dielectric Voltage-Withstand Test	95
49.1	General	95
49.2	Secondary circuits (controlled environment)	97
49.3	Power transformers	97
49.4	Induced potential (crossover lead)	97
49.5	Induced potential repeated	98
49.6	Dead-case-mounted semiconductors	98
50	Volt-Ampere Capacity	98
51	Burnout Test	99
52	Limited Short-Circuit Test	99
52.1	General	99
52.2	Test circuit	100A
53	Conductor Short-Circuit Test	101
54	Strain Relief and Flexing Test	102
54.1	Strain relief	102
54.2	Flexing	102
55	Accelerated Aging Tests	102
55.1	General	102
55.2	Gaskets	102
55.3	Sealing compound	103
55.4	Adhesives	104
56	Metallic Coating Thickness Test	104
57	Rain Test	106
58	Conduit Entries Strength Test	109
58.1	Polymeric enclosures	109
58.2	Metallic enclosures	110
59	Cover Retention Test	110
60	Bonding Conductor Tests	111
60.1	Overload withstand test	111
60.2	Resistance test	111
61	Glass Window Impact Test	111
62	Permanence of Marking	112

63 Component Evaluation	113
64 Isolating Resistor Evaluation	113

MANUFACTURING AND PRODUCTION TESTS

65 Electronic Controls Requiring a Critical Component Evaluation	114
66 Production-Line Dielectric Voltage-Withstand Test	114
66.1 General	114
66.2 Dead-case-mounted semiconductors	115
67 Production-Line Grounding-Continuity Test	115

RATINGS

68 Details	116
------------------	-----

MARKINGS

69 General	117
70 Wiring	119
71 Elevated Air Temperature	122A
72 Cautionary Markings	122A
73 Instructions	123

ACCESSORY EQUIPMENT

74 General	123
75 Construction	125
76 Performance	125
77 Markings	125

POLYMERIC MATERIALS

78 General	126
79 Flammability of Enclosure – 5-Inch Flame	127
80 Thermal Aging	130
81 Exposure to Ultraviolet Light Test	130
82 Water Exposure and Immersion Test	131
83 Volume Resistivity Test	131
84 Resistance to Hot-Wire Ignition Test	132
85 Heat-Deflection Temperature Test	132
86 Resistance to Impact Test	132
87 Resistance to Crushing Test	133
88 Mold-Stress Evaluation	133
89 Dielectric Strength Test	134
90 Knockout Test	134
91 Abnormal Operation Test	134
92 Resistance to Ignition Test	135
93 Creep and Overcurrent Test	135

APPENDIX A

Standards for Components.....	A1
-------------------------------	----

CANADIAN REQUIREMENTS COMPARISON GUIDE CRG 916

UL AND CANADIAN STANDARDS FOR ENERGY MANAGEMENT EQUIPMENT CRG1

FOREWORD

A. This Standard contains basic requirements for products covered by Underwriters Laboratories Inc. (UL) under its Follow-Up Service for this category within the limitations given below and in the Scope section of this Standard. These requirements are based upon sound engineering principles, research, records of tests and field experience, and an appreciation of the problems of manufacture, installation, and use derived from consultation with and information obtained from manufacturers, users, inspection authorities, and others having specialized experience. They are subject to revision as further experience and investigation may show is necessary or desirable.

B. The observance of the requirements of this Standard by a manufacturer is one of the conditions of the continued coverage of the manufacturer's product.

C. A product which complies with the text of this Standard will not necessarily be judged to comply with the Standard if, when examined and tested, it is found to have other features which impair the level of safety contemplated by these requirements.

D. A product employing materials or having forms of construction which conflict with specific requirements of the Standard cannot be judged to comply with the Standard. A product employing materials or having forms of construction not addressed by this Standard may be examined and tested according to the intent of the requirements and, if found to meet the intent of this Standard, may be judged to comply with the Standard.

E. UL, in performing its functions in accordance with its objectives, does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of UL represent its professional judgment given with due consideration to the necessary limitations of practical operation and state of the art at the time the Standard is processed. UL shall not be responsible to anyone for the use of or reliance upon this Standard by anyone. UL shall not incur any obligation or liability for damages, including consequential damages, arising out of or in connection with the use, interpretation of, or reliance upon this Standard.

F. Many tests required by the Standards of UL are inherently hazardous and adequate safeguards for personnel and property shall be employed in conducting such tests.

INTRODUCTION

1 Scope

1.1 These requirements cover energy management equipment and associated sensing devices rated 600 volts or less and intended for installation in accordance with the National Electrical Code, NFPA 70.

1.2 This equipment energizes or de-energizes electrical loads to achieve a desired use of electrical power. The equipment is intended to control electrical loads by responding to sensors or transducers monitoring power consumption, by sequencing, by cycling the loads through the use of preprogrammed data logic circuits, or any combination thereof. Devices responding to signals from a utility company may receive the signals over the power lines or as radio signals.

1.3 These requirements also cover equipment intended for connection only to a low-voltage circuit of limited power supplied by a Class 2 transformer.

1.4 These requirements do not cover switching devices operated by a mechanical or electromechanical clock mechanism to energize or de-energize loads. These requirements do cover electronic clock operated energy management equipment.

1.5 *Deleted November 5, 2001*

2 General

2.1 Components

2.1.1 Except as indicated in 2.1.2, a component of a product covered by this standard shall comply with the requirements for that component. See Appendix A for a list of standards covering components used in the products covered by this standard.

2.1.1 revised April 3, 2002

2.1.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

2.1.2 revised November 5, 2001

2.1.3 A component shall be used in accordance with its rating established for the intended conditions of use.

2.1.3 revised November 5, 2001

2.1.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

2.1.4 revised November 5, 2001

2.2 Units of measurement

2.2.1 When a value for measurement is followed by a value in other units in parentheses, the first stated value is the requirement.

2.2.2 Unless otherwise indicated, all voltage and current values mentioned in this standard are root-mean-square (rms).

2.3 Undated references

2.3.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3 Glossary

3.1 For the purpose of this standard the following definitions apply.

3.2 CLASS 2 SYSTEM – A circuit, transformer, or power source having energy- and voltage-limiting characteristics as described in the National Electrical Code, ANSI/NFPA 70.

3.3 CONTROLLED ENVIRONMENT – An environment relatively free of contaminants. A controlled environment may also be provided by means of a totally closed, gasketed enclosure or the equivalent.

3.4 DEAD-CASE-MOUNTED SEMICONDUCTOR – A semiconductor, such as a triac or silicon-controlled rectifier, employing an integral metal tab or stud that is insulated from live parts.

3.5 FIELD-WIRING TERMINAL – A wiring terminal on permanently-connected equipment to which supply connections are made when the equipment is installed in the field.

3.6 ISOLATED LIMITED-ENERGY LOW-VOLTAGE CIRCUIT – A circuit (also hereafter referred to as a low-voltage circuit) involving a potential of not more than 42.4 volts peak supplied by one of the following:

- a) An energy-limiting Class 2 transformer;
- b) A non-energy-limiting Class 2 transformer and an overcurrent protective device. The protective device is:
 - 1) Not to be of the automatic reclosing type;
 - 2) To be trip-free from the reclosing mechanism; and
 - 3) Not to be readily interchangeable with a device of a different rating;
- c) A combination of an isolated transformer secondary winding and a fixed impedance that complies with all the performance requirements for an energy-limiting Class 2 transformer or power source;
- d) A dry-cell battery having output characteristics not greater than those of an energy-limiting Class 2 transformer or power source; or

- e) A combination of a rechargeable battery and a fixed impedance that complies with all of the performance requirements for an energy-limiting Class 2 transformer or power source.

No Text on This Page

3.7 ISOLATED LIMITED-ENERGY SECONDARY CIRCUIT – A circuit derived from an isolated secondary winding of a transformer having a maximum capacity of 100 volt-amperes and an open-circuit secondary-voltage rating not exceeding 1000 volts.

3.8 ISOLATION – Electrical separation between two locations.

3.9 JUNCTION TEMPERATURE – A theoretical temperature based on a simplified representation of the thermal and electrical behavior of a semiconductor device.

3.10 MAXIMUM CASE TEMPERATURE – A specification, usually in the form of a curve of on-state current versus maximum case temperature, that refers to the maximum case temperature of a thyristor with regard to the on-state current. The case is an external point on the thyristor where this temperature is related to the maximum junction temperature for the thyristor.

3.11 NONISOLATED LIMITED-ENERGY LOW-VOLTAGE CIRCUIT (POWER SOURCE) – A circuit derived from a source of supply classified as line-voltage by connecting impedance in series with the supply circuit as a means of limiting the voltage and power to comply with Class 2 characteristics.

3.12 OPPOSITE POLARITY – A difference of potential between two points, where shorting of these two points would result in a condition involving overload, rupturing of printed wiring board tracks, components or fuses, and the like.

3.13 OPTICAL ISOLATOR – A photon-coupled device consisting of a light source and sensor integrated into a single package that provides circuit isolation.

3.14 PILOT DUTY RATING – A rating applied to electromagnetic loads.

3.15 PORTABLE EQUIPMENT – Cord- and plug-connected equipment that is capable of being carried or moved about.

3.16 PRIMARY CIRCUIT – The wiring and components that are conductively connected to the supply circuit.

3.17 PULSE TRANSFORMER – A transformer intended to pass pulse waveforms as distinguished from sine waves.

3.18 SAFETY CIRCUIT – A primary or secondary circuit that contains a control relied upon to reduce the risk of fire, electric shock, or injury to persons at the controlled equipment.

3.19 SAFETY CONTROL – An automatic control and interlock (including relays, switches, and other auxiliary equipment used to form a system) which is intended to reduce the risk of fire, electric shock, or injury to persons.

3.20 SECONDARY CIRCUIT – A circuit supplied from a secondary winding of an isolating transformer.

3.21 STATIONARY EQUIPMENT – Cord- and plug-connected equipment that is intended to be fastened in place, or located in a dedicated space.

3.22 USER SERVICING – Any form of servicing that can be performed by personnel other than those who are trained to maintain the particular equipment is considered user servicing. Some examples of user servicing are:

- a) The attachment of accessories by means of attachment plugs and receptacles or by means of other separable connectors.

- b) The changing of tapes and the like that do not involve complicated operations.
- c) The replacement of recording tapes, disks, program boards, punched cards, or paper forms. Replacement of lamps and fuses and resetting of circuit breakers located in an operator-access area unless the lamps, fuses, or circuit breakers are marked to indicate replacement or resetting only by qualified service personnel.
- d) The making of routine operating adjustments necessary to adapt the unit for its different intended functions.
- e) Routine cleaning of data-handling media.

CONSTRUCTION

4 General

4.1 An electronic or solid-state circuit used in a back-up, limiting, or other safety control, including controls that require a calibration test, is evaluated on the basis of its compliance with the requirements in this standard. Electronic components shall comply with the requirements for the application.

4.2 A circuit extending from the equipment and intended for connection to a low-voltage Class 2 circuit as defined in the National Electrical Code, ANSI/NFPA 70, shall not involve a potential of more than 30 volts rms (42.4 volts peak) and be supplied by:

- a) A primary battery;
- b) A standard Class 2 transformer; or
- c) A combination of a transformer and a fixed impedance that, as a unit, complies with all the performance requirements for a Class 2 transformer.

4.3 A circuit derived from a line-voltage circuit by connecting resistance in series with the supply circuit as a means of limiting the voltage and current is considered to be a low-voltage circuit when the impedance has been investigated for such use. See Isolating Resistor Evaluation, Section 64.

4.4 The equipment shall use materials that comply with the requirements for the application and shall be made and finished with the degree of uniformity and grade of workmanship practicable in a well-equipped factory.

5 Frame and Enclosure

5.1 General

5.1.1 Equipment shall be formed and assembled so that it will have the strength and rigidity necessary to resist the abuses to which it may be subjected, without increasing the risk of fire, electric shock, or injury to persons due to total or partial collapse resulting in a reduction of spacings, loosening or displacement of parts, or other serious defects.

5.1.2 Equipment that complies with the requirements in 5.1.3 – 5.8.6 is considered to comply with 5.1.1.

5.1.3 Electrical parts of the equipment, other than a supply cord or low-voltage terminals, shall be located or enclosed so that the risk of unintentional contact with uninsulated live parts will be reduced.

Exception: An enclosure is not required for equipment intended for field installation within the enclosure of another product provided that:

a) All required markings are provided as specified in Sections 69 – 72 and

b) The temperature, overvoltage and undervoltage tests are conducted with the equipment in a $40 \pm 2^\circ\text{C}$ ($104 \pm 3.6^\circ\text{F}$) ambient. See Barriers, Section 35, and the Overvoltage and Undervoltage Tests, Section 41.

5.1.4 Equipment incorporating an air-filtering system or utilizing a tight-fitting enclosure may be subject to an investigation to determine whether it provides the equivalent of a controlled environment.

Exception: A gasketed enclosure is considered to provide an enclosed environment.

5.1.5 An air filter acting as an enclosure part shall comply with the requirements for Class 1 filters as specified in the Standard for Test Performance of Air Filter Units, UL 900. If abnormal tests show that an equivalent flame barrier exists, then an air filter is not considered to be an enclosure part and may be omitted.

5.2 Covers

5.2.1 An enclosure and a part of an enclosure such as a door or cover shall be provided with means for firmly securing it in place.

5.2.2 Sheet-metal screws threading directly into metal shall not be used to attach a cover, door, or other part that is removed to install field wiring or for operation of the equipment. Machine screws and self-tapping machine screws may thread directly into sheet-metal walls. See 16.1.19.

5.2.3 Sheet-metal screws mounting internal components that are not removed for installation or operation may thread directly into metal.

5.2.4 An enclosure cover shall be hinged if it gives access to a fuse or other overcurrent device, the functioning of which requires renewal, or if it is necessary to open the cover in connection with normal operation of the device.

Exception: A hinged cover is not required if the only overload-protective devices enclosed are:

a) Supplementary fuses in control circuits, provided the devices and circuit loads are within the same enclosure;

b) Supplementary overcurrent devices rated 2 amperes or less for loads not exceeding 100 volt-amperes;

c) Extractor fuses having an integral enclosure; or

d) Overcurrent devices connected in a low-voltage circuit. See 3.6.

5.2.5 A door or cover giving access to a fuse or thermal cutout in other than a low-voltage circuit shall:

- a) Shut closely against a 1/4 inch (6.4 mm) rabbet or the equivalent,
- b) Have turned flanges for the full length of four edges, or
- c) Have angle strips fastened to it.


Flanges or angle strips shall fit closely with the outside of the walls of the box proper and shall overlap the edges of the box not less than 1/2 inch (12.7 mm). A construction determined to provide equivalent protection or a combination of flange and rabbet may be used. See Figures 5.1 and 5.2.

5.2.6 A strip used to provide a rabbet and an angle strip fastened to the edges of a door shall be secured at not less than two points, not more than 1-1/2 inches (38.1 mm) from each end of each strip and at points between these end fastenings not more than 6 inches (152 mm) apart.

5.2.7 If a cover is required by 5.2.4 to be hinged, then the cover shall not depend solely upon screws or other similar means requiring the use of a tool to hold it closed, but shall be provided with a spring latch or catch, or a hand operable captive fastener.


5.2.8 A snap-on cover that gives access to bare live parts or film-coated wire and that does not require a tool for removal shall have no apparent means of removal, such as an extending tab, and shall withstand the Cover Retention Test, Section 59.

Figure 5.1
Rabbet



SA0702A

5.2.9 The continuity of a bonding means for a fastener-attached cover shall comply with the requirements in Figure 5.2.



requirements in Bonding of Internal Parts, Section 18.

5.3 Transformers

5.3.1 A transformer shall be housed within its own enclosure or within the main enclosure of the equipment, or within a combination of the two.

5.3.2 A sheet-steel transformer enclosure shall have a thickness of at least 0.026 inch (0.66 mm) if uncoated and at least 0.029 inch (0.74 mm) if galvanized.

Exception: Sheet steel having a thickness of at least 0.020 inch (0.51 mm) if uncoated and at least 0.023 inch (0.58 mm) if galvanized may be used for a drawn end bell having maximum dimensions of 2-1/4 inches (57.2 mm) on the flat portion and 1-1/2 inches (38.1 mm) at the base of the drawn portion.

5.3.3 A cast-metal transformer enclosure shall comply with the requirements in 5.4.1. A transformer enclosure of other material shall have the necessary strength and rigidity and otherwise comply with the requirements for the application.

5.4 Cast metal

5.4.1 A cast-metal enclosure shall be at least 1/8 inch (3.2 mm) thick at every point, more than 1/8 inch thick at reinforcing ribs and door edges, and at least 1/4 inch (6.4 mm) thick at tapped holes for conduit.

Exception: Other than at plain or threaded conduit holes, die-cast metal shall be minimum:

- a) 3/32 inch (2.4 mm) thick for an area greater than 24 square inches (154.8 cm²) or having any dimension more than 6 inches (152 mm).*
- b) 1/16 inch (1.6 mm) thick for an area of 24 square inches or less and having no dimension more than 6 inches. The area limitation may be obtained by the provision of reinforcing ribs subdividing a larger area.*
- c) 0.035 inch (0.89 mm) thick if the enclosure will not be used as a splice box and if the voltage rating of the complete device is such that the voltage between any two conductors is 250 volts or less and is limited to direct current or single-phase alternating current.*
- d) 0.028 inch (0.71 mm) thick if the enclosure houses only low-voltage circuits.*

5.5 Sheet metal

5.5.1 Other than at points where a wiring system is to be connected, the thickness of a sheet-metal enclosure shall not be less than that specified in Tables 5.1 and 5.2.

5.5.2 At points at which a wiring system is to be connected, uncoated steel shall be at least 0.032 inch (0.81 mm) thick, zinc-coated steel shall be at least 0.034 inch (0.86 mm) thick, and nonferrous metal shall be at least 0.045 inch (1.14 mm) thick.

5.5.3 Tables 5.1 and 5.2 are based on a uniform deflection of the enclosure surface for any given load concentrated at the center of the surface regardless of metal thickness.

5.5.4 With reference to Tables 5.1 and 5.2, a supporting frame is a structure of angle or channel, or a folded rigid section of sheet metal, that is rigidly attached and has essentially the same outside dimensions as the enclosure surface and sufficient torsional rigidity to resist the bending moments that may be applied via the enclosure surface when it is deflected. Equivalent reinforcing may be accomplished by constructions that will produce a structure that is as rigid as one built with a frame of angles or channels. Constructions considered to be without supporting frame include:

- a) A single sheet with single formed flanges (formed edges);
- b) A single sheet that is corrugated or ribbed;
- c) An enclosure surface loosely attached to a frame – for example, with spring clips; and
- d) An enclosure surface having an unsupported edge.

Table 5.1
Minimum thickness of sheet metal for electrical enclosures – carbon steel or stainless steel

Without supporting frame ^a		With supporting frame or equivalent reinforcing ^a		Minimum thickness uncoated, inch (mm)	Minimum thickness metal coated, inch (mm)
Maximum width, ^b inches (cm)	Maximum length, ^c inches (cm)	Maximum width, ^b inches (cm)	Maximum length, ^c inches (cm)		
4.0	10.2	Not limited	6.25	15.9	Not limited
4.75	12.1	5.75	6.75	17.1	8.25
6.0	15.2	Not limited	9.5	24.1	Not limited
7.0	17.8	8.75	10.0	25.4	12.5
8.0	20.3	Not limited	12.0	30.5	Not limited
9.0	22.9	11.5	13.0	33.0	16.0
12.5	31.8	Not limited	19.5	49.5	Not limited
14.0	35.6	18.0	21.0	53.3	25.0
18.0	45.7	Not limited	27.0	68.6	Not limited
20.0	50.8	25.0	29.0	73.7	36.0
22.0	55.9	Not limited	33.0	83.8	Not limited
25.0	63.5	31.0	35.0	88.9	43.0
25.0	63.5	Not limited	39.0	99.1	Not limited
29.0	73.7	36.0	41.0	104.1	51.0
33.0	83.8	Not limited	51.0	129.5	Not limited
38.0	96.5	47.0	54.0	137.2	66.0
42.0	106.7	Not limited	64.0	162.6	Not limited
47.0	119.4	59.0	68.0	172.7	84.0
52.0	132.1	Not limited	80.0	203.2	Not limited
60.0	152.4	74.0	84.0	213.4	103.0
63.0	160.0	Not limited	97.0	246.4	Not limited
73.0	185.4	90.0	103.0	261.6	127.0

^a See 5.5.4 for description of supporting frame and method for accomplishing equivalent reinforcing.

^b The width is the smaller dimension of a rectangular piece of sheet metal that is part of an enclosure. Adjacent surfaces of an enclosure may have common supports and be made of a single sheet.

^c Not limited applies only if the edge of the surface is flanged at least 1/2 inch (12.7 mm) or fastened to adjacent surfaces not normally removed in use.

^d Sheet steel for an enclosure intended for outdoor use – raintight or rainproof – shall not be less than 0.034 inch (0.86 mm) thick if zinc coated and not less 0.032 inch (0.81 mm) thick if uncoated.

Table 5.2
Minimum thickness of sheet metal for enclosures – aluminum, copper, or brass

Without supporting frame ^a		With supporting frame or equivalent reinforcing ^a		Minimum thickness, inch (mm)	
Maximum width, ^b inches (cm)	Maximum length, ^c inches (cm)	Maximum width, ^b inches (cm)	Maximum length, ^b inches (cm)		
3.0	7.6	Not limited	7.0	17.8	0.023 ^d 0.58
3.5	8.9	4.0	8.5	21.6	
4.0	10.2	Not limited	10.0	25.4	0.029 0.74
5.0	12.7	6.0	10.5	26.7	
6.0	15.2	Not limited	14.0	35.6	0.036 0.91
6.5	16.5	8.0	15.0	38.1	
8.0	20.3	Not limited	19.0	48.3	0.045 1.14
9.5	24.1	11.5	21.0	53.3	
12.0	30.5	Not limited	28.0	71.1	0.058 1.47
14.0	35.6	16.0	30.0	76.2	
18.0	45.7	Not limited	42.0	106.7	0.075 1.91
20.0	50.8	25.0	45.0	114.3	
25.0	63.5	Not limited	60.0	152.4	0.095 2.41
29.0	73.7	36.0	64.0	162.6	
37.0	94.0	Not limited	87.0	221.0	0.122 3.10
42.0	106.7	53.0	93.0	236.2	
52.0	132.1	Not limited	123.0	312.4	0.153 3.89
60.0	152.4	74.0	130.0	330.2	

^a See 5.5.4 for description of supporting frame and method for accomplishing equivalent reinforcing.

^b The width is the smaller dimension of a rectangular piece of sheet metal that is part of an enclosure. Adjacent surfaces of an enclosure may have common supports and be made of a single sheet.

^c Not limited applies only if the edge of the surface is flanged at least 1/2 inch (12.7 mm) or fastened to adjacent surfaces not normally removed in use.

^d Sheet copper, brass, or aluminum for an enclosure intended for outdoor use – raintight or rainproof – shall not be less than 0.029 inch (0.74 mm) thick.

5.6 Nonmetallic

5.6.1 The requirements in 5.6.2 – 5.6.8 apply to polymeric enclosures.

5.6.2 A nonmetallic enclosure or enclosure part shall have mechanical strength and durability and be formed so that operating parts will be protected against damage and shall resist the abuses likely to be encountered during installation and normal use and service.

5.6.3 An enclosure or enclosure part shall protect persons against a risk of electric shock, and the material shall not create or contribute to a risk of fire, electric shock, or injury to persons.

5.6.4 Among the factors that are to be taken into consideration when judging a nonmetallic enclosure are:

- a) Mechanical strength;
- b) Resistance to impact;
- c) Moisture absorption;
- d) Resistance to combustion and to ignition from electrical sources;
- e) Dielectric properties, insulation resistance, and resistance to arc tracking; and
- f) Resistance to distortion and creeping at temperatures to which the material may be subjected under conditions of normal or abnormal use.

A material shall not display a loss of these properties beyond the minimum required level as a result of aging. Tests on nonmetallic enclosures for stationary equipment and equipment intended to be permanently connected electrically shall be conducted in accordance with Sections 78 – 93.

5.6.5 Enclosures for portable equipment shall be evaluated in accordance with the applicable requirements in the Standard for Polymeric Materials – Use in Electrical Equipment Evaluations, UL 746C.

5.6.6 A polymeric enclosure intended for connection to a permanent wiring system shall withstand the tests described in 58.1.1 – 58.1.6.

5.6.7 If continuity of a grounding system relies on dimensional integrity of a nonmetallic material, the dimensional stability of the material shall be considered in addition to the factors mentioned in 5.6.4. The material shall withstand the Creep and Overcurrent Test, Section 93.

5.6.8 If a bonding means is not assembled to the equipment, the equipment shall be marked in accordance with 72.7.

5.6.9 A part, such as a dial or nameplate, that is a part of an enclosure shall be metal or other material as specified for the enclosure in 5.4.1 – 5.6.4.

5.6.10 A nonmetallic part, such as a reset knob, lever, or button that protrudes through a hole in the enclosure that is not larger than an area of 1 square inch (6.45 cm²) shall be made of material classified V-2 or better in accordance with the Standard for Tests for Flammability of Plastic Materials for Parts in Devices and Appliances, UL 94.

5.6.11 A nonmetallic part that protrudes through a hole having an area larger than 1 square inch (6.45 cm²) shall be made of material that complies with the requirements in 5.6.2 – 5.6.4 and 5.6.9. See 6.2.1.

5.6.12 A nonmetallic cover attached by screws shall comply with the Cover Retention Test, Section 59, with the screws loosened one full turn.

5.7 Windows

5.7.1 Glass covering an observation opening shall be secured in place so that it cannot be readily displaced in service, and shall provide mechanical protection for the enclosed parts.

5.7.2 Glass for an opening not more than 4 inches (101.6 mm) in any dimension shall be at least 1/16 inch (1.6 mm) thick, and glass for a larger opening, but not more than 144 square inches (929 cm²) in area and having no dimension greater than 12 inches (304.8 mm), shall be at least 1/8 inch (3.2 mm) thick. Glass used to cover an area larger than 144 square inches shall not be less than 1/8 inch thick and shall conform to one of the following:

- a) The glass shall be of a nonshattering or tempered type that, when broken, shall conform to the performance specifications in the Performance Specifications and Methods of Test for Safety Glazing Material Used in Buildings, ANSI Z97.1-1975; or
- b) Shall withstand the 2.5 foot-pound (2.4 J) impact specified in the Glass Window Impact Test, Section 61.

5.7.3 A transparent material other than glass used as a covering over an opening in an enclosure shall comply with the requirements in 5.6.2 – 5.6.4 and 5.6.9 – 5.6.12.

5.8 Raintight and rainproof enclosures

5.8.1 When subjected to the Rain Test, Section 57, an enclosure designated as:

- a) Raintight shall be constructed so that rain does not enter the enclosure.
- b) Rainproof shall be constructed so that rain does not interfere with the operation of the apparatus used within the enclosure.

5.8.2 A raintight or rainproof enclosure shall be marked as specified in 69.7.

5.8.3 A gasket used to make an enclosure raintight or rainproof shall be tested as specified in the Accelerated Aging Tests, Section 55.

5.8.4 A raintight or rainproof enclosure shall be provided with external means for mounting.

Exception: A rainproof enclosure may be provided with internal means for mounting if the mounting means is constructed so that water cannot enter the enclosure.

5.8.5 An opening for conduit in a raintight enclosure, other than in the bottom of the enclosure, shall either be threaded, or accommodate a specific hub complying with the requirements for such devices.

5.8.6 An opening for conduit in a rainproof enclosure shall either:

- a) Be threaded or
- b) Accommodate a specific hub complying with the requirements for such devices unless the opening is located wholly below the lowest terminal lug or other live part within the enclosure. There shall be provision for drainage of the enclosure if a knockout or unthreaded hole is provided other than in the bottom.

6 Openings in Enclosures

6.1 Ventilating openings

6.1.1 A ventilating opening shall not be provided in an enclosure that houses a fuse or any portion of a circuit breaker other than the operating handle, unless the construction affords containment of electrical breakdown disturbances equivalent to that provided by an enclosure complying with the requirements in 5.2.5– 5.2.7.


6.1.2 A ventilating opening shall not be provided in a compartment or part of an enclosure that contains field-wiring splices in a line-voltage circuit.

6.1.3 A ventilating opening shall not be located in a mounting surface of an enclosure.

6.1.4 The shortest distance between a ventilating opening and the bottom of an enclosure or a wall-mounting surface shall be at least one-quarter of the enclosure height or depth, respectively, or 1 inch (25.4 mm), whichever is less.

6.1.5 A ventilating opening may be provided in the bottom surface of an enclosure if the opening does not permit materials to fall directly out from the interior of the unit. Figure 6.1 illustrates a construction that meets this requirement.

Figure 6.1
Bottom panel baffles



6.1.6 There shall be no emission of flame or molten material through a ventilating opening, or manifestation of risk of fire, during normal tests or during abnormal tests, such as transformer burnout and burnout of a relay with blocked armature.

6.1.7 Unless the construction of equipment provided with forced ventilation is such that there is no direct path between live parts and the outlet opening, burnout tests in addition to those mentioned in 6.1.6 shall be conducted to determine that there is no emission of flame or molten material through that opening.

6.1.8 Air from a ventilating opening, either forced or otherwise, shall not be directed:

- a) Into a duct or into a concealed space in a building,
- b) Against the mounting surface, and
- c) So that a disturbance may be propagated to other equipment.

6.1.9 See Accessibility of Uninsulated Live Parts, Film-Coated Wire, and Moving Parts, Section 10, for requirements for accessibility of live parts in an enclosure having ventilating openings.

6.2 Other openings

6.2.1 The smaller dimension (width) of an opening in an enclosure around a dial, adjusting knob, lever, handle, pointer, or the like shall not be more than 1/8 inch (3.2 mm) for any setting or position of the dial, knob, or other members.

6.2.2 Except for the openings described in 6.1.1 – 6.1.7, an enclosure shall have no open holes other than:

- a) Not more than four unused holes intended for mounting various components inside the enclosure. The largest dimension of each such opening shall not be more than 3/16 inch (4.8 mm).
- b) Not more than four holes 1/8 inch (3.2 mm) or less in diameter for the escape of air or drainage of paint during a painting process, located as close to the corners of the enclosure as possible, preferably at the rear of the enclosure.
- c) A drainage opening in a rainproof enclosure that shall not exceed 1/4 by 1/4 inch (6.4 by 6.4 mm).
- d) Not more than:
 - 1) Four holes for mounting an enclosure having a maximum dimension of 18 inches (457 mm);
 - 2) Six holes for an enclosure with a maximum dimension more than 18 inches but less than 48 inches (1.2 m); and
 - 3) Eight holes for an enclosure with a maximum dimension of 48 inches or more.

Four of the holes for mounting an enclosure with a maximum dimension of 12 inches (305 mm) may be keyhole slots having the configuration illustrated in Figure 6.2. The dimensions specified in Figure 6.2 may vary if the area is equivalent. Four of the holes for mounting a larger enclosure may be keyhole slots, the dimensions of which are not specified, and which will be evaluated with regard to the enclosure dimensions and configurations.

e) The unclosed portion of an opening for passage of a capillary tube, an air pipe, a bellows, or other necessary mechanism, which shall not exceed 1/16 inch (1.6 mm).


6.2.3 A plate or plug for an unused conduit opening or other hole in an enclosure shall have a thickness not less than:

a) 0.014 inch (0.36 mm) for steel or 0.019 inch (0.48 mm) for nonferrous metal for a hole having a 1/4 inch (6.35 mm) maximum dimension and

b) 0.027 inch (0.69 mm) for steel or 0.032 inch (0.81 mm) for nonferrous metal for a hole having a 1-3/8 inch (34.9 mm) maximum dimension. A closure for a larger hole shall have a thickness equal to that required for the enclosure of the equipment, or a standard knockout seal shall be used.

Such a plate or plug shall be securely mounted.

Figure 6.2
Keyhole slot



EC600

6.3 Screens and expanded metal

6.3.1 The wires of a screen shall not be less than 16 AWG (1.3 mm²) if used in openings 1/2 square inch (3.2 cm²) or less in area, and shall not be less than 12 AWG (3.3 mm²) for larger openings.

6.3.1 revised February 10, 2004

6.3.2 Perforated sheet steel and sheet steel employed for expanded metal mesh shall not be less than 0.042 inch (1.07 mm) thick – 0.045 inch (1.14 mm) if zinc coated – for mesh openings or perforations 1/2 square inch (3.2 cm²) or less in area and shall not be less than 0.080 inch (2.03 mm) thick – 0.084 inch (2.13 mm) if zinc coated – for larger openings.

Exception: Expanded metal mesh that complies with the requirements in 6.3.3 may be used.

6.3.3 In small equipment where the indentation of a guard or enclosure will not alter the clearance between uninsulated, movable, current-carrying parts and grounded metal so as to adversely affect performance or reduce spacings below the minimum values specified in Table 27.1, 0.020 inch (0.51 mm) expanded metal mesh – 0.023 inch (0.58 mm) if zinc coated – may be used, if:

- a) The exposed mesh on any one side or surface of the device so protected has an area of not more than 72 square inches (464.5 cm²) and has no dimension greater than 12 inches (305 mm) or
- b) The width of an opening so protected is not greater than 3-1/2 inches (88.9 mm).

6.4 Wire openings

6.4.1 If threads for the connection of conduit are tapped all the way through a hole in an enclosure wall, or if an equivalent construction is used, there shall not be less than three threads in the metal, and the construction of the equipment shall be such that a conduit bushing can be attached.

6.4.2 If threads for the connection of conduit are not tapped all the way through a hole in:

- a) An enclosure wall,
- b) Conduit hub, or
- c) A similar part,

there shall not be less than 3-1/2 threads in the metal and there shall be a smooth, rounded inlet hole for the conductors that affords protection to the conductors equivalent to that provided by a standard conduit bushing and that has an internal diameter approximately the same as that of the corresponding trade size of rigid conduit.

6.4.3 In an enclosure threaded for support by rigid conduit, at least five full threads shall be provided for engaging the conduit.

6.4.4 A conduit hub or nipple attached to the enclosure of a pressure switch or similar equipment by swaging, staking, or similar means shall withstand the pullout, torque, and bending tests described in 58.1.2 – 58.1.4.

No Text on This Page

6.4.5 Equipment provided with a conduit nipple and no mounting holes, and marked for direct attachment to an outlet box, need not be subjected to the torque, bending moment, and pull tests, but shall withstand the impact specified in 58.1.6.

Exception: A metallic enclosure with a welded-on nipple need not be subjected to the test described in 58.1.6.

6.4.6 Each clamp and fastener for the attachment of:

- a) Conduit;
- b) Electrical metallic tubing;
- c) Armored cable;
- d) Nonmetallic flexible tubing;
- e) Nonmetallic-sheathed cable;
- f) Service cable; or
- g) Similar items

that is supplied as a part of an enclosure shall comply with the requirements in the Standard for Fittings for Cable and Conduit, UL 514B.

6.4.6 revised November 5, 2001

6.4.7 A knockout in a sheet-metal enclosure shall be reliably secured but shall be capable of being removed without undue deformation of the enclosure.

6.4.8 A knockout shall be provided with a flat surrounding surface for proper seating of a conduit bushing, and shall be located so that installation of a bushing at any knockout likely to be used during installation will not result in a spacing between uninsulated live parts and the bushing less than that required by this standard.

6.4.9 For an enclosure not provided with conduit openings or knockouts, spacings not less than the minimum required by this standard shall be provided between uninsulated live parts and a conduit bushing installed at any location likely to be used during installation. Permanent marking on the enclosure, a template, or a full-scale drawing furnished with the equipment may be used to limit such a location.

6.4.10 With regard to the requirement in 6.4.9, means shall be provided so that an opening for conduit can be made without subjecting internal parts to contamination resulting from the presence of metallic particles.

6.4.11 In measuring a spacing between an uninsulated live part and a bushing installed in the knockout referred to in 6.4.8 and 6.4.9, it is to be assumed that a bushing having the dimensions in Table 6.1 is in place, and that a single locknut is installed on the outside of the enclosure.

6.4.12 No wire other than wires leading to a part mounted on a door or cover shall be brought out through the door or cover.

Table 6.1
Dimensions of bushings

Trade size of conduit, inches	Overall diameter,		Height,	
	inches	(mm)	inches	(mm)
1/2	1	25.4	3/8	9.5
3/4	1-15/64	31.4	27/64	10.7
1	1-19/32	40.5	33/64	13.1
1-1/4	1-15/16	49.2	9/16	14.3
1-1/2	2-13/64	56.0	19/32	15.1
2	2-45/64	68.7	5/8	15.9
2-1/2	3-7/32	81.8	3/4	19.1
3	3-7/8	98.4	13/16	20.6
3-1/2	4-7/16	112.7	15/16	23.8
4	4-31/32	126.2	1	25.4
4-1/2	5-35/64	140.9	1-1/16	27.0
5	6-7/32	158.0	1-3/16	30.2
6	7-7/32	183.4	1-1/4	31.8

7 Mounting

7.1 Equipment that is intended to be fastened in place shall have provision for mounting it securely in position. Bolts, screws, or other parts used for mounting the equipment shall be independent of those used to secure components of the equipment to the frame, base, or panel.

7.2 Portable equipment shall not be provided with means for permanent mounting.

8 Mechanical Assembly

8.1 A control switch, lampholder, attachment-plug receptacle, or plug connector provided as a part of the equipment shall be mounted securely and shall be prevented from turning by means other than friction between surfaces.

8.2 A lock washer, applied as intended, may be used to prevent a control switch from turning.

8.3 The equipment shall be assembled in accordance with 8.4 – 8.6 so that it will not be adversely affected by the vibration of normal operation.

8.4 Screws and nuts that attach operating parts to movable members shall be upset or otherwise locked to prevent loosening under the conditions of actual use.

8.5 An uninsulated live part, including a terminal, shall be secured to its supporting surface by a means other than friction between surfaces so that it will be prevented from turning or shifting in position if such motion may result in reduction of spacings to less than those required by this standard. Contact assemblies shall be secured so as to provide continued alignment of contacts.

8.6 A lock washer, applied as intended, may be used at a terminal or connection stud.

9 Operating Mechanism

9.1 The equipment shall be investigated under conditions of actual service to determine if it complies with all applicable requirements.

9.2 For equipment using electronic or solid-state components or circuits to control a motor, solenoid coil, or other inductive load, it shall be determined that the controlled load will not be caused to overheat due to half-waving or wave distortion of the controller output. This may be accomplished by testing the combination in accordance with 46.2.1, by incorporating protective devices into the controller, or by other equivalent means.

9.3 An operating mechanism shall not subject manually-operated switch parts to undue stress.

9.4 The position of an operating handle shall be marked, if necessary, as a guide for proper operation.

9.5 A control that has or is intended to have a marked off position or an implied off position shall:

- a) Open all ungrounded conductors of the circuit with an air gap when the adjusting means is in the off position and
- b) Be prevented from functioning automatically when in the off position either by a positive mechanical means or the equivalent.

9.6 With reference to the requirements in 9.5, the off state of a solid-state switch is not considered to be an open circuit.

9.7 A component, such as a resistor, capacitor, diode, and the like, shall not be connected across the contacts of a safety control or a protective or limiting device.

Exception: A component may be connected across the contacts of a safety control if investigated and determined to comply with the requirements for use in the end product.

10 Accessibility of Uninsulated Live Parts, Film-Coated Wire, and Moving Parts

10.1 To reduce the risk of unintentional contact that may involve a risk of electric shock from an uninsulated live part or film-coated wire, or injury to persons from a moving part, an opening in an enclosure shall comply with either (a) or (b).

- a) For an opening that has a minor dimension (see 10.5) less than 1 inch (25.4 mm), such a part or wire shall not be contacted by the probe illustrated in Figure 10.1.
- b) For an opening that has a minor dimension of 1 inch or more, such a part or wire shall be spaced from the opening as specified in Table 10.1.

Exception: A motor other than one used in either a hand-held product or a hand-supported portion of a product need not comply with these requirements if it complies with the requirements in 10.2.

Figure 10.1
Articulate probe with web stop




Table 10.1
Minimum distance from an opening to a part that may involve a risk of electric shock or injury to persons

Minor dimension ^a of opening, inches ^b (mm)		Minimum distance from opening to part, inches ^b (mm)	
3/4 ^c	19.1	4-1/2	114.0
1	25.4	6-1/2	165.0
1-1/4	31.8	7-1/2	190.0
1-1/2	38.1	12-1/2	318.0
1-7/8	47.6	15-1/2	394.0
2-1/8	54.0	17-1/2	444.0
d	d	30	762.0
^a See 10.5 for explanation of diameter of opening. ^b Between 3/4 and 2-1/8 inches, interpolation is to be used to determine a value between values specified in the table. ^c Any dimension less than 1 inch applies to a motor only. ^d More than 2-1/8 inches, but not more than 6 inches (152.0 mm).			

10.2 With reference to a part or wire in an integral enclosure of a motor as mentioned in the Exception to 10.1:

- a) An opening may have a minor dimension (see 10.5) less than 3/4 inch (19.1 mm) if:
- 1) A moving part cannot be contacted by the probe illustrated in Figure 10.2;
 - 2) Film-coated wire cannot be contacted by the probe illustrated in Figure 10.3;
 - 3) In a directly accessible motor (see 10.7), an uninsulated live part cannot be contacted by the probe illustrated in Figure 10.4; and
 - 4) In an indirectly accessible motor (see 10.6), an uninsulated live part cannot be contacted by the probe illustrated in Figure 10.2.
- b) An opening may have a minor dimension of 3/4 inch or more if a part or wire is spaced from the opening as specified in Table 10.1.

10.3 The probes mentioned in 10.1 and 10.2 and illustrated in Figures 10.1 – 10.4 are to be applied to any depth that the opening will permit; and are to be rotated or angled before, during, and after insertion through the opening to any position that is necessary to examine the enclosure. The probes illustrated in Figures 10.1 and 10.4 are to be applied in any possible configuration; and, if necessary, the configuration is to be changed after insertion through the opening.

10.4 The probes mentioned in 10.3 and 10.5 shall be used as measuring instruments to judge the accessibility provided by an opening, and not as instruments to judge the strength of a material; they shall be applied with the minimum force necessary to determine accessibility.

Figure 10.2
Probe for moving parts and uninsulated live parts





Figure 10.3
Probe for film-coated wire



10.5 With reference to the requirements in 10.1 and 10.2, the minor dimension of an opening is the diameter of the largest cylindrical probe having a hemispherical tip that can be inserted through the opening.

10.6 With reference to the requirements in 10.2, an indirectly accessible motor is a motor that is:


- a) Accessible only by opening or removing a part of the outer enclosure, such as a guard or panel, that can be opened or removed without using a tool or
- b) Located at such a height or is otherwise guarded or enclosed so that it is unlikely to be contacted.

10.7 With reference to the requirements in 10.2, a directly accessible motor is a motor that can be contacted without opening or removing any part, or is located so as to be accessible to contact.

10.8 During the examination of a product to determine whether it complies with the requirements in 10.1 or 10.2, a part of the enclosure that may be opened or removed by the user without using a tool (to attach an accessory, to make an operating adjustment, or for other reasons) is to be opened or removed.

10.9 With reference to the requirements in 10.1 and 10.2, insulated brush caps are not required to be additionally enclosed.

Figure 10.4
Articulate probe



SA1788A

11 Protection Against Corrosion

11.1 Iron and steel parts shall be protected against corrosion by:

- a) Enameling;
- b) Galvanizing;
- c) Sherardizing;
- d) Plating; or
- e) Other equivalent means.

Exception No. 1: Bearings, thermal elements, or the like, if such protection is impracticable, need not be protected.

Exception No. 2: Small minor parts of iron or steel, such as washers, screws, bolts, and the like, that do not carry current need not be protected if corrosion of such unprotected parts would not be likely to result in a risk of fire, electric shock, or injury to persons.

Exception No. 3: Parts made of stainless steel, properly polished or treated if necessary, need not be protected.

11.2 The requirement in 11.1 applies to all enclosing cases whether of sheet steel or cast iron, and to all springs and other parts upon which proper mechanical operation may depend.

11.3 An enclosure designated either raintight or rainproof shall be protected against corrosion in accordance with the requirements in 11.4 – 11.18.

11.4 Metal shall be used in combinations that are galvanically compatible.

11.5 A hinge or other attachment shall be resistant to corrosion.

11.6 These requirements do not contemplate corrosion that might be caused by exposure to the earth or other corrosive agents.

11.7 The requirements in 11.8 – 11.18 do not apply to a part, such as a decorative grille, that is not a required part of an enclosure.

11.8 A nonmetallic enclosure is to be evaluated on the basis of the effect of exposure to ultraviolet light and water. See Component Evaluation, Section 63.

11.9 A metallic enclosure shall be protected against corrosion as specified in 11.10– 11.18. See 5.3.1 – 5.5.4 for the required enclosure thickness.

11.10 Copper, bronze, brass containing not less than 80 percent copper, or stainless steel may be used without additional protection against corrosion. Sheet, extruded or cast aluminum, die-cast zinc, or other metal shall be of a grade or alloy having resistance to atmospheric corrosion equivalent to that specified for sheet steel of the required thickness, or shall be subjected to appropriate tests, or shall be additionally protected against corrosion.

No Text on This Page

11.11 An enclosure of cast iron or malleable iron at least 1/8 inch (3.2 mm) thick shall be protected against corrosion by:

- a) A 0.00015-inch (0.0038-mm) thick coating of zinc, cadmium, or the equivalent on the outside surface and a visible coating of such metal on the inside surface or
- b) One coat of an organic finish of the epoxy or alkyd-resin type or other outdoor paint on each surface.

11.12 Unless the paint can be determined to comply with these requirements by consideration of its composition, corrosion tests are required.

11.13 An enclosure of sheet steel less than 0.126 inch (3.20 mm) thick if zinc-coated or 0.123 inch (3.12 mm) thick if uncoated shall be protected against corrosion by one of the following means or by other metallic or nonmetallic coatings that have been found to give equivalent protection as described in 11.16.

- a) Hot-dipped, mill-galvanized sheet steel conforming with the coating Designation G90 in Table I of the Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot Dip Process, ASTM A653/A653M-94, with not less than 40 percent of the zinc on any side, based on the minimum single-spot test requirement in this ASTM designation. The weight of zinc coating may be determined by any appropriate method; however, in case of question, the weight of coating shall be established in accordance with the Standard Test Method for Weight of Coating on Zinc Coated (Galvanized) Iron or Steel Articles of ASTM A90-87.
- b) A zinc coating, other than that provided on hot-dipped, mill-galvanized sheet steel, uniformly applied to an average thickness of not less than 0.00061 inch (0.0155 mm) on each surface with a minimum thickness of 0.00054 inch (0.0137 mm). The thickness of the coating shall be established by the Metallic Coating Thickness Test, Section 56. An annealed coating shall also comply with 11.18.
- c) A zinc coating complying with 11.14 (a) or (b) with one coat of an organic finish of the epoxy or alkyd-resin type or other outdoor paint on each surface applied after forming. See 11.12.
- d) A cadmium coating not less than 0.001 inch (0.03 mm) thick on both surfaces. The thickness of coating shall be established in accordance with the Metallic Coating Thickness Test, Section 56.
- e) A cadmium coating not less than 0.00075 inch (0.0191 mm) thick on both surfaces with one coat of outdoor paint on both surfaces, or not less than 0.00051 inch (0.013 mm) thick on both surfaces with two coats of outdoor paint on both surfaces. The thickness of the cadmium coating shall be established in accordance with the Metallic Coating Thickness Test, Section 56, and the paint shall be as specified in (c).

11.14 An enclosure of sheet steel not less than 0.126 inch (3.20 mm) thick if zinc-coated or not less than 0.123 inch (3.12 mm) thick if uncoated shall be protected against corrosion by one of the following means or by other metallic or nonmetallic coatings that have been shown to give equivalent protection as described in 11.16.

- a) Hot-dipped, mill-galvanized sheet steel conforming with the coating Designation G60 or A60 in Table I of the Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process, General Requirements, ASTM A653/A653M-94, with not less than 40 percent of the zinc on any side, based on the minimum single-spot test requirement in this ASTM designation. The weight of zinc coating may be determined by any appropriate method; however, in case of question, the weight of coating shall be established in accordance with the Standard Test Method for Weight of Coating on Zinc-Coated (Galvanized) Iron or Steel Articles, ASTM A90-87.
- b) A zinc coating, other than that provided on hot-dipped, mill-galvanized sheet steel, uniformly applied to an average thickness of not less than 0.00041 inch (0.0104 mm) on each surface with a minimum thickness of 0.00034 inch (0.0086 mm). The thickness of the coating shall be established by the Metallic Coating Thickness Test, Section 56.
- c) Two coats of an organic finish of the epoxy or alkyd resin or other outdoor paint on each surface. Compliance with these requirements is to be determined by consideration of the composition of the paint or by corrosion tests.
- d) Any one of the means specified in 11.13.

11.15 The requirements in 11.14 also apply to an enclosure of zinc-coated sheet steel not less than 0.056 inch (1.42 mm) thick and an enclosure of uncoated sheet steel not less than 0.053 inch (1.35 mm) thick if the enclosure is intended to be mounted within and protected from direct exposure to weather by the enclosure of other equipment, such as an air conditioner. Such an enclosure shall not be marked rainproof or raintight.

11.16 With reference to 11.13 – 11.15, other finishes, including paints, metallic finishes and combinations of the two may be used when comparative tests with galvanized sheet steel – without annealing, wiping or other surface treatment – complying with 11.13(a) or 11.14(a), as applicable, indicate they provide equivalent protection. Among the factors that are to be taken into consideration when judging the compliance of such coating systems are exposure to salt spray, moist carbon dioxide-sulphur dioxide-air mixtures, moist hydrogen sulphide-air mixtures, ultraviolet light and water.

11.17 If tests are required, test specimens of a finish as described in 11.12, 11.13(c), 11.14(c), or 11.16, if the paint is tested, are to be consistent with the finish that is to be used in production with regard to the base metal, cleaning or pretreatment method, application method, number of coats, curing method, thickness, or the like.

11.18 A hot-dipped, mill-galvanized A60 (alloyed) coating or an annealed zinc coating that is bent or similarly formed after annealing and that is not otherwise required to be painted shall be painted in the bent or formed area if the bending or forming process damages the zinc coating, except that such areas on the inside surface of an enclosure that water does not enter during the rain test need not be painted. The zinc coating is considered to be damaged if flaking or cracking of the zinc coating at the outside radius of the bent or formed section is visible at 25 power magnification. Simple sheared or cut edges and punched holes are not considered to be formed.

12 Insulating Materials

12.1 A barrier or integral part, such as an insulating washer or bushing, and a base or a support for mounting live parts, shall be moisture-resistant material that will not be adversely affected by the temperature and stresses to which it will be subjected under conditions of use.

12.2 Insulating material shall be evaluated with regard to its use. Materials, such as mica, some molded compounds, and certain refractory materials usually comply with the requirements for sole support of live parts. When an investigation is required to determine whether a material complies, the investigation shall be conducted in accordance with the Standard for Polymeric Materials – Use in Electrical Equipment Evaluations, UL 746C, with consideration given to:

- a) The material's;
 - 1) Mechanical strength;
 - 2) Resistance to hot wire ignition;
 - 3) Resistance to high-current-arc ignition;
 - 4) Resistance to high-voltage-arc ignition;
 - 5) Dielectric strength;
 - 6) Insulation resistance; and
 - 7) Heat-resistant qualitiesin both the aged and unaged conditions;
- b) The degree to which the material is enclosed; and
- c) Any other feature affecting the risk of fire, electric shock, or injury to persons.

All factors are to be considered with regard to conditions of actual service.

12.3 Ordinary vulcanized fiber may be used for insulating bushings, washers, separators, and barriers, but not as sole support for uninsulated live parts.

12.4 A sensor such as a current transformer, transducer, or the like, shall be provided with insulation that has been evaluated for the maximum voltage and temperature involved in its application, while taking into consideration the presence of other circuits.

12.5 All internal polymeric parts shall be classified at least HB in accordance with the Standard for Tests for Flammability of Plastic Materials for Parts in Devices and Appliances, UL 94.

13 Field Connections

13.1 General

13.1.1 Compartments, raceways, and the like, for routing and stowage of conductors connected in the field shall not contain rough, sharp, or moving parts that may damage conductor insulation.

13.2 Equipment permanently connected electrically

13.2.1 For power circuit connections, permanently-connected equipment shall have provision for the connection of a wiring system.

13.2.2 Wiring terminals or leads shall be provided and shall comply with the requirements for the connection of conductors having an ampacity not less than the largest of the following ratings that are applicable:

- a) One hundred twenty-five percent of the ampere rating of an electric space-heating equipment load that is to be permanently connected electrically.
- b) One hundred twenty-five percent of a continuous duty load.
- c) One hundred twenty-five percent of the full-load motor-current rating in accordance with 68.4 and 68.5. See Table 47.2 or 47.3 for the ampere rating corresponding to a horsepower rating.
- d) For a combination load, 125 percent of the full-load motor current of the largest motor, plus 125 percent of the ampere rating of an electric space-heating equipment load that is to be permanently connected electrically, plus 125 percent of the continuous duty load, plus 100 percent of the sum of the current ratings of all other loads.
- e) For direct-current motors intended to be operated from a rectified single-phase power supply unless marked in accordance with 70.18,
 - 1) One hundred ninety percent if a half-wave rectifier is used.
 - 2) One hundred fifty percent if a full-wave rectifier is used.
- f) The ampere rating of the equipment for a load not specified in (a), (b), (c), (d), or (e).

13.2.3 With reference to 13.2.2, it is assumed that 75°C (167°F) conductors will be employed for currents of more than 100 amperes.

13.2.4 For equipment marked to indicate that it may be used with copper, copper-clad aluminum, or aluminum conductors, the field wiring terminals shall comply with the requirements for such devices and with the requirement in 13.2.2 for a wire of each metal for which it is marked. See 70.12.

13.2.5 A terminal box or compartment on equipment permanently connected electrically shall be located so that wire connections therein will be accessible for inspection, without disturbing either factory or field connected wiring, after the equipment is installed in the intended manner.

Exception No. 1: Wire connections to equipment intended to be mounted on an outlet box may be accessible upon removal of the equipment from the outlet box.

Exception No. 2: Factory supplied low-voltage, non-safety circuit wire connected to a hinged panel or cover may be flexed.