



UL 943B

STANDARD FOR SAFETY

Appliance Leakage-Current Interrupters

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

UL Standard for Safety for Appliance Leakage-Current Interrupters, UL 943B

Third Edition, Dated December 4, 2017

SUMMARY OF TOPICS:

This new edition of ANSI/UL 943B is being issued to address editorial corrections and maintenance of UL Standards for Safety. These changes are considered to be non-substantive and not subject to UL's STP process.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
Document Sharing Hub

No Text on This Page

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

DECEMBER 4, 2017

1



ANSI/UL 943B-2017

UL 943B

Standard for Appliance Leakage-Current Interrupters

First Edition – May, 2001

Second Edition – August, 2011

Third Edition

December 4, 2017

This ANSI/UL Standard for Safety consists of the Third Edition.

The most recent designation of ANSI/UL 943B as an American National Standard (ANSI) occurred on October 26, 2017 ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2017 UNDERWRITERS LABORATORIES INC.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

No Text on This Page

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	5
2 Glossary	5
3 Components	7
4 Units of Measurement	7
5 References	7

CONSTRUCTION

6 Mechanical Assembly	7
7 Enclosure	11
7.1 General	11
7.2 Metal enclosures	11
7.3 Polymeric enclosures	12
7.4 Corrosion resistance	12
8 Accessibility of Uninsulated Live Parts and Film-Coated Wire	12
9 Electrical Insulation	13
10 Attachment Plug	13
11 Flexible Cord	15
12 Terminations	16
13 Grounding	17
14 Spacings	17
15 Alternate Spacings – Clearances and Creepage Distances	19
16 Live Parts	20
17 Internal Wiring	20
18 Operating Mechanism	21
19 Supervisory Circuit	21
20 Auto-Monitoring Function	22

PROTECTION AGAINST INJURY TO PERSONS

21 Sharp Edges	22
----------------------	----

PERFORMANCE

22 General	23
23 Humidity Conditioning	25
24 Leakage Current Test	25
25 Drop Test	26
26 Voltage Surge Test	27
27 Trip Threshold Measurement	28
28 High-Resistance Ground Fault Test	29
29 Dielectric Voltage-Withstand Test	32
30 Resistance to False Tripping Test	33
31 Temperature Test	34
32 Overload Test	36
33 Low-Resistance Ground Fault Test	38
34 Endurance Test	39
35 Abnormal Operation	41

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM



Documents

Document Sharing Hub

36	Extra-Low-Resistance Ground Faults Test	41
37	Short Circuit Test	43
38	Security of Blades Test	43
39	Crushing Resistance Test	43
40	Strain-Relief Test	43
41	Security of Terminals	44
42	Dust Test	44
43	Auto-Monitoring Function Test	44

RATINGS

44	Details	46
----	---------------	----

MARKINGS

45	General	46
----	---------------	----

APPENDIX A

Standards for Components.....	A1
-------------------------------	----

INTRODUCTION

1 Scope

1.1 These requirements cover appliance leakage-current interrupters (ALCIs), intended for use only in 2- or 3- wire alternating-current circuits wherein one of the wires is grounded in accordance with the National Electrical Code, ANSI/NFPA 70. They are intended to interrupt the electric circuit to the load when a fault current to ground exceeds some predetermined value that is less than that required to operate the overcurrent protective device of the supply circuit. An ALCI trips when the current to ground reaches a value in the range of 4 – 6 mA.

1.2 These requirements cover 2-wire appliance leakage-current interrupters for use only in cord-connected appliances intended for connection to alternating-current circuits of 250 V or less. An additional ground conductor may be provided. They are not to be provided with a general-purpose outlet receptacle, cord-connector body, or similar devices. Devices complying with these requirements are acceptable for use as components in an end product where the acceptability of the combination is to be determined.

1.3 The acceptability of an appliance leakage-current interrupter in any particular application depends upon its ability to be used continuously under the conditions that prevail in actual service. Accordingly, for a particular application, an appliance leakage-current interrupter may be affected by the requirements for the equipment it is used in, and it may be necessary to additionally evaluate features or performance characteristics that are not specified in this standard.

1.4 This standard does not cover ground-fault circuit-interrupters, which are covered by the Standard for Ground-Fault Circuit-Interrupters, UL 943.

2 Glossary

2.1 For the purpose of this standard, the following definitions shall apply:

2.2 ACCESSIBLE PART – A part so located that it can be contacted by a person, either directly or by means of a probe or tool.

2.3 AUTOMATIC RECLOSURE – Denotes the act of an appliance leakage-current interrupter resetting itself after having been tripped.

2.4 CORD CONNECTED – Denotes connection to a supply circuit by way of a flexible cord terminating in an attachment plug.

2.5 DOUBLE INSULATION – The insulation system resulting from a combination of functional and supplementary insulation.

2.6 ENCLOSURE – Any surface or surrounding structure intended to minimize access to energized parts or parts presenting real or potential risk of injury to persons.

2.7 ENERGIZED PART – A part at some potential with respect to another part, or to earth.

2.8 FUNCTIONAL INSULATION – The insulation necessary for the proper functioning of the device, and for basic protection against the risk of electric shock.

2.9 INDOOR USE – Use in an indoor location or where exposure to rain is not likely to occur.

2.10 GROUND FAULT – An unintentional electrical path between a part operating normally at some potential to ground, and ground.

2.11 LEAKAGE CURRENT – All currents including capacitively coupled currents which may be conveyed between energized parts of a circuit and ground or other parts.

2.12 ORDINARY TOOLS – Pliers, and flat-bladed and cross recessed-head (Phillips type) screwdrivers.

2.13 RATED CURRENT – The marked value of current.

2.14 RATED VOLTAGE – For devices with a marked voltage within the range of 110 – 125 V, the rated voltage is to be considered to be 120 V. For devices with an additional marked voltage within the range of 190 – 250 V, the rated voltage is considered to be 120/240 V.

2.15 REINFORCED INSULATION – An insulation providing protection against the risk of electrical shock that is equivalent to double insulation.

2.16 RISK OF ELECTRIC SHOCK – A risk of electric shock hazard is considered to exist at a part of an appliance leakage-current interrupter if:

- a) There would be current of 6 mA or more in a resistance of 500 ohms connected between the part in question and the grounded supply conductor, and
- b) The device would not operate to open the circuit to the 500-ohm resistor within the time allowed in 28.1.

2.17 SUPPLEMENTARY INSULATION – An independent insulation provided in addition to the functional insulation to insure protection against the risk of electric shock in the event that functional insulation should fail.

2.18 TRIP – Automatic interruption by the appliance leakage-current interrupter of the electric circuit to the load.

3 Components

3.1 Except as indicated in 3.2, a component of a product covered by this standard shall comply with the requirements for that component. See Appendix A for a list of standards covering components generally used in the products covered by this standard.

3.2 A component is not required to comply with a specific requirement that:

- a) Involves a feature or characteristic not required in the application of the component in the product covered by this standard, or
- b) Is superseded by a requirement in this standard.

3.3 A component shall be used in accordance with its rating established for the intended conditions of use.

3.4 Specific components are incomplete in construction features or restricted in performance capabilities. Such components are intended for use only under limited conditions, such as certain temperatures not exceeding specified limits, and shall be used only under those specific conditions.

4 Units of Measurement

4.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

5 References

5.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

CONSTRUCTION

6 Mechanical Assembly

6.1 An appliance leakage-current interrupter shall be formed and assembled so that it will have the strength and rigidity necessary to resist abuses to which it is likely to be subjected, without producing or increasing a risk of fire, electric shock or injury to persons due to total or partial collapse with resulting reduction of spacings, loosening or displacement of parts, or other serious defects.

6.2 An appliance leakage-current interrupter shall have all parts reliably secured in place.

6.3 An appliance leakage-current interrupter shall be constructed so that it will not be necessary to open or remove the enclosure when used as intended.

6.4 Male contact devices such as plugs, provided with, or as an integral part of, an appliance leakage-current interrupter shall also comply with the applicable construction and performance requirements from the Standard for Attachment Plugs and Receptacles, UL 498.

6.5 Lampholders, switches, and other similar components shall be mounted securely and turning shall be restricted from turning by more than friction between surfaces. For example, the use of a lockwasher is acceptable to restrict the turning of a device having a single hole mounting means.

Exception No. 1: A lampholder of a type in which the lamp cannot be replaced, (such as a neon pilot or indicator light in which the lamp is sealed-in by a nonremovable jewel), is not be prohibited from turning if rotation cannot reduce spacings below the minimum acceptable values or produce stress on a connector.

Exception No. 2: A switch or other similar component shall be securely mounted and turning shall be minimized, unless the turning of such a component is part of the design of the unit and introduces no additional risk of fire or electrical shock, or both, such as reduced spacings below the minimum acceptable values or stress on a connection.


6.6 An indicator light shall be one in which the lamp is sealed-in, such as by a nonremovable jewel.

6.7 A switch shall be located within the unit enclosure in such a manner as not to be accessible or exposed to tampering, nor subject to damage during normal use. This requirement does not apply to the actuating means of a switch.

6.8 The maximum acceptable moment, center of gravity, dimensions, and weight of a direct plug-in unit shall comply with the requirements specified in (a), (b), (c) and (d). See 6.9, 6.10 and Figure 6.1.

- a) The quotient of WY/Z shall not exceed 48 ounces (1361 g).
- b) The quotient of WY/S shall not exceed 48 ounces (1361 g).
- c) The product of WX shall not exceed 80 ounce-inches (0.56 N-m).
- d) The weight of a unit shall not exceed 28 ounces (794 g).

Figure 6.1
Dimensions of a direct plug-in unit



C.G. = Center of Gravity

CP100

6.9 Definitions for the symbols used in 6.8 are as follows:

- a) W is the weight of the unit in ounces (g).
- b) Y is the distance illustrated in Figure 6.1 in inches (mm).
- c) Z is the lesser of the two distances, Z_1 or Z_2 , as illustrated in Figure 6.1 in inches (mm).
- d) S is the lesser of the two distances, S_1 or S_2 , as illustrated in Figure 6.1 in inches (mm).
- e) X is the greater of the two distances, X_1 or X_2 , as illustrated in Figure 6.1 in inches (mm).

6.10 The moment and weight specified in 6.8 are to be determined as follows:

- a) For units with an output cord, the cord is to be cut off at the enclosure, or at the strain-relief means if the strain-relief means is outside the enclosure.
- b) For units with directly mounted accessories, the values are to be measured with the accessories in place.


UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
Document Sharing Hub

6.11 When inserted in a parallel-blade duplex receptacle, any part of a unit, including output wiring, shall not interfere with full insertion of an attachment plug into the adjacent receptacle. See Figure 6.2.

Exception: A unit that renders the adjacent receptacle completely unusable in any one mounting position is considered to comply with this requirement.



6.12 A mounting tab shall not be provided with the unit.

6.13 The enclosure of an attachment plug-type ALCI shall be capable of being gripped for removal from the receptacle to which it is connected. Gripping means include detents on the enclosure, ribs, or other equivalent means to facilitate grasp and removal of the ALCI. The perimeter of the face section from which the blades project shall not be less than 5/16 inch (7.9 mm) from any point on either blade.

UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL



Documents
Document Sharing Hub

7 Enclosure

7.1 General

7.1.1 An appliance leakage-current interrupter shall be provided with an enclosure that shall house all current-carrying parts other than primary blades and output leads. The enclosure shall have the strength and properties necessary to reduce the risk of mechanical damage to the various parts.

7.1.2 If access to the interior of a unit can present a risk of fire, electric shock, or injury to persons, seams and joints of the enclosure shall be assembled by welding, riveting, the use of screws or fasteners that are not removable by the use of an ordinary tool, (see 2.12), or the equivalent. For enclosure parts secured together by adhesive, see 7.3.2.

Exception: A unit containing components that may require factory assembly may have the enclosure assembled by screws or other fasteners removable by an ordinary tool, provided there is means to discourage user-tampering such as sealing of one or more of the assembly fasteners. Potting compound, encapsulation, or equivalent means provided to comply with this requirement shall be in place when the units are subjected to the Enclosure Tests outlined in 7.3.1 and Crushing-Resistance Test of Section 39.

7.1.3 Cross recessed-head screws (Phillips type), spring clips, and similar devices are considered to be defeatable by an ordinary tool.

7.2 Metal enclosures

7.2.1 An enclosure constructed of sheet metal shall be formed from stock having a thickness not less than that specified in Table 7.1. The thickness of enclosure sheet metal, other than steel or aluminum, shall not be less than that specified in Table 7.1 for uncoated steel, and shall have the necessary strength and rigidity.

Table 7.1
Thickness of sheet metal for enclosures

	Minimum acceptable thickness	
	Inch	(mm)
Uncoated steel	0.026	(0.66)
Zinc-coated steel	0.029	(0.74)
Aluminum	0.040	(1.02)

7.2.2 A lanced tab provided for internal component mounting may have a small opening caused by die clearance if:

- a) The opening caused by the tab is substantially closed by the mounted component, and
- b) The tab is located on the surface of the enclosure with the supply-connector pins.

7.3 Polymeric enclosures

7.3.1 A polymeric enclosure or a polymeric part of an enclosure shall comply with the applicable requirements for enclosures as specified in the Standard for Polymeric Materials – Use in Electrical Equipment Evaluations, UL 746C.

Exception No. 1: The Drop Test of Section 25 of this standard shall be conducted in place of the tests described in the Resistance to Impact Test of the Standard for Polymeric Materials – Use in Electrical Equipment Evaluations, UL 746C.

Exception No. 2: For a direct plug-in appliance leakage-current interrupter, the crushing test shall be conducted in accordance with the Crushing Test of the Standard for Attachment Plugs and Receptacles, UL 498.

7.3.2 An adhesive used in the assembly of an appliance leakage-current interrupter shall comply with the applicable requirements for adhesives as specified in the Standard for Polymeric Materials – Use in Electrical Equipment Evaluations, UL 746C.

Exception: Methods utilizing fusion techniques, such as solvent cementing, ultrasonic welding, electromagnetic induction, and thermal welding need not be investigated.

7.4 Corrosion resistance

7.4.1 Except as noted in 7.4.2, iron and steel parts shall be protected against corrosion by galvanizing, plating, enameling, or other equivalent means, if the corrosion of such unprotected parts would be likely to result in a risk of fire, electric shock, or injury to persons.

7.4.2 The requirement in 7.4.1 applies to all enclosing cases or to other parts upon which intended mechanical operation may depend. It does not apply to laminations and minor parts of iron or steel, such as washers, screws, and bolts, that are not current-carrying, if the corrosion of such unprotected parts would not be likely to result in a risk of fire, electrical shock or injury to persons, or result in the device not operating as intended. A part made of stainless steel does not require additional protection against corrosion.

8 Accessibility of Uninsulated Live Parts and Film-Coated Wire

8.1 An appliance leakage-current interrupter shall not have openings that allow a 1/16-inch (1.6-mm) diameter metal rod to be inserted and contact an uninsulated live part, film-coated wire, or internal wiring.

Exception: If the appliance leakage-current interrupter is intended to be enclosed in or constructed as an integral part of the end-use product, the construction shall comply with the accessibility of live parts requirements of the end-product standard.

8.2 With respect to the requirement in 8.1, a part of the outer enclosure that may be opened or removed by the user without using a tool, is to be opened or removed.