

APRIL 23, 2015

1

UL 1767B

**SPECIFIC APPLICATION EARLY-SUPPRESSION FAST-RESPONSE (ESFR)
PENDENT SPRINKLERS HAVING A NOMINAL DISCHARGE COEFFICIENT
OF 28.0.**

Issue Number: 1

April 23, 2015

Summary of Topics

This First Issue of the Outline of Investigation for Specific Application Early- Suppression Fast-Response (ESFR) Pendent Sprinklers Having A Nominal Discharge Coefficient Of 28.0, UL 1767B, includes requirements for ESFR sprinklers having a nominal K-factor of 28.0 intended for protection of cartoned, unexpanded Group A plastic commodity stored up to 43 feet (13.1 m) in height with a maximum ceiling height of 48 feet (14.6 m).

UL's Outlines of Investigation are copyrighted by UL. Neither a printed nor electronic copy of an Outline of Investigation should be altered in any way. All of UL's Outlines of Investigation and all copyrights, ownerships, and rights regarding those Outlines of Investigation shall remain the sole and exclusive property of UL.

COPYRIGHT © 2015 UNDERWRITERS LABORATORIES INC.

**UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL**



Documents
Document Sharing Hub

No Text on This Page

*UL COPYRIGHTED MATERIAL –
NOT AUTHORIZED FOR FURTHER REPRODUCTION OR
DISTRIBUTION WITHOUT PERMISSION FROM UL*



Documents

Document Sharing Hub

CONTENTS

INTRODUCTION

1 Scope	4
2 Components	4
3 Units of Measurement	4
4 Undated References	5
5 Glossary	5

CONSTRUCTION

6 Nominal "K" Factors	5
-----------------------------	---

PERFORMANCE

7 Large Scale Fire Tests for Specific Application Pendent ESFR Sprinklers having a Nominal K-factor of 28.0	5
---	---