

OTHER
RECOGNIZED
DOCUMENT

ULC/ORD-C262-1992

GATE VALVES
FOR
FIRE-PROTECTION
SERVICE



Underwriters' Laboratories of Canada



Documents

Document Sharing Hub

UNDERWRITERS' LABORATORIES OF CANADA (ULC) is a not-for-profit organization incorporated in 1920 by letters patent issued by the Canadian government. It maintains and operates laboratories and a certification service for the examination, testing and classification of devices, constructions, materials and systems to determine their relation to life, fire and property hazards. Underwriters' Laboratories of Canada also develops and publishes standards, classifications and other recognized documents for products having a bearing on fire, accident, or property hazards.

Underwriters' Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization and a Standards Writing Organization under the National Standards System of Canada.

Other Recognized Documents developed by Underwriters' Laboratories of Canada are developed in accordance with the procedure outlined in the document CAN-P-3 "Criteria and Procedures for Accreditation of Certification Organizations" published by the Standards Council of Canada.

The headquarters of Underwriters' Laboratories of Canada is located in Scarborough, Ontario and in addition ULC is represented across Canada as well as in the United States of America, Britain, Europe and Japan.

Underwriters' Laboratories of Canada,
7 Crouse Road,
Scarborough, Ontario.
M1R 3A9

THE STANDARDS COUNCIL OF CANADA is the coordinating body of the National Standards System, a federation of independent autonomous organizations working towards the further development and improvement of voluntary standardization in the national interest.

The principal objects of the Council are to foster and promote voluntary standardization as a means of advancing the national economy, benefitting the health, safety and welfare of the public, assisting and protecting the consumer, facilitating domestic and international trade, and furthering international cooperation in the field of standards.

The National Standards System of Canada accepts the use of Other Recognized Documents (ORD's) as defined in CAN-P-3 "Criteria and Procedures for Accreditation of Certification Organizations" published by the Standards Council of Canada.

The Standards Council of Canada is located at 350 Sparks Street, Ottawa, Ontario.

NOTE: It is important to note that it is the responsibility of the user of this document to judge its suitability for the particular application.

ULC/ORD-C262-1992

**GATE VALVES
FOR
FIRE-PROTECTION SERVICE**

Prepared and Published by
UNDERWRITERS' LABORATORIES OF CANADA



FIRST EDITION February, 1992

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission of Underwriters' Laboratories of Canada.

TABLE OF CONTENTS

	<u>PAGE</u>
FOREWORD	
PREFACE	
1. SCOPE	2
2. CONSTRUCTION	2
2.1 General	2
2.2 Working Pressures	2
2.3 Bodies and Bonnets	3
2.4 Gates	4
2.5 Seating Surfaces	4
2.6 Stems	4
2.7 Stuffing Boxes and Stem Seals	6
2.8 Handwheels	6
2.9 Wrench Nuts	8
2.10 Indicator Post Flanges	9
2.11 Nonmetallic Materials	9
3. MARKING	10
4. PERFORMANCE	11
4.1 Nonmetallic Materials Tests	11
4.1.1 Tests on Organic Coating Materials Seating Surfaces	11
4.1.2 Resilient Seat Material Securement Test	11
4.1.3 Resilient Seat Cycling Test	11



Table of Contents (Cont'd):

4.2	Leakage Test	11
4.3	Friction Loss Test for Valves Having Reduced Waterways	12
4.4	Mechanical Strength Test	12
4.5	Strength of Body Test	13
5.	TEST METHODS	13
5.1	Nonmetallic Materials Tests	13
5.1.1	Tensile Strength and Elongation Tests	13
5.1.2	Permanent Elongation Or Set	14
5.1.3	Accelerated Oxygen Pressure Aging Test	14
5.1.4	Hardness Tests	15
5.1.5	Disbondment and Blistering Test	15
5.1.6	Impact Test	15
5.1.7	Resilient Seat Material Securement Test	15
5.1.8	Resilient Seat Cycling Test	16
5.2	Stuffing Box Repacking Test	16
5.3	Seat Leakage Test	16
5.4	Hydraulic Friction Loss Test	17



UNDERWRITERS' LABORATORIES OF CANADA

FOREWORD

Certification organizations are periodically called upon to respond promptly to a need to provide a certification service for devices, constructions, materials and systems for which no recognized standards of acceptance are available. Accordingly, the certification agency draws upon its experience, existing specifications and requirements in related areas, together with assistance from its advisory councils to develop and prepare an "Other Recognized Document" (ORD) for use in conducting the necessary tests and evaluation investigation.

Underwriters' Laboratories of Canada has over the years prepared many ORD's in response to requests from, and in conjunction with, industry, code writing bodies, regulatory agencies and others prior to inaugurating a certification programme. In many instances such documents have become published ULC Standards and subsequently National Standards of Canada. It is the intention of Underwriters' Laboratories of Canada to continue this practice, as appropriate.

Comments on the content of this ORD should be directed to the Head Office of Underwriters' Laboratories of Canada, 7 Crouse Road, Scarborough, Ontario, CANADA, M1R 3A9.

NOTE: *These Recognized Documents are accepted under the National Standards System of Canada. Reference may be made to the Document CAN-P-3, "Criteria and Procedures for Accreditation of Certification Organization" published by the Standards Council of Canada located at 45 O'Connor Street, Suite 1200, Ottawa, Ontario, CANADA, K1P 6N7.*



INCORPORATED 1920

UNDERWRITERS' LABORATORIES OF CANADA

General Offices and Testing Station 7 CROUSE ROAD, SCARBOROUGH, ONTARIO, CANADA M1R 3A9

Telephone (416) 757-3611 Fax (416) 757-9540

In Reply,ing
Please Refer to**ULC/ORD-C262-1992**

GATE VALVES FOR FIRE-PROTECTION SERVICE

PREFACE

This is the First Edition of ULC/ORD-C262-1992, entitled "Gate Valves for Fire-Protection Service".

A product which complies with these requirements will not necessarily be acceptable if, when examined and tested, it is found to have features not covered by this document which may impair the result contemplated by these requirements.

A product employing materials or having forms of construction differing from those detailed in these requirements may be examined and tested according to the intent of the requirements, and if found to be substantially equivalent, may be given recognition.

Units of measurement used in this document are Metric SI.