

**CAN/ULC-S112:2010-R2016
(Reaffirmed 2016)**

**STANDARD METHOD OF FIRE TEST OF FIRE DAMPER
ASSEMBLIES**

Prepared and Published by:



Approved by:



Standards Council of Canada
Conseil canadien des normes

Underwriters Laboratories of Canada (ULC) was established in 1920 by letters patent issued by the Canadian Government. It maintains and operates laboratories and certification services for the examination, testing and certification of appliances, equipment, materials, constructions and systems to determine their relation to life, fire and property hazards as well providing inspection services.

Underwriters Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization, a Testing Organization, and an Inspection Body under the National Standards System of Canada.

ULC Standards develops and publishes standards and other related publications for building construction, security and burglar protection, environmental safety, electrical equipment, fire protection equipment, gas and oil equipment, thermal insulation products, materials and systems, energy use in the built environment and electrical utility safety.

ULC Standards is a not-for-profit organization and is accredited by the Standards Council of Canada as a Standards Development Organization.

National Standards of Canada developed by ULC Standards conform to the criteria and procedures established by the Standards Council of Canada. Such standards are prepared using the consensus principle by individuals who provide a balanced representation of interests relevant to the subject area on a national basis.

ULC is represented across Canada as well as many countries worldwide. For further information on ULC services, please contact:

Customer Service: 1-866-937-3852

National Standard of Canada

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations*, and *Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at www.scc.ca.

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

CORPORATE HEADQUARTERS

Underwriters Laboratories of Canada
7 Underwriters Road
Toronto, Ontario M1R 3A9
Telephone: (416) 757-3611
Fax: (416) 757-9540

REGIONAL OFFICES

PACIFIC OFFICE

13775 Commerce Parkway, Suite 130
Richmond, British Columbia V6V 2V4
Telephone: (604) 214-9555
Fax: (604) 214-9550

EASTERN OFFICE

6505, Rte Transcanadienne, Suite 330
St-Laurent, Québec H4T 1S3
Telephone: (514) 363-5941
Fax: (514) 363-7014

For further information on ULC standards, please contact:

ULC STANDARDS

171 Nepean Street, Suite 400
Ottawa, Ontario K2P 0B4
Telephone: (613) 755-2729
Fax: (613) 231-5977
E-mail: customerservice@ulc.ca
Web site: www.ulc.ca

The intended primary application of this standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

Copies of this National Standard of Canada may be ordered from ULC Standards.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

STANDARD METHOD OF FIRE TEST OF FIRE DAMPER ASSEMBLIES

ICS 13.220.30; 19.040; 91.140.30

Prepared and Published by:



Approved by:



First Edition March 1982
Second Edition July 1990
Third Edition June 2010
REAFFIRMED APRIL 2016

Copyright © 2016

ULC Standards

All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission.

TABLE OF CONTENTS

ULC STANDARDS COMMITTEE ON FIRE TESTS	I
PREFACE	III
1 SCOPE	1
2 REFERENCE PUBLICATIONS	1
3 GLOSSARY	2
4 CONSTRUCTION	3
4.1 GENERAL	3
4.2 HEAT RESPONSIVE DEVICES	4
4.3 SLEEVES	4
4.4 ACTUATORS	5
4.5 CORROSION PROTECTION	5
5 PERFORMANCE REQUIREMENTS	6
6 FIRE-ENDURANCE AND HOSE-STREAM TEST	6
6.1 TEST ASSEMBLIES	6
6.2 CONTROL AND CONDUCT OF FIRE TESTS	7
6.3 DIFFERENTIAL PRESSURE	7
6.4 HOSE STREAM TEST	8
6.4.1 Test Specimen	8
6.4.2 Application of the Hose Stream	8
6.4.3 Exemption	8
6.4.4 Optional Program	9
6.4.5 Hose Stream Equipment and Details	9
6.4.6 Nozzle Distance	9
6.4.7 Procedure for Hose Stream Test	9
7 CYCLING TEST	9
8 RIGIDITY TESTS	10
8.1 GENERAL	10
8.2 LATERAL DISPLACEMENT TEST	10
8.3 LONGITUDINAL DISPLACEMENT TEST	10

9 SALT- SPRAY EXPOSURE TEST	10
10 SPRING CLOSING FORCE TEST	11
11 DYNAMIC CLOSURE TEST	11
11.1 GENERAL	11
11.2 METHOD	11
12 DUCT IMPACT TEST	12
13 HYDROSTATIC STRENGTH TEST FOR PNEUMATIC ACTUATORS	13
14 INSTALLATION AND OPERATING INSTRUCTIONS	13
15 CONDITIONS OF ACCEPTANCE	14
16 REPORT	15
TABLES	16
FIGURES	17

ULC STANDARDS COMMITTEE ON FIRE TESTS

NAME	AFFILIATION	REGION	CATEGORY
A. Laroche (Chair)	Canadian Codes Centre, National Research Council Canada	Canada	Regulator
C. Andersson	Health Canada	Canada	Regulator
B. Bulley	Canadian Steel Door Manufacturers Association	Canada	Producer
B. Cheer	Ontario Building Officials Association	Ontario	Regulator
S. Craft	CHM Fire Consultants Ltd.	Ontario	General Interest
T. Crimi	A.C. Consulting Solutions Inc.	Ontario	General Interest
C. Dagenais	FPIInnovations	Canada	User
D. Falconer	Falconer Engineering & Testing	Ontario	General Interest
G. Frater	Canadian Steel Construction Council	Canada	Producer
G. Gardin	Canadian Plastics Industry Association	Canada	Producer
M. Gilfillan	Canadian Fire Safety Association	Canada	General Interest
G. Hadjisophocleous	Carleton University	Ontario	General Interest
L. Hamre	PLC Fire Safety Solutions	New Brunswick	General Interest
J. Humpries	City of Toronto	Ontario	Regulator
G. Loughheed	National Research Council Canada	Canada	User
M. McClure	ThermoFire Systems Inc.	Ontario	General Interest
R. McGrath	Cement Association of Canada	Canada	Producer
G. Morinville	National Defence and the Canadian Armed Forces	Canada	User
E. Randsalu	Office of the Fire Marshal and Emergency Management	Ontario	Regulator
J. Roberts	LRI Engineering Inc.	Canada	User
P. Shinkoda	CGC Inc.	Canada	Producer
I. Smith	Exova Canada Inc.	Canada	User
I. Van Zeeland	Canadian Wood Council	Canada	Producer
N. Benichou (Associate Member)	National Research Council Canada	Canada	Non-Voting
M. Birk (Associate Member)	Queen's University	Ontario	Non-Voting
L. Kearns (Associate Member)	National Defence and the Canadian Armed Forces	Canada	Non-Voting
K. Kooner (Associate Member)	Intertek	Canada	Non-Voting
H. Locke (Associate Member)	Locke & Locke Inc.	British Columbia	Non-Voting
E. Sopeju (Associate Member)	Underwriters Laboratories of Canada	Canada	Non-Voting
J. Su (Associate Member)	National Research Council Canada	Canada	Non-Voting
B. Weckman (Associate Member)	University of Waterloo	Ontario	Non-Voting
K. Wu (Project Manager)	ULC Standards	Canada	Non-Voting

This list represents the membership at the time the Committee balloted on the final text of this edition. Since that time, changes in the membership may have occurred.

STANDARD METHOD OF FIRE TEST OF FIRE DAMPER ASSEMBLIES

PREFACE

This is the Reaffirmation of the Third Edition of the Standard Method of Fire Test of Fire Damper Assemblies, CAN/ULC-S112.

This Edition of the Standard has been formally approved by the ULC Standards Committee on Fire Tests.

This Standard has been developed in compliance with the requirements of SCC for accreditation of a Standards Development Organization.

Only metric SI units of measurement are used in this Standard. If a value for measurement is followed by a value in other units in parentheses, the second value may be approximate. The first stated value is the requirement.

In Canada, there are two official languages, English and French. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require additional markings and/or installation instructions to be in both official languages.

The Third Edition of this National Standard of Canada has been reaffirmed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. ULC Standards shall not be held responsible for identifying any or all such patent rights.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

The review and action to revise or reaffirm this Standard will not exceed 5 years from the date of publication, unless the Standard is identified as fitting within a stabilized category, whereby the review will commence within the appropriate time frame set out by ULC Standards.

This Standard is intended to be used for conformity assessment.

Document ID: 123456789

1 SCOPE

1.1 These requirements and methods of test apply to *fire damper* assemblies rated $\frac{3}{4}$ h, 1 h, 1½ h, 2 h, or 3 h for use in air-conditioning and ventilating system ducts or openings (without ducts) piercing horizontally or vertically oriented fire separations where the fire separations are required to have a fire resistance rating of not more than 4 h.

1.2 These *fire damper* assemblies are intended for installation in accordance with the provincial or municipal building regulations that are based on the National Building Code of Canada.

1.3 Tests made in conformity with these test methods will register performance during the fire-test exposure under laboratory conditions; but such tests shall not be construed as determining suitability for use after exposure to fire.

1.4 It is the intent that tests made in conformity with these test methods will develop data to enable regulatory bodies to determine the suitability of damper assemblies for use in locations where fire resistance of a specified duration is required.

1.5 *Fire dampers* are evaluated for use as either:

- A *Fire Dampers* for Static Systems - For HVAC systems that are automatically shut down in the event of a fire or for air transfer openings in walls or partitions;
- B *Fire Dampers* for Dynamic Systems - For HVAC systems that are operational in the event of a fire.

1.6 A product whose features, characteristics, components, materials, or systems conflict with specific requirements or provisions of this Standard does not comply with this Standard.

2 REFERENCE PUBLICATIONS

2.1 The documents shown below are referenced in the text of this Standard. Unless otherwise stated elsewhere in this Standard such reference shall be considered to indicate the edition and/or revisions of the document available at the date on which the Committee approved this ULC Standard.

Standard Published by the Air Movement and Control Association International Inc. (AMCA)
30 West University Drive, Arlington Heights, Illinois, 60004 USA
Telephone: (847) 394-0150 or Fax: (847) 253-0171
www.amca.org

- AMCA Standard 500-D-98, Laboratory Methods for Testing Dampers for Rating

Documents Published by the American Society for Testing and Materials (ASTM)
100 Barr Harbour Drive, PO Box C700, West Conshohocken, PA 19428-2959 U.S.A.
Telephone: (610) 832-9585 or Fax: (610) 832-9555
www.astm.org

- ASTM A 90/A 90M-06, Standard Test Method for Weight [Mass] of Coating on Iron and Steel Articles with Zinc or Zinc-Alloy Coatings
- ASTM A 313/A 313M-02 (E 2003), Standard Specification for Stainless Steel Spring Wire