

**CAN/ULC-S112.2:2007-R2016
(Reaffirmed 2016)**

**STANDARD METHOD OF FIRE TEST OF CEILING FIRESTOP
FLAP ASSEMBLIES**

Prepared and Published by:



ULC Standards
Normes ULC

Approved by:



Standards Council of Canada
Conseil canadien des normes



Documents

Document Sharing Hub

Underwriters Laboratories of Canada (ULC) was established in 1920 by letters patent issued by the Canadian Government. It maintains and operates laboratories and certification services for the examination, testing and certification of appliances, equipment, materials, constructions and systems to determine their relation to life, fire and property hazards as well as providing inspection services.

Underwriters Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization, a Testing Organization, and an Inspection Body under the National Standards System of Canada.

ULC Standards develops and publishes standards and other related publications for building construction, security and burglar protection, environmental safety, electrical equipment, fire protection equipment, gas and oil equipment, thermal insulation products, materials and systems, energy use in the built environment and electrical utility safety.

ULC Standards is a not-for-profit organization and is accredited by the Standards Council of Canada as a Standards Development Organization.

National Standards of Canada developed by ULC Standards conform to the criteria and procedures established by the Standards Council of Canada. Such standards are prepared using the consensus principle by individuals who provide a balanced representation of interests relevant to the subject area on a national basis.

ULC is represented across Canada as well as many countries worldwide. For further information on ULC services, please contact:

Customer Service: 1-866-937-3852

National Standard of Canada

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations*, and *Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at www.scc.ca.

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

CORPORATE HEADQUARTERS

Underwriters Laboratories of Canada
7 Underwriters Road
Toronto, Ontario M1R 3A9
Telephone: (416) 757-3611
Fax: (416) 757-9540

REGIONAL OFFICES

PACIFIC OFFICE

13775 Commerce Parkway, Suite 130
Richmond, British Columbia V6V 2V4
Telephone: (604) 214-9555
Fax: (604) 214-9550

EASTERN OFFICE

6505, Rte Transcanadienne, Suite 330
St-Laurent, Québec H4T 1S3
Telephone: (514) 363-5941
Fax: (514) 363-7014

For further information on ULC standards, please contact:

ULC STANDARDS

171 Nepean Street, Suite 400
Ottawa, Ontario K2P 0B4
Telephone: (613) 755-2729
Fax: (613) 231-5977
E-mail: customerservice@ulc.ca
Web site: www.ulc.ca

The intended primary application of this standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

Copies of this National Standard of Canada may be ordered from ULC Standards.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

STANDARD METHOD OF FIRE TEST OF CEILING FIRESTOP FLAP
ASSEMBLIES

ICS 13.220.50; 91.060.30

Prepared and Published by:



Approved by:



First Edition.....January 1984
Second Edition.....October 2007
REAFFIRMED**APRIL 2016**

Copyright © 2016

ULC Standards

All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission.

AVADocuments.com

TABLE OF CONTENTS

ULC COMMITTEE ON FIRE TESTS	I
REFERENCE PUBLICATIONS	III
PREFACE	1
1. SCOPE.....	2
2. CONSTRUCTION	2
3. TESTS.....	3
4. FIRE ENDURANCE	3
4.1 TEST ASSEMBLIES	3
4.2 CONTROL AND CONDUCT OF FIRE TESTS	4
4.3 CONDITIONS OF ACCEPTANCE	5
5. CLOSING RELIABILITY TEST	5
6. DUST LOADING TEST	6
7. SALT-SPRAY EXPOSURE TEST.....	6
8. CORROSION RESISTANCE	6
8.1 ZINC COATINGS	6
8.2 CADMIUM COATINGS	8
9. SPRING CLOSING FORCE TEST	9
10. TEST REPORT	9
TABLES	11
FIGURES	18
APPENDIX A (INFORMATIVE)	22
A1 FURNACE CONTROL	22

11/11/2016 11:11:11 AM

ULC STANDARDS COMMITTEE ON FIRE TESTS

NAME	AFFILIATION	REGION	CATEGORY
A. Laroche (Chair)	Canadian Codes Centre, National Research Council Canada	Canada	Regulator
C. Andersson	Health Canada	Canada	Regulator
B. Bulley	Canadian Steel Door Manufacturers Association	Canada	Producer
B. Cheer	Ontario Building Officials Association	Ontario	Regulator
S. Craft	CHM Fire Consultants Ltd.	Ontario	General Interest
T. Crimi	A.C. Consulting Solutions Inc.	Ontario	General Interest
C. Dagenais	FPIInnovations	Canada	User
D. Falconer	Falconer Engineering & Testing	Ontario	General Interest
G. Frater	Canadian Steel Construction Council	Canada	Producer
G. Gardin	Canadian Plastics Industry Association	Canada	Producer
M. Gilfillan	Canadian Fire Safety Association	Canada	General Interest
G. Hadjisophocleous	Carleton University	Ontario	General Interest
L. Hamre	PLC Fire Safety Solutions	New Brunswick	General Interest
J. Humpries	City of Toronto	Ontario	Regulator
G. Loughheed	National Research Council Canada	Canada	User
M. McClure	ThermoFire Systems Inc.	Ontario	General Interest
R. McGrath	Cement Association of Canada	Canada	Producer
G. Morinville	National Defence and the Canadian Armed Forces	Canada	User
E. Randsalu	Office of the Fire Marshal and Emergency Management	Ontario	Regulator
J. Roberts	LRI Engineering Inc.	Canada	User
P. Shinkoda	CGC Inc.	Canada	Producer
I. Smith	Exova Canada Inc.	Canada	User
I. Van Zeeland	Canadian Wood Council	Canada	Producer
N. Benichou (Associate Member)	National Research Council Canada	Canada	Non-Voting
M. Birk (Associate Member)	Queen's University	Ontario	Non-Voting
L. Kearns (Associate Member)	National Defence and the Canadian Armed Forces	Canada	Non-Voting
K. Kooner (Associate Member)	Intertek	Canada	Non-Voting
H. Locke (Associate Member)	Locke & Locke Inc.	British Columbia	Non-Voting
E. Sopeju (Associate Member)	Underwriters Laboratories of Canada	Canada	Non-Voting
J. Su (Associate Member)	National Research Council Canada	Canada	Non-Voting
B. Weckman (Associate Member)	University of Waterloo	Ontario	Non-Voting
K. Wu (Project Manager)	ULC Standards	Canada	Non-Voting

This list represents the membership at the time the Committee balloted on the final text of this edition. Since that time, changes in the membership may have occurred.

REFERENCE PUBLICATIONS

The documents shown below are referenced in the text of this Standard. Unless otherwise stated elsewhere in this Standard such reference shall be considered to indicate the edition and/or revisions of the document available at the date on which the Committee approved this ULC Standard.

Documents Published by the American Society for Testing and Materials (ASTM)
100 Barr Harbour Drive, PO Box C700, West Conshohocken, PA 19428-2959 U.S.A.
Telephone: (610) 832-9585
www.astm.org

- A313/A313M-03, Standard Specification for Stainless Steel Spring Wire
- E11-04, Standard Specification for Wire Cloth and Sieves for Testing Purposes

Documents Published by Underwriters' Laboratories of Canada (ULC)
7 Underwriters Road, Toronto, ON M1R 3B4 Canada
Telephone: (416) 757-3611 or 1-866-9373-ULC
www.ulc.ca

- CAN/ULC-S101-07, Standard Methods of Fire Endurance Tests of Building Construction and Materials
 - ULC-S505, Standard for Fusible Links for Fire Protection Service
-

STANDARD METHOD OF FIRE TEST OF CEILING FIRESTOP FLAP ASSEMBLIES

PREFACE

This is the Reaffirmation of the Second Edition of the Standard Method of Fire Test of Ceiling Firestop Flap Assemblies, CAN/ULC-S112.2.

This Edition of the Standard has been formally approved by the ULC Standards Committee on Fire Tests.

This Standard has been developed in compliance with the requirements of SCC for accreditation of a Standards Development Organization.

Only metric SI units of measurement are used in this Standard. If a value for measurement is followed by a value in other units in parentheses, the second value may be approximate. The first stated value is the requirement.

Appendix A, identified as Informative, is for information purposes only.

In Canada, there are two official languages, English and French. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require additional markings and/or installation instructions to be in both official languages.

The Second Edition of this National Standard of Canada has been reaffirmed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. ULC Standards shall not be held responsible for identifying any or all such patent rights.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

The review and action to revise or reaffirm this Standard will not exceed 5 years from the date of publication, unless the Standard is identified as fitting within a stabilized category, whereby the review will commence within the appropriate time frame set out by ULC Standards.

This Standard is intended to be used for conformity assessment.

1. SCOPE

1.1 These requirements cover the test procedure for the performance evaluation of ceiling firestop flap assemblies which may or may not be part of an air diffusion device, intended for use in fire resistive floor-ceiling and roof-ceiling assemblies.

1.2 The purpose of the fire endurance test procedure which follows, is to supply information that may be used to compare the ability of a submitted ceiling firestop flap assembly to retard the transmission of heat to that of a "standard" ceiling firestop flap assembly. For the purposes of this document a "standard" ceiling firestop flap assembly shall be constructed as illustrated in Figure 1. Should it be necessary to evaluate other aspects of the intended performance of a submitted ceiling firestop flap assembly, it may be required that the submitted unit be incorporated in a full scale floor and ceiling assembly and tested in accordance with CAN/ULC-S101, Standard Methods of Fire Endurance Tests of Building Construction and Materials.

2. CONSTRUCTION

2.1 Ceiling firestop flap assemblies shall be constructed so as to provide an effective barrier to heat transmission in the closed position.

2.2 Pins, hinges and latches used in the assembly of a ceiling firestop flap shall be of material having resistance to atmospheric corrosion equivalent to brass or bronze.

2.3 Component springs used in the assembly of a ceiling firestop flap shall be of material having spring properties equivalent to stainless steel conforming to ASTM A313, Standard Specification for Chromium - Nickel Stainless and Heat-Resisting Steel Spring Wire.

2.4 Steel parts used in the assembly shall be provided with one of the following corrosion-protection systems:

- A Employing stainless steel having resistance to corrosion at least equal to the 300 series of stainless steel;
- B Coating of zinc capable of withstanding not less than two dips in a standard copper sulphate solution;
- C Coating of cadmium not less than 10 µm thick;
- D Two coats of good quality finish of the alkyd-resin type or other type outdoor paint. The suitability of the paint shall be determined by corrosion tests.

2.5 Coated or uncoated metals used in the assembly of ceiling firestop flaps shall not be used in combination such as to cause detrimental galvanic action which will adversely affect the function of any part of the assembly formed from such material.

2.6 A fusible link or other temperature-responsive device shall conform to the performance requirements of ULC-S505, Standard for Fusible Links for Fire Protection Service, except that such requirements may be modified if appropriate for the particular application.