

**CAN/ULC-S524:2014-AMD1
(Including Amendment 1)**

STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS

Prepared and Published by:



ULC Standards
Normes ULC

Approved by:



Standards Council of Canada
Conseil canadien des normes



Documents

Document Sharing Hub

Underwriters Laboratories of Canada (ULC) was established in 1920 by letters patent issued by the Canadian Government. It maintains and operates laboratories and certification services for the examination, testing and certification of appliances, equipment, materials, constructions and systems to determine their relation to life, fire and property hazards as well providing inspection services.

Underwriters Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization, a Testing Organization, and an Inspection Body under the National Standards System of Canada.

ULC Standards develops and publishes standards and other related publications for building construction, security and burglar protection, environmental safety, electrical equipment, fire protection equipment, gas and oil equipment, thermal insulation products, materials and systems, energy use in the built environment and electrical utility safety.

ULC Standards is a not-for-profit organization and is accredited by the Standards Council of Canada as a Standards Development Organization.

National Standards of Canada developed by ULC Standards conform to the criteria and procedures established by the Standards Council of Canada. Such standards are prepared using the consensus principle by individuals who provide a balanced representation of interests relevant to the subject area on a national basis.

ULC is represented across Canada as well as many countries worldwide. For further information on ULC services, please contact:

Customer Service: 1-866-937-3852

National Standard of Canada

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations*, and *Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at www.scc.ca.

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

CORPORATE HEADQUARTERS

Underwriters Laboratories of Canada
7 Underwriters Road
Toronto, Ontario M1R 3A9
Telephone: (416) 757-3611
Fax: (416) 757-9540

REGIONAL OFFICES

PACIFIC OFFICE

13775 Commerce Parkway, Suite 130
Richmond, British Columbia V6V 2V4
Telephone: (604) 214-9555
Fax: (604) 214-9550

EASTERN OFFICE

6505, Rte Transcanadienne, Suite 330
St-Laurent, Québec H4T 1S3
Telephone: (514) 363-5941
Fax: (514) 363-7014

For further information on ULC standards, please contact:

ULC STANDARDS

171 Nepean Street, Suite 400
Ottawa, Ontario K2P 0B4
Telephone: (613) 755-2729
Fax: (613) 231-5977
E-mail: customerservice@ulc.ca
Web site: www.ulc.ca

The intended primary application of this standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

Copies of this National Standard of Canada may be ordered from ULC Standards.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS

ICS 13.220.20; 13.320

Prepared and Published by:



Approved by:



First Edition February 1982
Second Edition April 1986
Third Edition May 1991
Fourth Edition February 2001
Fifth Edition December 2006
SIXTH EDITION JULY 2014
AMENDMENT 1 JANUARY 2016

Copyright © 2016

ULC Standards

All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission.

Copyright Underwriters' Laboratories of Canada

AMENDMENT NOTICE**ULC STANDARDS**

STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS	CAN/ULC-S524:2014
AMENDMENT 1	JANUARY 2016

The following amendments are being incorporated into CAN/ULC-S524:2014:

1. Revised Clause 4.2.1.1 and added a Note to permit wireless source of power supply consistent with Clause 4.6.3(D).
2. Revised Subsection 4.2.3, Emergency Power Supply, by revising Clause 4.2.3.2 and adding new Clauses 4.2.3.3 and 4.2.3.4, to be consistent with CAN/ULC-S527-11 Amendment 1, Standard for Control Units for Fire Alarm Systems, which allows for 4 h battery supervisory capacity.
3. Revised Clause 4.3.1.8 and added a new Clause 4.3.1.9, under Subsection 4.3, Electrical Supervision and 4.3.1, General, to further explain the electrical supervision requirements in Subsection 10.2.4, Field Device Power Buss Fault Isolator. Subsequent Clauses are renumbered, including the cross references therein.
4. Added new Clause 4.4.10 under Subsection 4.4, Wiring, and renumbered subsequent Clauses. Revised similar Clause 4.5.9 and added new Clause 4.5.10 under Subsection 4.5, Optical Fibre Cables, for clarity.
5. Clarified the criteria for Large Scale Network Systems, by revising Clause 5.8.1 under Subsection 5.8, Large Scale Network Systems, and the explanatory note in Appendix A, Clause A5.8.1, Campus Style Network.
6. Revised Clauses 5.8.5 to be consistent with CAN/ULC-S527-11 Amendment 1 for large scale networks.
7. Clarified Clauses 5.8.6 and 5.8.9 (now 5.8.10) to require stand-alone alternate page location only for high rise *buildings* as defined by the National Building Code of Canada.
8. Added a new Clause 5.8.7 to more adequately address the requirement to request, grant or deny control by a display and control centre. This Clause aligns with the existing requirement in CAN/ULC-S527-11 Amendment 1. Subsequent Clauses are renumbered.
9. Added new Clause 7.1.13, under Section 7, General Requirements of Fire Alarm System Devices, and Subsection 7.1, General, to require labels for supporting field devices.
10. Revised Clauses 8.2.3.1 and 8.2.3.2 and deleted Clause 8.2.3.3, under Subsection 8.2.3, Mounting of Fire Detectors, as well as the title of Figure 6, for consistency and clarity.
11. Added new Clause 8.3.4.3 under Subsection 8.3.4, Galleries, Mezzanine and Interior Balconies and new Figure 18.1 to better illustrate the requirement.
12. Added a new Subsection 8.3.14, Elevator and Dumbwaiter Shafts (Hoistways) under Subsection 8.3, Spot Type Fire Detectors, to expand the requirement contained in Clause 8.2.2.5.

13. Added the word “Locations” to the title of Subsection 9.2 to more accurately describe its contents.
14. Added a new Clause 9.4.19 and Note under Subsection 9.4, Visible Signal Devices (Strobe Lights) to provide detailed strobe intensity for devices installed in residential sleeping rooms. Revised Clause 9.4.1 to reference Clause 9.4.19.
15. Revised wording of, and added Notes in, Clause 10.2.1.3 under Subsection 10.2, Fault Isolators and 10.2.1, Field Device Data Fault Isolators, for greater clarity.
16. Revised Clause 10.2.4.1 under Subsection 10.2.4, Field Device Power Buss Fault Isolators, to correct the reference to Figures 33.1 to 33.4 into new Figure 33.5 instead.
17. Added a Note under Subsection 10.2.6, Suite Fault Isolators, and reference a new Appendix Note under Appendix A (Informative), Explanatory Materials, Clause A10.2.6, with its included Figure, to clarify wiring configurations for suite fault isolators.
18. Transferred Subsection 8.9, Fire Suppression Systems to a new Section 12, renamed, FIRE SUPPRESSION RELEASING SYSTEMS, to clarify and add new requirements.
 - 18.1 Added a new Subsection 12.1, General. Revised the title of previous Subsection 8.9.2 into new Subsection 12.3, Alarm Initiating Devices and Supervisory Devices for Suppression Systems.
 - 18.2 Added new Clause 12.3.1 and renumbered the rest of the Clauses and Subsections, including Appendix notes under Appendix A.
 - 18.3 Revised renumbered Clause 12.3.2 (formerly Clause 8.9.2.1), to clarify that covers only apply to certain alarm initiating devices.
 - 18.4 Revised Clauses 12.3.11 and 12.3.12, to reference new Figure 31.1.
 - 18.5 Revised wording of renumbered Clause 12.3.13 (formerly clause 8.9.2.12) for clarity. Renumbered Figure 31 to Figure 31.2 and revised the reference clause.
 - 18.6 Added new Subsections, 12.4, Notification Devices for Suppression Systems with explanatory note in Appendix A, Clause A12.4.4.
 - 18.7 Added new two new Subsections 12.5, Releasing Stations for Suppression Systems; and 12.6, Releasing Panels for Suppression Systems.
 - 18.8 Revised the reference clauses in Table 2 and Appendix F.
19. Revised Figures 2.4 and 2.6 to correctly illustrate the functions and features.
20. Revised Figures 21, Spacing of Spot Type Heat Detectors for Beam Construction, and Figure 24, Detector Spacing of Spot Type Smoke Detectors, to provide an isometric view for the spacing of spot type heat detectors and to correctly reflect the related Clauses.
21. Added new Figure 31.1 to illustrate the requirements in previous Clauses 8.9.2.10 and 8.9.2.11, now renumbered to Clauses 12.3.11 and 12.3.12 under Subsection 12.3, Alarm Initiating Devices and Supervisory Devices for Suppression Systems.

- 22. Renumbered Figure 31 to 31.2 and revised the reference Clause to 12.3.13.
- 23. Added new Figure 33.5, Installation of Power Buss Fault Isolator Serving Field Devices, to illustrate the requirement in Clause 10.2.4.1.
- 24. Created new Appendix Subsection A4.2.3.3, Uninterruptible Power Supplies (UPS) under Appendix A (Informative), Explanatory Materials, to provide guidance for installation of UPS and battery chargers.
- 25. Revised explanatory note in Appendix A, Clauses A5.8.1 and A5.8.7, to provide greater clarity.
- 26. Added four new Figures in Appendix A (Informative) Clause A10.2.6 on Examples of Wiring Configuration for Residential Notification Devices, to illustrate the requirement in Subsection 10.2.6-Note, Suite Fault Isolators.

NOTICE

PLEASE NOTE THAT THIS STANDARD INCLUDES AN AMENDMENT. THE CURRENT EDITION OF THIS STANDARD IS NOT VALID UNLESS USED TOGETHER WITH THE AMENDMENT.

IT IS POSSIBLE, HOWEVER, THAT CERTAIN CODES WILL REFER TO THE SUPERSEDED EDITION OF THIS STANDARD, WITHOUT THE AMENDMENT. IN THOSE INSTANCES, THE COMPILATION OF THIS DOCUMENT ALLOWS FOR REFERENCE TO BE MADE TO THE STANDARD PRIOR TO THE INCLUSION OF THE AMENDMENT.

No Text on This Page

Copyright Underwriters' Laboratories of Canada

AMENDMENT 1

4.2 POWER SUPPLY

4.2.1 General

4.2.1.1 Two independent power supplies shall be provided for the *fire alarm system*; one primary and one emergency, in accordance with the National Building Code of Canada.

NOTE: Battery operated wireless *field devices* in compliance with Subsection 4.6, Short-Range Radio Frequency Equipment (Wireless), are permitted to use the *field device* battery as the only source of power.

4.2.3 Emergency Power Supply

4.2.3.1 — *No change.* —

4.2.3.2 Where a *distributed type system* or *remote power supplies* are provided, with an internal battery in each *control unit*, *transponder* or *remote power supply*, and the battery provides supervisory capacity as specified in Clauses 4.2.3.3 and 4.2.3.4, the primary power may be taken from an essential *emergency power supply* if the fire alarm circuit is protected by separate over-current protectors and identified in accordance with CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Section 32. A label shall be installed at the main source with the following or similar wording:

- A “The fire alarm system power is supplied from the essential emergency power supply”; and/or
- B “L'alimentation du système d'alarme provient de l'alimentation de secours”.

4.2.3.3 When batteries are used for *emergency power supply*, they shall be sized to meet the following requirements:

- A 24 h of standby battery power plus the duration of rated alarm load if *emergency power supply* is provided entirely by the batteries; or
- B 4 h of standby battery power plus the duration of rated alarm load if *emergency power supply* is provided by an engine-driven generator.

NOTE: Where uninterrupted power supplies (UPS) are installed, refer to Appendix A (Informative), Explanatory Material, Clause A4.2.3.3.

4.2.3.4 The duration of the rated alarm load as described in Clause 4.2.3.3, shall be as required by the National Building Code of Canada.

4.3 ELECTRICAL SUPERVISION

4.3.1 General

4.3.1.8 Except as permitted in Clauses 4.3.1.10 and 4.3.1.11, where a power buss serves more than one National Building Code of Canada required fire alarm zone:

- A A single fault (open circuit fault, short circuit fault or ground fault) shall not prevent the normal operation of input or output field devices in more than one National Building Code of Canada required fire alarm zone; and
- B Shall comply with the same requirements as described in Clause 4.3.1.9.

NOTE: Refer to Appendix A (Informative) Explanatory Materials, Clause A4.3.1.8.

4.3.1.9 In Class A power buss, the primary wiring circuit and the alternate wiring circuit shall be installed in separate raceways or cable assemblies having a minimum separation of 300 mm where the cables are installed vertically and 1200 mm where the cables are installed horizontally (Refer to Figure 1.1), except under the following conditions:

- A Single conduit/raceway not exceeding 3000 mm in length to enclosures for control units, transponders, annunciators, display and control centres or remote power supplies. (Refer to Figure 1.2);
- B Single conduit/raceway drops to individual field devices (Refer to Figure 1.3); or
- C Single conduit/raceway drops to multiple field devices installed within a single room not exceeding 100 m² in area (Refer to Figure 1.4).

4.3.1.10 Except as permitted in Clause 4.3.1.11, where an audio buss serves more than one National Building Code of Canada required fire alarm zone, a single fault (open circuit fault, short circuit fault or ground fault) shall not prevent the normal operation of input or output field devices in more than one National Building Code of Canada required fire alarm zone.

4.3.1.11 Where equipment for control units or transponders is installed in multiple enclosures within the same room, wiring between these enclosures need not be electrically supervised where installed in metallic raceways not exceeding 18 m in length.

4.3.1.12 Where a power buss serves supporting field devices which are located within a common National Building Code of Canada required fire alarm zone but serve other National Building Code of Canada required fire alarm zones, the power buss segment serving these supporting devices is not required to comply with Clause 4.3.1.8.

4.3.1.13 Class A circuit with fault isolators installed in accordance with Subsection 10.2, Fault Isolators, or an equivalent method, shall be utilized to meet the requirements of Clauses 4.3.1.10 and 4.3.1.11.

NOTE: For data communication links, refer to Subsection 5.7.3, Field Device Data Communication Link.

4.4 WIRING

4.4.10 Where cables leave a building, non-current carrying conductive components shall be bonded as per CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Section 26.

4.4.11 When using shielded cable, the shield shall be:

- A Continuous and isolated from ground through all junction boxes;
- B Bonded in accordance with the manufacturer's published installation instructions; and

C Independent.

NOTE 1: Independent means the shields for groups of cables should not be commonly connected.

NOTE 2: The reason for this requirement is to prevent multiple ground loops that can disrupt proper system communications.

4.4.12 Shielded cable assemblies used for data communication links located in the same raceway shall each have a separate shielded wiring cable assembly unless individually shielded within a multiple conductor cable assembly.

4.4.13 Ancillary circuits shall not be used to activate circuits of a voltage level greater than 30 V directly within the control unit or transponder. Multiple voltage relays or devices, mounted external to the control unit or transponder, shall be utilized to activate circuits of a voltage level greater than 30 V.

4.5 OPTICAL FIBRE CABLES

4.5.9 Where electrically conductive lines, including an electrical conductive component of an *optical fibre cable*, leave a *building*, lightning arrestors and/or bonding shall be provided in accordance with CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Sections 26 and 56, and surge arrestor protection as per the manufacturer's published installation instructions.

4.5.10 Where optical fibre cables leave a *building*, non-current carrying conductive components shall be grounded in accordance with CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Sections 26 and 56.

5.8 LARGE SCALE NETWORK SYSTEMS

NOTE: Refer to Appendix A (Informative) Explanatory Materials, Clause A5.8, Campus Style Network, for good engineering practices or design guidance where these systems are applied to campus style network.

5.8.1 *Fire alarm systems* that utilize more than one *control unit* or *transponder* and meet one or more of the following criteria, shall comply with the requirements of this Subsection:

- A Contains more than 1000 total active *field devices*, *supporting field devices*, and *fire detectors* (see Appendix A (Informative), explanatory Materials, Clause A5.8.1 with respect to campus style *fire alarm systems*); or
- B Are located in a *building* within the scope of Subsection 3.2.6 of the National Building Code of Canada.

5.8.5 Each *control unit* and *transponder* shall have signal silence, reset and trouble silence switches with visual indicators, degraded mode, and stand-alone capability indicators. Except at the primary *display and control centre(s)*, signal silence and reset are only active in degraded and stand-alone mode.

5.8.6 *Buildings* equipped with *voice communication* systems that are required by the National Building Code of Canada, shall have at least one *control unit* or *transponder* in addition to the primary *display and control centre*, incorporating the following:

- A Annunciation capability as required by the National Building Code of Canada;
- B A means to transmit voice messages (where applicable); and
- C A minimum of one "All Call" switch to enable voice messages to be transmitted (where applicable).

5.8.7 Where multiple display and control centres incorporate voice alarm features, are provided, the following shall also apply:

- A Manual controls and voice alarm features can only be operated from one location at any given time;
- B Indication shall be provided continuously displayed at all display and control centres as to which is in control, either by a dedicated indicator or a text message where alphanumeric displays are used;
- C Complete loss of communication to the display and control centre shall not inhibit other communicating display and control centres from being able to gain control; and
- D Ability to request, grant, or deny system control with provision for fail-safe auto-transfer from one command centre to another shall be provided.

5.8.8 Each *control unit* and *transponder* shall be located in a suitable service room and/or *central alarm and control facility*, separated from the remainder of the *building* by a minimum 1 h fire separation.

NOTE 1: Suitable service rooms may include, but are not limited to, a dedicated fire alarm room, electrical room, telecommunication room or information technology server room, but should not include rooms with significant combustible materials, hazardous equipment or high voltage equipment installations. Refer also to Clause 5.1.9.

NOTE 2: Refer to requirements for the protection of electrical conductors in the National Building Code of Canada. See also Appendix A (Informative) Explanatory Materials, Clause A5.8.8.

NOTE 3: Multiple *control units* or *transponders* installed in the same room within 18 m of each other, which are interconnected to operate as a single unit, may be considered as a single *control unit* or *transponder* to meet the requirement of Clause 5.8.8.

5.8.9 Each *control unit* and *transponder* shall contain audio amplifiers where voice communication capability is provided.

5.8.10 Each *control unit* and *transponder* shall provide *alert* and *alarm signal* tone generators or digitized voice messages as required by the system operation sequence for stand-alone mode operation.

7 GENERAL REQUIREMENTS OF FIRE ALARM SYSTEM DEVICES

7.1 GENERAL

7.1.13 Each *supporting field device*, regardless of installation location, shall have an identifying label securely attached so that it is visible in the installed position, identifying the system or function served.

Exception: Where a supporting field device serves a single field device, and is installed within the same enclosure as that field device, labelling is not required.

8.2 GENERAL REQUIREMENTS FOR FIRE DETECTORS

8.2.3 Mounting of Spot Type Fire Detectors

8.2.3.1 Spot type *fire detectors* shall be mounted on the ceiling except as otherwise permitted in this Standard.

8.2.3.2 Spot type *fire detectors* may be installed on the wall between 100 mm and 300 mm from the ceiling, measured to the top edge of the detector. (Refer to Figure 6).

8.3 SPOT TYPE FIRE DETECTORS

8.3.4 Galleries, Mezzanine and Interior Balconies

8.3.4.3 *Smoke detectors* installed in compliance with the requirements of Subsection 3.2.4 of the National Building Code shall be installed within 300 mm of the opening through the floor assembly and shall be spaced at a maximum spacing of 4.6 m. Refer to Figure 18.1.

8.3.14 Elevator And Dumbwaiter Shafts (Hoistways)

8.3.14.1 A *fire detector* required in a shaft by the National Building Code of Canada shall be mounted at the highest point of the shaft.

8.3.14.2 *Heat detectors* installed in the bottom of a shaft (pit) shall be mounted between 100 mm and 300 mm below the lowest point of travel of each car within the shaft.

NOTE: *Heat detectors* installed within shafts can be mechanically affixed to a bracket in a ceiling-mounted orientation or mounted in a side wall orientation.

8.3.14.3 In lieu of spot type heat detection, linear heat detection cable installed around the inside perimeter of the shaft enclosure may be used to protect the bottom of a shaft (pit) per Clause 8.3.14.2.

9.1 GENERAL

9.1.7 Except as permitted in Clause 12.4.5, *audible signal devices* within a *building* shall generate similar sounds and sound patterns when activated.

9.2 AUDIBLE SIGNAL DEVICE LOCATIONS

9.4 VISIBLE SIGNAL DEVICES (STROBE LIGHTS)

9.4.1 Except as noted in Clause 9.4.19, the effective luminous intensity of each strobe light shall be rated not less than 15 candela (cd).

9.4.19 Where *visible signal devices* are installed in sleeping rooms, each *visible signal device* shall have a minimum candela rating of 177 cd where the device is installed less than 610 mm from the ceiling and a minimum candela rating of 110 cd for all other locations.

NOTE: The *visible signal device* should be located within 4.87 m of the pillow.

10.2 FAULT ISOLATORS

10.2.1 Field Device Data Fault Isolators

10.2.1.3 Data *fault isolators* required by Clause 10.2.1.2 are not required:

- A Between *field devices* located within the same floor area that are monitoring mechanical equipment serving other floor areas; and

NOTE: For example, *water flow devices* on sprinkler systems or duct type *smoke detectors* on HVAC systems serving other floor areas are considered part of the same area specified in Clause 10.2.1.2 and need not be separately fault isolated from other devices within that area.

- B Between *field devices* located within the same floor area, that are monitoring equipment on the same floor.

NOTE: For example, fire suppression system within the same floor area that may be separately annunciated need not be separately fault isolated from other devices within that area.

10.2.4 Field Device Power Buss Fault Isolators

10.2.4.1 This Subsection applies to the installation of *power buss fault isolators* as required by Clause 4.3.1.8 for power busses serving *field devices*. (Refer to Figure 33.5.)

NOTE 1: Where available, *power buss fault isolators* should be located in a fire separated electrical room.

NOTE 2: Refer to Appendix A (Informative) Explanatory Materials, Clause 10.2.4.1.

10.2.6 Suite Fault Isolators

10.2.6.1 This Subsection applies to the installation of *suite fault isolators* where provided as one option to meet the requirements of the National Building Code of Canada for notification appliances serving residential or care occupancies.

NOTE 1: Supervision for open circuit, ground fault and short circuit fault shall be maintained in each defined suite where suite fault isolation is used

NOTE 2: Refer to Appendix A (Informative), Explanatory Materials, Clause A10.2.6 for alternate methods to comply with the National Building Code of Canada requirements for notification appliances serving residential occupancies.

8.9 FIRE SUPPRESSION SYSTEMS – this subsection has been replaced with new Section 12, and revised. See below.

12 FIRE SUPPRESSION RELEASING SYSTEMS

12.1 GENERAL

12.1.1 Except as detailed within this Section, *fire alarm system* equipment installed for the detection, notification, and control of fire suppression systems shall be installed in accordance with the applicable requirements for *fire alarm systems*, as detailed elsewhere in this Standard.

12.1.2 Each releasing device (e.g., solenoid, relay) and *circuit* provided for use with a fire suppression system releasing shall be electrically supervised.

12.2 FIRE DETECTOR FOR SUPPRESSION RELEASING

12.2.1 In addition to the requirements for *fire detector* spacing detailed elsewhere in the Standard, where two or more *fire detectors* are required to activate for the release of a suppression system, *detector spacing* shall be reduced in accordance with good engineering practice. See Appendix A (Informative) Explanatory Materials, Clause A12.2.1.

NOTE: An alarm initiated by the first *fire detector* shall put the *fire alarm system* in an alarm or alert condition. See Clause 12.3.1.

12.2.2 Where *fire detectors* provided with pre-alarm functions (e.g. laser spot-type *smoke detectors* or air sampling-type detectors) are used for the releasing of suppression systems, the fire detection threshold to activate the release of the suppression system shall be in accordance with good engineering practice. See Appendix A (Informative) Explanatory Materials, Clause A12.2.2.

NOTE: Where *fire detectors* are provided with pre-alarm functions, signaling and annunciation should be in accordance with good engineering practice.

12.3 ALARM INITIATING DEVICES AND SUPERVISORY DEVICES FOR SUPPRESSION SYSTEMS

NOTE: Refer to Appendix F (Informative), Base Building Annunciation for High Value Asset Fire Protection Systems.

12.3.1 Activation of suppression systems shall be annunciated at the base *building fire alarm system*.

NOTE: Where fire detectors are provided with pre-alarm functions, signaling and annunciation shall be in accordance with good engineering practice.

12.3.2 Where alarm initiating devices and *supervisory devices* require adjustment, they shall be installed so as to permit the removal of covers for adjustment purposes.

12.3.3 *Water flow devices* shall be installed to ensure activation within 90 s of water flowing in the system that is equal to or greater than that of a single sprinkler of the smallest orifice size installed on the system. Refer to Appendix A (Informative) Explanatory Materials, Clause A12.3.3.

12.3.4 *Water flow devices* incorporating an adjustable time delay shall be set with a sufficient delay to reduce the possibility of a false indication (e.g. caused by water hammer).

12.3.5 *Supervisory devices* shall be connected to a latching type supervisory circuit of a *control unit* or *transponder*.

12.3.6 *Supervisory devices* shall be wired to allow the circuit operation to differentiate between an open circuit wiring fault and the operation of a device.

12.3.7 A *supervisory device* used to monitor the position of a valve handle, shall be set to operate within two turns of the valve handle or when the stem of the valve has moved 20% of the distance from its normal open position.

12.3.8 A *supervisory device* used to monitor the position of a valve handle, shall remain activated while the valve is in any off-normal position.

12.3.9 Where actuating lever type *supervisory devices* cannot be used, plug type switches may be used, provided:

- A The cable is tight when plugged in normal position; and
- B The supervisory circuit operates on one-half turn of the valve handle.

12.3.10 Water temperature type *supervisory devices* shall be set to provide an indication of low water temperature that could affect operation of the system. The set temperature shall be suited to site conditions but shall not be any lower than 4 °C.

12.3.11 *Tamper devices*, where utilized with alarm initiating devices, shall be wired so that the activation of the *tamper device* shall cause a *trouble signal* and shall not prevent the reception of an alarm from any alarm initiating device on that *circuit*. Refer to Figure 31.1.

12.3.12 *Tamper devices*, where utilized with *supervisory devices*, shall be wired so that the activation of the *tamper device* shall cause a *trouble signal* and shall not prevent the reception of a supervisory function indication from any *supervisory device* on that circuit. Refer to Figure 31.1.

12.3.13 *Supporting field devices* not installed in fire protection equipment rooms (e.g., sprinkler and fire pump rooms) and not installed in exit stair shafts shall be installed in the same floor area which the fire suppression system devices serve. Refer to Figure 31.2.

12.4 NOTIFICATION DEVICES FOR SUPPRESSION SYSTEMS

12.4.1 Notification devices provided for local notification of fire suppression system operation shall be installed in accordance with the requirements detailed elsewhere in the Standard, as appropriate for the device type.

12.4.2 Notification devices provided to warn occupants within the protected space of the activation of the suppression system shall be installed within the protected space and shall initiate upon activation of the first *fire detector*.

12.4.3 Notification devices provided to warn persons not to enter a protected space due to suppression system activation shall be installed within the protected space and shall initiate upon activation of the first *fire detector*.

12.4.4 Where notification devices to warn occupants to evacuate a protected space and not to enter a protected space are provided, each type of notification device shall provide unique notification. Refer to Appendix A (Informative), Explanatory Materials, Clause A12.4.4.

12.4.5 *Audible signal devices* providing local notification of fire suppression system operation shall produce a sound that is different from the base *building fire alarm system audible signal devices*.

12.4.6 *Visible signal devices* providing local notification of fire suppression system operation shall produce a visual signal that is different from the base *building fire alarm system visible signal devices*, or be labelled or provided with signage to indicate they are unique signal devices.

12.5 RELEASING AND ABORT STATIONS FOR SUPPRESSION SYSTEMS

12.5.1 Releasing stations for manual activation of suppression systems shall be installed in accordance with the appropriate requirements for *manual stations*, as detailed elsewhere in the Standard.

12.5.2 Releasing stations shall be of a unique appearance and colour from base *building fire alarm manual stations*, and shall comply with the requirements of CAN/ULC-S528, Standard for Manual Stations for Fire Alarm Systems, Including Accessories.

12.5.3 Abort stations shall be of a constant pressure type and comply with the requirements of CAN/ULC-S527, Standard for Manual Stations for Control Units for Fire Alarm Systems, Subsection 4.25.2.3, Abort Feature.

12.6 RELEASING PANELS FOR SUPPRESSION SYSTEMS

12.6.1 *Control units* installed to provide releasing service (releasing panels) for fire suppression system operation shall be installed in accordance with the requirements for *control units* and *transponders*, as detailed elsewhere in the Standard.

12.6.2 Releasing panels shall be annunciated for alarm, supervisory, and trouble conditions, as appropriate, at the base *building fire alarm system*.

12.6.3 Where releasing panels are installed in *buildings* not required to be provided with a *fire alarm system*, alarm, supervisory, and trouble conditions shall be annunciated at the releasing panel.

12.6.4 Each releasing panel shall be provided with a physical disconnect switch to allow testing without actuation of the fire suppression system(s) controlled by the releasing panel. Activation of the switch shall cause a non-latching *supervisory signal* on the base *building fire alarm system*.

12.6.5 The sequence of operation for the releasing panel shall be consistent with the requirements of the applicable Codes and Standards for the controlled fire suppression system, and good engineering practices.

TABLE 2


RESPONSE TIMES FOR CONTROL UNITS AND TRANSPONDERS

(Reference: Clauses 4.1.10, 4.1.11, 4.6.6-Note, Clause 5.1.10, Table 3, Clause A12.3.3)

FIGURES

FIGURE 2.4
EXAMPLE OF FAULT ISOLATOR SERVING A SINGLE FIELD DEVICE IN AN EXIT STAIR

(Reference: Clause 5.7.1.1-Note, 10.2.1.9-Note and Table 3)




DCLC - - - - - CONVENTIONAL CIRCUIT ——— ZONE DELINEATION == ==

	ADDRESSABLE CONTROL DEVICE		BIDIRECTIONAL ISOLATION MODULE		ADDRESSABLE SMOKE DETECTOR		END OF LINE DEVICE
	ADDRESSABLE MONITOR DEVICE		SUPERVISED VALVE		ADDRESSABLE HEAT DETECTOR		JUNCTION BOX
	EXHAUST DAMPER		WATER FLOW SWITCH		ADDRESSABLE MANUAL STATION		BREAK LINE (CONTINUATION)

su2263

FIGURE 2.6
FLOOR DATA COMMUNICATION LINK B (DCLB) CIRCUITS CONNECTED TO DATA
COMMUNICATION LINK A (DCLA) INSTALLED IN A SINGLE FIRE-RATED ELECTRICAL ROOM

(Reference: Clause 5.7.1.1-Note)



DCL - - - - - CONVENTIONAL CIRCUIT ——— WALL ——— ZONE DELINEATION ——— =

CTL	ADDRESSABLE CONTROL DEVICE	ISO	BIDIRECTIONAL ISOLATION MODULE	⊗	ADDRESSABLE SMOKE DETECTOR	EOL	END OF LINE DEVICE
MON	ADDRESSABLE MONITOR DEVICE	SV	SUPERVISED VALVE	◐	ADDRESSABLE HEAT DETECTOR	JB	JUNCTION BOX
⌵	EXHAUST DAMPER	FS	WATER FLOW SWITCH	◑	ADDRESSABLE MANUAL STATION	⚡	BREAK LINE (CONTINUATION)


su2264

FIGURE 6**INSTALLATION OF SPOT TYPE FIRE DETECTORS**

(Reference: Clause 8.2.3.2)

**FIGURE 18.1
DETECTOR SPACING OF SMOKE DETECTORS: GALLERIES, MEZZANINE AND INTERIOR
BALCONIES**


(Reference: Clause 8.3.4.3)



su2262

FIGURE 21
SPACING OF SPOT TYPE HEAT DETECTORS FOR BEAM CONSTRUCTION



(Reference: Clause 8.3.10.2)



su2265

FIGURE 24
DETECTOR SPACING OF SPOT TYPE SMOKE DETECTORS


(Reference: Clause 8.3.10.9)



su2266

FIGURE 31.1
EXAMPLE OF TAMPER DEVICE SERVING FIRE SUPPRESSION SYSTEM

(Reference: Clauses 12.3.11 and 12.3.12)



LEGEND:
 N.C. = Normally Closed
 N.O. = Normally Open


su2267

LEGEND:

N.C. = Normally Closed

N.O. = Normally Open

FIGURE 31.2
EXAMPLE OF SUPPORTING FIELD DEVICES SERVING FIRE SUPPRESSION SYSTEM
(Reference: Clause 12.3.13)




su2268

FIGURE 33.5
INSTALLATION OF POWER BUSS FAULT ISOLATOR SERVING FIELD DEVICES


(Reference: Clause 10.2.4.1)

A. POWER BUSS FAULT ISOLATOR ON POWER CIRCUIT



CTL	ADDRESSABLE CONTROL DEVICE	ISO	BIDIRECTIONAL ISOLATION MODULE	⊗	ADDRESSABLE SMOKE DETECTOR	EOL	END OF LINE DEVICE
MON	ADDRESSABLE MONITOR DEVICE	SV	SUPERVISED VALVE	⊙	ADDRESSABLE HEAT DETECTOR	JB	JUNCTION BOX
⌵	EXHAUST DAMPER	FS	WATER FLOW SWITCH	◼	ADDRESSABLE MANUAL STATION	⌵	BREAK LINE (CONTINUATION)

su2269

B. NO ISOLATOR ON POWER CIRCUIT

DCLC - - - - -

POWER CIRCUIT ———

ZONE DELINEATION == ==

CTL	ADDRESSABLE CONTROL DEVICE	ISO	BIDIRECTIONAL ISOLATION MODULE	ADDRESSABLE SMOKE DETECTOR	END OF LINE DEVICE
MON	ADDRESSABLE MONITOR DEVICE	SV	SUPERVISED VALVE	ADDRESSABLE HEAT DETECTOR	JUNCTION BOX
EXHAUST DAMPER		FS	WATER FLOW SWITCH	ADDRESSABLE MANUAL STATION	BREAK LINE (CONTINUATION)

su2270

NOTE: Refer to the manufacturer's published installation instruction in regard to separation of riser wiring.

A APPENDIX A (INFORMATIVE) – EXPLANATORY MATERIALS

A4.2.3.3 Uninterruptable Power Supplies (UPS)

Uninterruptable power supplies (UPS) should be installed in accordance with CSA C22.1, Canadian Electrical Code, Part I, Safety Standard for Electrical Installations, Section 46 - Emergency Power Supply, Unit Equipment, Exit Signs, and Life Safety Systems.

A warning condition from the UPS system should provide a non-latching *supervisory signal* on the *fire alarm system* indicating a common UPS system fault condition.

Loss of primary power to the UPS system should provide a non-latching *supervisory signal* on the *fire alarm system* indicating a loss of primary power.

The disconnecting means for a UPS system should be fitted with a locking device to prevent unauthorized operation.

The input and output of a UPS system should be permanently connected except where the UPS system and the connections are provided in a lockable enclosure.

A5.8 LARGE SCALE NETWORK SYSTEMS

A5.8.1 CAMPUS STYLE NETWORK

There are instances where multiple *buildings* or structures, which are protected by individual *fire alarm control units* and *transponders*, are served by a common *fire alarm network*. In these applications, only *control units* and *transponders* connected with DCLC are permitted to provide control functions. Where *control units* and *transponders* are connected by DCLB or DCLA, they are permitted to provide monitoring function only. Refer to Figures 4.1 and 4.2.

In the determination for the application of Large Scale Network requirements, all *active field devices*, *supporting field devices*, and *fire detectors* connected to a *fire alarm system* are required to be counted. This includes where a *fire alarm system* covers multiple *buildings* and / or facilities. For example, a *fire alarm system* serving a main *building* and ancillary *buildings* on the same property would require all devices in all *buildings* to be counted.

For specific consideration are campus style *fire alarm systems*, such as those common in post-secondary institutions or large business facilities. These systems commonly cover multiple *buildings* with a common communication network which interconnect the *building fire alarm systems*. When considering if these campus *fire alarm systems* are to meet the large scale network requirements, the type of common communication network needs to be reviewed.

Where the network is provided only for supervision (i.e., to a campus security office), this network does not create a common *fire alarm system* between the various campus *buildings*. Rather, the network is for monitoring only and allows each *building fire alarm system* to function independently. In this case, the *active field devices*, *supporting field devices*, and *fire detectors* for each individual *fire alarm system* are to be considered independently. Where this common supervision also provides the connection to a *fire signal receiving centre* for the purposes of sending a signal to the local fire department, and directly, or indirectly to a *fire signal receiving centre*, the requirements of CAN/ULC-S561 are also applicable.

Where the network is provided with command and control functions, this type of network creates a common *fire alarm system* throughout the campus. As such, all *active field devices*, *supporting field devices*, and *fire detectors* on the network are required to be counted. With these types of systems, the *design* professionals should consider, in conjunction with the *authorities having jurisdiction*, the appropriateness of this type of system for the campus.

NOTE: For additional information on controls, refer to Clauses 5.2.9 through 5.2.11.

In applying the requirements for Large-Scale Networks to campus style *fire alarm systems*, the requirements of Subsection 5.8, Large Scale Network Systems, are to be assessed to determine applicability and appropriateness for the system. For example, the requirement to locate network conductors in fire rated enclosures or to provide fire rated conductors may not be appropriate. In many campus style systems, network conductors are installed in below-grade raceways. In these situations, an equivalent fire protection may be achieved by the installation methodology.


A5.8.8

In order to ensure continuous operation of the *fire alarm* and *voice communication* systems in a “High Building” for a sufficient duration of time to control and direct the evacuation of building occupants, a level of protection is required by the National Building Code of Canada, for those electrical conductors interconnecting the major elements of the *fire alarm system*. These requirements are in addition to the requirements of Subsection 5.8, Large Scale Network Systems.


NOTE: Requirements for “High Buildings” are described in the National Building Code of Canada.

A10.2.6 EXAMPLES OF WIRING CONFIGURATIONS FOR RESIDENTIAL NOTIFICATION DEVICES



Copyright Underwriters' Laboratories of Canada
Provided by IHS Markit under license with ULC
No reproduction or networking permitted without license from IHS

A. ADDRESSABLE SIGNAL DEVICES ON DCL WITH LOW VOLTAGE POWER SUPPLY CIRCUIT

NOTE: This example represents one way of meeting the requirement but there may be other methods that are also acceptable.

B. SIGNAL DEVICES ON SEPARATE CIRCUITS

NOTE 1: Circuits wired back to *control unit or transponder*.

C. CLASS B CIRCUIT WITH SUITE FAULT ISOLATORS**D. CLASS A CIRCUIT FOR IN-SUITE SIGNALS**

A12.2.1

It is common practice to use the cross-zone, counting zone or priority matrix features of the *control unit* or *transponder* for releasing fire suppression systems.

A12.2.2

Air sampling-type detectors can provide multiple thresholds of smoke detection. Some levels may be used for pre-alarm notification, while higher smoke obscuration levels may be used for alarm activation. While suppression system release may be activated by a higher smoke obscuration level, the fire detection threshold for the activation of the *building fire alarm system* must be in accordance with CAN/ ULC-S529, Standard for Smoke Detectors for Fire Alarm Systems.

A12.3.3

The 90 s duration is from the start of the water flow to the activation of the *water flow device*. The response time of the *fire alarm system* after activation of the *water flow device* shall be in accordance with Table 2, Response Times for Control Units and Transponders.

A12.4.4

Where notification devices to warn occupants to evacuate a protected space and not to enter a protected space are provided, each type of notification device shall provide unique notification. For example, in a *building* where the base *building fire alarm system* utilizes horns for occupant notification, the notification devices installed to warn persons within the protected space of the activation of the suppression system could be bells and the notification devices installed to warn persons not to enter the protected space could be *visible signal devices*.

F APPENDIX F (INFORMATIVE) – BASE BUILDING ANNUNCIATION FOR HIGH VALUE ASSET FIRE PROTECTION SYSTEMS

(Reference: Subsection 12.3)

No Text on This Page

TABLE OF CONTENTS

ULC STANDARDS COMMITTEE ON FIRE ALARM AND LIFE SAFETY EQUIPMENT AND SYSTEMS	I
ULC STANDARDS SUBCOMMITTEE ON INSTALLATION, INSPECTION AND VERIFICATION OF FIRE ALARM SYSTEMS	II
ULC STANDARDS WORKING GROUP ON INSTALLATION OF FIRE ALARM SYSTEMS	III
PREFACE	IV
1 SCOPE	1
2 REFERENCE PUBLICATIONS	1
3 GLOSSARY	3
4 REQUIREMENTS OF FIRE ALARM SYSTEMS	9
4.1 GENERAL	9
4.2 POWER SUPPLY	11
4.2.1 General	11
4.2.2 Primary Power Supply	11
4.2.3 Emergency Power Supply	12
4.2.4 Engine-Driven Generators	12
4.3 ELECTRICAL SUPERVISION	12
4.3.1 General	12
4.3.2 Trouble Signals	14
4.4 WIRING	14
4.5 OPTICAL FIBRE CABLES	16
4.6 SHORT-RANGE RADIO FREQUENCY EQUIPMENT (WIRELESS)	16
4.7 PLANS AND SPECIFICATIONS	17
5 INSTALLATION OF FIRE ALARM EQUIPMENT	18
5.1 CONTROL UNITS AND TRANSPONDERS	18
5.2 ANNUNCIATORS AND DISPLAY AND CONTROL CENTRE	19
5.3 CONTROL SWITCHES	20
5.4 ANCILLARY DISPLAY	20
5.5 REMOTE POWER SUPPLIES	20
5.6 BATTERIES	21
5.7 DATA COMMUNICATION LINK (DCL)	21
5.7.1 General	21
5.7.2 Network Data Communication Link	22
5.7.3 Field Device Data Communication Link	22
5.8 LARGE SCALE NETWORK SYSTEMS	23
6 VOICE COMMUNICATION	24
6.1 GENERAL	24
6.2 AUTOMATED VOICE	25

6.3	EMERGENCY TELEPHONES	25
7	GENERAL REQUIREMENTS OF FIRE ALARM SYSTEM DEVICES	26
7.1	GENERAL	26
7.2	PROTECTIVE COVERS AND ACCESSORIES	26
8	INITIATING AND INPUT DEVICES	27
8.1	MANUAL STATIONS	27
8.2	GENERAL REQUIREMENTS FOR FIRE DETECTORS	27
8.2.1	General	27
8.2.2	Mounting of Fire Detectors	28
8.2.3	Mounting of Spot Type Fire Detectors	28
8.3	SPOT TYPE FIRE DETECTORS	29
8.3.1	Smooth Ceiling Spacing	29
8.3.2	Sloped Ceiling Spacing	29
8.3.3	Ceiling Height Variations	30
8.3.4	Galleries, Mezzanine and Interior Balconies	30
8.3.5	Partitions	30
8.3.6	Corridors	30
8.3.7	Special Applications	30
8.3.8	High Ceilings	30
8.3.9	Solid Joist Construction	31
8.3.10	Beam Construction	31
8.3.11	Exit Stair Shafts	33
8.3.12	High Air Movements and Humidity	33
8.3.13	Raised Floors and Suspended Ceilings	33
8.4	MULTI-SENSOR DEVICES	33
8.5	AIR DUCT TYPE SMOKE DETECTORS	33
8.6	BEAM TYPE SMOKE DETECTORS	34
8.7	AIR SAMPLING TYPE DETECTORS	34
8.8	FLAME SENSING DETECTORS	35
8.9	FIRE SUPPRESSION SYSTEMS	35
8.9.1	Fire Detector For Suppression Releasing	35
8.9.2	Alarm Initiating Devices And Supervisory Devices For Extinguishing Systems ..	35
8.10	OTHER FIRE DETECTORS	36
9	NOTIFICATION AND OUTPUT DEVICES	37
9.1	GENERAL	37
9.2	AUDIBLE SIGNAL DEVICES	37
9.3	AUDIBLE SIGNAL DEVICES IN SUITES OF RESIDENTIAL OCCUPANCY	38
9.4	VISIBLE SIGNAL DEVICES (STROBE LIGHTS)	38
9.5	COMBINATION AUDIBLE / VISIBLE SIGNAL DEVICE (STROBE LIGHTS)	39
9.6	STROBE SYNCHRONIZATION MODULES	40
9.7	FIRE DO NOT ENTER SIGNS	40
9.8	DIRECTIONAL SIGNS FOR EVACUATION	40
10	OTHER FIRE ALARM SYSTEM DEVICES	41
10.1	END-OF-LINE DEVICES	41
10.2	FAULT ISOLATORS	41

10.2.1 Field Device Data Fault Isolators	41
10.2.2 Network Data Fault Isolators	42
10.2.3 Audio Buss Fault Isolators	42
10.2.4 Field Device Power Buss Fault Isolators	43
10.2.5 Equipment Power Buss Fault Isolators	44
10.2.6 Suite Fault Isolators	44
10.3 DOOR HOLDERS (HOLD-OPEN DEVICES) AND DOOR CLOSERS	44
11 INTERCONNECTION TO THE FIRE SIGNAL RECEIVING CENTRE	45
TABLES	46
FIGURES	50
APPENDIX A (INFORMATIVE) - EXPLANATORY MATERIALS	99
APPENDIX B (INFORMATIVE) - SUGGESTED WIRING AND INSTALLATION GUIDE	110
APPENDIX C (INFORMATIVE) - SOUND LEVEL MEASUREMENTS	111
C1 SOUND LEVEL MEASURING DEVICES	111
C2 MEASUREMENT METHOD	111
C3 SELECTING TEST AREA	111
C4 AMBIENT NOISE LEVEL MEASUREMENTS	111
APPENDIX D (INFORMATIVE) - STROBE LIGHTS	119
APPENDIX E (INFORMATIVE) - RESPONSIBILITY DEMARCATIONS FOR INTERCONNECTION OF FIRE SIGNAL RECEIVING CENTRE	121
APPENDIX F (INFORMATIVE) - BASE BUILDING ANNUNCIATION FOR HIGH VALUE ASSET FIRE PROTECTION SYSTEMS	124

AVADocuments.com

ULC STANDARDS COMMITTEE ON FIRE ALARM AND LIFE SAFETY EQUIPMENT AND SYSTEMS

NAME	AFFILIATION	REGION	CATEGORY
A.M. Leber (Chair)	LRI Engineering Inc.	Canada	General Interest
S. Ames	System Sensor Canada	Canada	Producer
D. Boynowski	Siemens Canada Ltd.- Building Technologies	Canada	Producer
P. Clarke	Department of National Defence	Canada	User
S. Crosby	Jensen Hughes Consulting Canada Ltd.	Canada	General Interest
D. Delen	Morrison Hershfield Limited	Canada	General Interest
D. Duggan	Fire Detection Devices Ltd.	Canada	Producer
L. Eisner	Mircom Technologies Ltd.	Canada	Producer
G. Fawcett	Society of Fire Protection Engineers, Southern Ontario Chapter	Ontario	General Interest
M. Fortin	National Research Council of Canada	Canada	General Interest
B. Fremis	Defence Construction Canada	Canada	General Interest
W.D. Goodyear	D. Goodyear Fire Consulting	Canada	General Interest
D. Hollingshead	Canadian Security Association	Canada	User
R. Jagmohan	Honeywell Security and Custom Electronics	Canada	Producer
K. Jess	Alberta Municipal Affairs	Alberta	Regulator
P. Jobin	Gouvernement du Québec, Ministère de la Sécurité Publique	Quebec	Regulator
F. Kurz	Fire Protection Technicians Network	Canada	User
G. Landmesser	Canadian Fire Alarm Association	Canada	User
K. Lefebvre	Canadian Association of Fire Chiefs	Canada	Regulator
D. Morris	Canadian Fire Safety Association	Canada	General Interest
D. Nita	Digital Security Controls Ltd.	Canada	Producer
B. Paterson	Office of the Ontario Fire Marshal and Emergency Management	Ontario	Regulator
P. Patry	Ontario Municipal Fire Prevention Officers Association	Ontario	Regulator
S. Postma	Health Canada	Canada	Regulator
M. Shea	Chief Electrical Inspectors Association	Canada	Regulator
S. Stroud	ADT Security Services Canada, Inc.	Canada	User
J. Van Keuren	Chubb Edwards - UTC Fire & Security Canada	Canada	Producer
L. Shudak (Associate Member)	UL LLC	U.S.A.	Non-Voting
A. Tsisserev (Associate Member)	EFS Engineering Solutions Ltd.	Canada	Non-Voting
T. Zhong (Associate Member)	Underwriters Laboratories of Canada Inc.	Canada	Non-Voting
T. Espejo (Project Manager)	ULC Standards	Canada	Non-Voting

This list represents the membership at the time the Committee balloted on the final text of this edition. Since that time, changes in the membership may have occurred.

ULC STANDARDS SUBCOMMITTEE ON INSTALLATION, INSPECTION AND VERIFICATION OF FIRE ALARM SYSTEMS

MEMBER

REPRESENTING

R. de Launay (Chair)	Human Resources and Skills Development Canada, Canada
P. Adams	Society of Fire Protection Engineers, Southern Ontario Chapter, Ontario
M. Arruda	Electrical Contractors Association of Ontario, Ontario
A. Cavers	Underwriters Laboratories of Canada Inc., Canada
P. Clarke	Canadian Forces Fire Marshal's Office, Canada
S. Crosby	Randal Brown and Associates Engineering Ltd., Canada
D.N. Delen	Morrison Hershfield Limited, Canada
B. Fremis	Defence Construction Canada, Canada
W. D. Goodyear	D. Goodyear Fire Consulting, Canada
J. Heynen	Canadian Association of Fire Chiefs, Canada
M. Hugh	SimplexGrinnell Div of Tyco International of Canada Ltd, Canada
F. Kurz	Fire Protection Technicians Network, Canada
A.M. Leber	Leber/Rubes Inc., Canada
W. Liang	QPS Evaluation Services, Canada
I. MacDonald	R. J. Bartlett Engineering Ltd., Canada
A. Mezenberg	Chubb Edwards – UTC Fire & Security Canada, Canada
D. Morris	Canadian Fire Safety Association, Canada
B. Paterson	Office of the Ontario Fire Marshal and Emergency Management, Ontario
M. Prasad	ULC Standards, Canada
M. Fortin	National Research Council of Canada, Canada
D. Thorn	Honeywell Limited, Canada
A. Tsisserev	Stantec, Canada
D. Weber	Vipond Systems Group, Canada
T. Zhong	Underwriters Laboratories of Canada Inc., Canada
T. Espejo (Project Manager)	ULC Standards, Canada



Documents

Document Sharing Hub

ULC STANDARDS WORKING GROUP ON INSTALLATION OF FIRE ALARM SYSTEMS

MEMBER

REPRESENTING

W. D. Goodyear (Chair)	D. Goodyear Fire Consulting, Canada
R. Barnes	Chubb Edwards – UTC Fire & Security Canada, Canada
A. Cavers	Underwriters Laboratories of Canada Inc., Canada
S. Crosby	Randal Brown & Associates Engineering Ltd., Canada
S. Denn	Brampton Fire and Emergency Services, Ontario
L. Durand	Saskatoon Fire and Protection Services, Saskatchewan
T. Espejo	ULC Standards, Canada
A. Friedman	Toronto Fire Services, Ontario
M. Hugh	SimplexGrinnell Div of Tyco International of Canada Ltd, Canada
F. Kurz	Fire Protection Technicians Network, Canada
R. de Launay	Human Resources and Skills Development Canada, Canada
G. Landmesser	Canadian Fire Alarm Association, Canada
I. MacDonald	R. J. Bartlett Engineering Ltd., Canada
P. McDonald	Underwriters Laboratories of Canada Inc., Canada
B. Paterson	Office of the Ontario Fire Marshal and Emergency Management, Ontario
S. Ridyard	Leber/Rubes Inc., Canada
D. Sylvester	Mircom Group of Companies, Canada
P. Schuyler	H.H. Angus and Associates, Ltd., Canada
V. Tantaló	Durham Central Fire Systems, Ontario
D. Thorn	Honeywell Limited, Canada
D. Weber	Vipond Systems Group, Canada
M. Zukov	ARENCON, Inc., Ontario

Further to the above, the following person has provided additional contribution to the Working Group.

A. Wilson	Mircom Group of Companies, Canada
-----------	-----------------------------------



Documents

Document Sharing Hub

STANDARD FOR INSTALLATION OF FIRE ALARM SYSTEMS

PREFACE

This is the Sixth Edition CAN/ULC-S524-14, Standard for Installation of Fire Alarm Systems.

This Edition of the Standard was developed by the ULC Standards Working Group on S524, reviewed by the ULC Standards Subcommittee on Installation, Inspection and Verification of Fire Alarm Systems, and has been formally approved by the ULC Standards Committee on Fire Alarm and Life Safety Equipment and Systems.

Only metric SI units of measurement are used in this Standard. If a value for measurement is followed by a value in other units in parentheses, the second value may be approximate. The first stated value is the requirement.

Appendices A to F, identified as informative, are for guidance and informational purposes only.

In Canada, there are two official languages, French and English. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require markings and/or instructions to be in either or both official languages, except as stated elsewhere in this Standard.

This Sixth Edition National Standard of Canada is based on, and now supersedes, the Fifth Edition publication.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. ULC Standards shall not be held responsible for identifying any or all such patent rights.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

The initiation of the review of this Standard will commence within 5 years of the date of publication, unless the Standard is identified as fitting within a stabilized category, whereby the review will commence within the appropriate time frame set out by ULC Standards.

This Standard is intended for conformity assessment.

Copyright Underwriters' Laboratories of Canada
Provided by IHS Markit under license with ULC
No reproduction or networking permitted without license from IHS

1 SCOPE

1.1 This Standard describes the requirements for the *design* and installation of a *fire alarm system* with or without *voice communication* capability, as defined in Section 3, Glossary.

NOTE 1: This Standard is intended to apply to both required and voluntary fire alarm installations.

NOTE 2: The requirements in this Standard address the installation for various types of *fire alarm system* equipment and devices. These requirements are intended to apply when the equipment and devices are required by the *fire alarm system design*.

NOTE 3: This Standard recognizes that a *fire alarm system* may have additional features or functions differing from those detailed in these requirements, if the features or functions enhance:

- A the life safety of the occupants of the *building*; and/or
- B the protection of the *building* or property.

Refer to Appendix A (Informative) Explanatory Materials, Clause A1.1.

1.2 The installation of fire detection and alarm devices not covered by these requirements shall be in accordance with good engineering practice and manufacturer's published installation instructions.

2 REFERENCE PUBLICATIONS

2.1 The documents shown below are referenced in the text of this Standard. Unless otherwise stated elsewhere in this Standard such reference shall be considered to indicate the edition and/or revisions of the document available at the date on which the Committee approved this ULC Standard. All undated references shall be interpreted as referring to the latest edition of that document.

Documents Published by the CSA Group
5060 Spectrum Way, Mississauga, ON L4W 5N6 Canada
Telephone: (416) 747-4000 or 1-800-469-6727
www.csagroup.ca

- CSA C22.1-12, Canadian Electrical Code (CEC), Part I, Safety Standard for Electrical Installations
- CSA C282-09, Emergency Electrical Power Supply for Buildings
- CAN/CSA Z32-09, Electrical Safety and Essential Electrical Systems in Health Care Facilities

Documents Published by the National Fire Protection Association (NFPA)
1 Batterymarch Park, Quincy, MA 02169-7471 U.S.A.
Telephone: (617) 770-3000
www.nfpa.org

- NFPA 13-2013, Standard for Installation of Sprinkler Systems
- NFPA 72-2013, National Fire Alarm and Signaling Code

Document Published by the National Research Council Canada (NRC)
1200 Montreal Road, Bldg. M-58, Ottawa, ON K1A 0R6 Canada

Telephone: (613) 993-9101 or 1-877-672-2672
www.nrc-cnrc.gc.ca

- National Building Code (NBC) of Canada 2010
- National Fire Code (NFC) of Canada 2010

Document Published by the Office of the Ontario Fire Marshal (OFM)
Ministry of Community Safety and Correctional Services, Office of the Fire Marshal, 5775 Yonge Street,
7th Floor, Toronto, ON M2M 4J1 Canada
Telephone: (416) 325-3100
www.ofm.gov.on.ca

- Technical Guideline TG-02-98, June 1998, Fire Alarm Audibility in Existing Residential Occupancies

Documents Published by ULC Standards
7 Underwriters Road, Toronto, ON M1R 3B4 Canada
Telephone: (416) 757-3611 or 1-866-9373-ULC
E-mail: publications@ulc.ca
www.ulc.ca

- CAN/ULC-S139–12, Standard Method of Fire Test for Evaluation of Integrity of Electrical Cables
- CAN/ULC-S525, Audible Signal Devices for Fire Alarm Systems, Including Accessories
- CAN/ULC-S526, Visible Signal Devices for Fire Alarm Systems, Including Accessories
- CAN/ULC-S527, Standard for Control Units for Fire Alarm Systems
- CAN/ULC-S528, Standard for Manual Stations for Fire Alarm Systems, Including Accessories
- CAN/ULC-S529, Smoke Detectors for Fire Alarm Systems
- CAN/ULC-S530, Heat Actuated Fire Detectors for Fire Alarm Systems
- CAN/ULC-S533, Egress Door Securing and Releasing Devices
- CAN/ULC-S541, Speakers for Fire Alarm Systems, Including Accessories
- CAN/ULC-S548, Devices and Accessories for Water Type Extinguishing Systems
- CAN/ULC-S559, Standard for Equipment for Fire Signal Receiving Centres and Systems
- CAN/ULC-S561, Standard for Installation and Services for Fire Signal Receiving Centres and Systems
- ULC/ORD-C228, Door Closers and Holders

Telecommunications Industry Association (TIA)/Electronic Industries Alliance (EIA)
1320 N. Courthouse Road, Suite 200 Arlington, VA 22201 U.S.A.
Telephone: (703) 907-7700

www.tiaonline.org

- TIA EIA-568-[C1.1-2012], Commercial Building Telecommunications Cabling Standard, Part 1: General Requirements.
- TIA EIA-568-[C.2-2010], Commercial Building Telecommunications Cabling Standard, Part 2: Balanced Twisted-Pair Telecommunications Cabling Components.
- TIA EIA-568-[C.3-2011], Optical Fiber Cabling Components Standard- Cabled Optical Fiber and Array Connectivity.
- TIA EIA-606-[B-2012], Administration Standard for the Commercial Telecommunications Infrastructure.
- TIA TSB-140-[2004], Telecommunications Systems Bulletin – Additional Guidelines for Field-Testing Length, Loss and Polarity of Optical Fiber Cabling Systems.
- TIA-598-[C-(2005)], Optical Fiber Cable Color Coding.

3 GLOSSARY

NOTE: Terms used in this Standard that are in *italic* print are defined as follows:

3.1 *ACTIVE FIELD DEVICE* – A *field device* that can be uniquely identified by a *control unit* and/or *transponder* to determine its presence and operating status, and which may be commanded to operate or to change its operating parameters independently of other *field devices* that share a common *circuit*.

3.2 *ADDRESSABLE DEVICE* – See definitions for *active field device* and *supporting field device*.

NOTE: Collectively, *active field devices* and *supporting field devices* are commonly referred to as *addressable devices*.

3.3 *AIR DUCT TYPE SMOKE DETECTOR* – A *fire detector* designed to activate when the concentration of airborne combustion products in an air duct exceeds a pre-determined level.

3.4 *AIR SAMPLING TYPE DETECTOR* – A *fire detector* designed to activate when the concentration of airborne combustion products exceed a pre-determined level and is part of an air sampling system.

3.5 *ALARM SIGNAL*[‡] – An audible signal transmitted throughout a zone or zones or throughout a *building* to advise occupants that a fire emergency exists.

3.6 *ALERT SIGNAL*[‡] – An audible signal to advise designated persons of a fire emergency.

3.7 *AMBIENT NOISE LEVEL* – The background sound or noise in an area or environment, being composite of sounds from many sources, including *building* HVAC (heating, ventilating, air conditioning). *Ambient noise level* measurements should be recorded when temporary sound sources are absent or are at their lowest level.

3.8 *ANCILLARY CIRCUIT* – A *circuit* which connects a *control unit* and/or *transponder* to *ancillary devices*.

3.9 *ANCILLARY DEVICE* – A device which has a life-safety application, and is activated by the *fire alarm system*, but is not part of the *fire alarm system*.

3.10 **ANCILLARY DISPLAY** – A component to visually indicate status information from a *fire alarm system* or *ancillary device*.

3.11 **ANNUNCIATOR** – A component to visually indicate the National Building Code of Canada required status information from a *fire alarm system*.

3.12 **AUDIBLE SIGNAL DEVICE** – A device which utilizes sound to notify the occupants of a *building* of an emergency situation.

3.13 **AUTHORITY HAVING JURISDICTION (AHJ)** – The government body responsible for the enforcement of any part of this Standard or the official or agency designated by that body to exercise such a function.

3.14 **AUTOMATED VOICE** – A pre-recorded voice message that may be activated in the event of an emergency or other customized applications.

3.15 **BEAM TYPE CEILING** – *Ceilings* having solid structural or solid non-structural members or baffles projecting down from the *ceiling* surface more than 100 mm and spaced more than 900 mm, centre to centre.

NOTE: Open truss beam construction is not considered to impede the flow of fire products unless the upper member is in continuous contact with the *ceiling* and projects more than 100 mm below the *ceiling*.

3.16 **BEAM TYPE SMOKE DETECTOR** – A *fire detector* where light from an internal source is transmitted externally, monitored by a photosensitive receiver, and is designed to activate when the concentration of airborne combustion products exceeds a predetermined level.

3.17 **BUILDING[‡]** – Any structure used or intended for supporting or sheltering any use or occupancy.

3.18 **CARE[‡]** Means the provision of services other than treatment by or through *care* facility management to residents who require these services because of cognitive, physical or behavioural limitations.

3.19 **CARE OCCUPANCIES[‡]** – The occupancy or use of a *building* or part thereof where *care* is provided to residents. (See Appendix A (Informative) Explanatory Materials, Clause A3.19.)

3.20 **CEILING** – The upper surface of a space, regardless of height.

3.21 **CEILING HEIGHT** – The height from the continuous floor of a room or space to the continuous *ceiling* of a room or space.

3.22 **CENTRAL ALARM AND CONTROL FACILITY (CACF)** – A location within a *building* provided for the purpose of command and control of the *fire alarm system*.

3.23 **CIRCUIT** – Conductors connected directly to *field devices* which provide a *control unit* and/or *transponder* with *field device* status information, alarm signalling or other functions.

3.24 **CLASS A CIRCUIT (Return Loop Circuit)** – A *circuit* having one continuous path connecting all components on the *circuit* and terminating through an alternate connection path in the source enclosure.

3.25 **CLASS B CIRCUIT (Terminated Circuit)** – A *circuit* having one continuous path connecting all devices on the *circuit* and terminating at an end-of-line device.

3.26 **COMPATIBLE** – The correct electrical, electronic or mechanical interaction between a series of system components that depend on individual unique characteristics that are connected together to meet the requirements of this Standard (e.g. *control unit* and/or *transponder* and *field devices*).

3.27 **CONTROL UNIT** – A component that provides the control and logic processing for a *fire alarm system*.

3.28 **CONVENTIONAL FIELD DEVICE** – A *field device* that is usually connected to a *control unit* and/or *transponder* on a common wiring *circuit* with other devices so that all devices on the *circuit* provide a common status change information (e.g. fire alarm detection or *signalling*). Such devices cannot be uniquely identified by a *control unit* and/or *transponder* unless there is only one device on the *circuit*. (Refer to Clause 3.1, *active field device*).

3.29 **DATA COMMUNICATION LINK (DCL)** – The data channel between *control units* and/or *transponders*, *display and control centres*, *annunciators*, *active field devices* and *supporting field devices* of a *distributed type system* or *remote receiving equipment*.

3.29.1 **DATA COMMUNICATION LINK STYLE A (DCLA)** – A *data communication link* style performing similar to a *Class A circuit* with operational characteristics as detailed in Table 1.

3.29.2 **DATA COMMUNICATION LINK STYLE B (DCLB)** – A *data communication link* style performing similar to a *Class B circuit* with operational characteristics as detailed in Table 1.

3.29.3 **DATA COMMUNICATION LINK STYLE C (DCLC)** – A *data communication link* style with a primary wiring *circuit* and an alternate wiring *circuit* with operational characteristics as detailed in Table 1.

3.30 **DEGRADED MODE CAPABILITY** – A feature where, under conditions of partial *data communication link* failure, *control units* and/or *transponders*, which remain connected to each other, are capable of receiving inputs and activating outputs in the areas served by the *control units* and/or *transponders* which remain in communication with each other.

3.31 **DESIGN** – The selection, application and layout of the *fire alarm system* components.

3.32 **DETECTOR SPACING** – A horizontally measured dimension relating to the allowable coverage of detectors.

3.33 **DISPLAY AND CONTROL CENTRE (DCC)** – Equipment used for the status display of the *input zones* and for the manual control of a *fire alarm system*, and may include manual control for emergency voice alarm and *emergency telephone* functions. The *display and control centre* may be located remotely from a *fire alarm control unit* and/or *transponder*.

3.34 **DISTRIBUTED TYPE SYSTEM** – A system consisting of two or more *control units* and/or *transponders*, one of which operates as the *display and control centre*.

3.35 **EFFECTIVE LUMINOUS INTENSITY** – The quantity of directly perceived light produced by a *visible signal device*, measured in candela (cd).

3.36 **ELECTRICAL SUPERVISION** – A means whereby a fault condition which would interfere with the operation of a *circuit* in a *fire alarm system* is detected.

3.37 **EMERGENCY TELEPHONE** – A feature of a *fire alarm system*, which provides two-way *voice communication* between each *floor area* and a *display and control centre* and/or the equipment at a *central alarm and control facility*.

3.38 **EMERGENCY POWER SUPPLY** – An emergency source of electrical energy, independent of the *primary power supply*, used to power the *fire alarm system* in the event of a failure of the *primary power supply*.

3.39 **FAULT ISOLATOR** – A device used for wire to wire *short circuit* protection.

3.39.1 **AUDIO BUSS FAULT ISOLATOR** – A *fault isolator* intended for use on audio (paging, telephone or tone) busses to ensure that a *short circuit fault* on an audio buss in one fire alarm zone does not prevent the normal operation of an audio buss in another fire alarm zone.

3.39.2 **DATA FAULT ISOLATOR** – A *fault isolator* intended for use on *data communication links* to ensure that a *short circuit fault* on a *data communication link* in one fire alarm zone does not prevent the normal operation of a *data communication link* in another fire alarm zone.

3.39.3 **POWER BUSS FAULT ISOLATOR** – A *fault isolator* intended for use on power busses to ensure that a *short circuit fault* on a power buss in one fire alarm zone does not prevent the normal operation of a power buss in another fire alarm zone.

3.39.4 **SUITE FAULT ISOLATOR** – A *fault isolator* intended for use on signal *circuits* serving suites of a residential or *care occupancy* to ensure that a *short circuit fault* on a signal *circuit* in one suite of a residential or *care occupancy* does not prevent the normal operation of a signal device in another suite of a residential or *care occupancy*.

3.40 **FIELD DEVICE** – A device located remotely from, but connected electrically to a *control unit* and/or *transponder* to transmit or receive status change information (e.g. fire alarm detection or signalling).

3.41 **FIRE ALARM SYSTEM** – A combination of interconnected devices consisting of at least a *control unit*, a *manual station* and an *audible signal device*, designed to warn the *building* occupants of an emergency fire condition.

3.42 **FIRE DETECTOR[†]** – A device which detects a fire condition and automatically initiates an electrical signal to actuate an *alert signal* or an *alarm signal* and includes *heat detectors* and *smoke detectors*.

3.43 **FLAME DETECTOR** – A *fire detector* designed to activate at a predetermined level of infrared, ultraviolet, or visible radiation emanating from the process of combustion.

3.44 **FLOOR AREA[†]** – The space on any storey of a *building* between exterior walls and required firewalls, including the space occupied by interior walls and partitions, but not including exits and vertical service spaces and their enclosing assemblies.

3.45 **GROUND FAULT** – A *circuit* impedance to ground sufficient to prevent normal operation.

3.46 **HEAT DETECTOR[†]** – A *fire detector* designed to operate at a predetermined temperature or rate of temperature rise.

3.47 **INPUT CIRCUIT** – A *circuit* connected directly to *conventional field devices* to provide a *control unit* and/or *transponder* with *field device* status information.

3.48 **INPUT ZONE** – An area or *field device* within a *building* which initiates *annunciator* indication as required by the National Building Code of Canada.

3.49 **LARGE SCALE NETWORK** — *Fire alarm systems* that contain more than 1 000 active and *supporting field devices* and that utilize more than one *control unit* or *transponder*.

3.50 *MANUAL STATION* – A *field device* designed to initiate a signal when operated manually.

3.51 *OPEN CIRCUIT FAULT* – A *circuit* impedance increase sufficient to prevent normal operation.

3.52 *OPTICAL FIBRE CABLE* – A cable consisting of one or more optical fibres which transmits modulated light for the purpose of control, signalling or communication.

3.53 *OPTICAL TIME DOMAIN REFLECTOMETER (OTDR)* – A test instrument that analyzes the light loss in an optical fibre to find faults, splices and bends.

3.54 *PRIMARY POWER SUPPLY* – The primary source of electrical energy used to power the *fire alarm system*.

3.55 *RELEASING DEVICE SERVICE* – The control of *building safety systems* by the *fire alarm system* (e.g. sprinkler pre-action systems and extinguishing systems). Examples of items which may be controlled include elevators, smoke control and venting systems, fire doors, and extinguishing systems.

3.56 *REMOTE POWER SUPPLY* – A power supply, battery, and charger combination, which is mounted externally from a control panel or *transponder* to extend the power capabilities of fire alarm *circuits* serving fire alarm devices and/or ancillary systems.

NOTE: *Remote power supply* is also known as booster power supply, signal booster power supply, adder power supply, expansion power supply, notification appliance extender, auxiliary power supply or NAC extender.

3.57 *REMOTE RECEIVING EQUIPMENT* – *Control units* and/or *transponders* that receive information from *control units* and/or *transponders* in other *buildings*.

3.58 *RESPONSE TIME* – The time lapse from the occurrence of an alarm or supervisory input status change, or trouble condition, to activation of system outputs.

3.59 *SHORT CIRCUIT FAULT* – A *circuit* impedance decrease sufficient to prevent normal operation.

3.60 *SHORT-RANGE RADIO FREQUENCY DEVICE* – Any device that communicates with control / receiving equipment by low-power radio signals.

NOTE: These devices are commonly referred to as *wireless devices* and may be subject to the requirements of Industry Canada Radio Standards Specifications.

3.61 *SHORT-RANGE RADIO FREQUENCY DEVICE LINK* – A low-power radio signal that provides a data channel between *short-range radio frequency devices*.

NOTE: *Short-range radio frequency device links* are commonly referred to as *wireless device links* and may be subject to the requirements of Industry Canada Radio Standards Specification.

3.62 *SIGNAL RECEIVING CENTRE* – A facility that receives *fire alarm system* signals and at which trained personnel and service persons are on duty at all times.

3.63 *SLOPED CEILING* – *Ceilings* having a slope ratio greater than 1 in 8.

3.64 *SLOPED CEILING-PEAKED TYPE* – *Ceilings* which slope in two or more directions from the highest point.

3.65 *SLOPED CEILING-SHED TYPE* – *Ceilings* in which the high point is at one side with the slope extending toward the opposite side.

3.66 *SMOKE DETECTOR*[‡] – A *fire detector* designed to operate when the concentration of airborne combustion products exceed a pre-determined level.

3.67 *SMOOTH CEILING* – *Ceilings* having a surface uninterrupted by continuous projections.

3.68 *SOFTWARE* – A program, or set of programs and associated data, procedures, rules, documentation, and materials concerned with the use, operation, and maintenance of an automated information or message processing system or computing system. (Also refer to Clause 3.69, *software program*).

3.69 *SOFTWARE PROGRAM* – A series of instructions designed to achieve a certain result that is translated into machine-readable form (code).

3.70 *SPECIFIC TROUBLE INDICATION* – A *trouble signal* which consists of a common *trouble signal* and a specific visual indication which identifies the failed *circuit* or item of equipment, or operational malfunction.

3.71 *STAND-ALONE CAPABILITY* – An optional feature where, under conditions of *data communication link* failure, *control units* and/or *transponders* are capable of receiving inputs and activating outputs in the area served by that *control unit* and/or *transponder*.

3.72 *STATUS CHANGE CONFIRMATION (SMOKE DETECTOR ALARM VERIFICATION)* – An optional feature providing confirmation of a normal to off-normal status change of a *smoke detector*.

3.73 *STROBE LIGHT* – A *visible signal device* which utilizes high intensity flashing light to notify occupants of a *building* to the activation of the *fire alarm system*.

3.74 *SUPERVISORY DEVICE* – A *field device* to signal a condition that could prevent proper operation of a fire protection system.

3.75 *SUPERVISORY SIGNAL* – A visual and audible indication of the off-normal status of equipment that has been installed for the protection of life and property.

3.76 *SUPPORTING FIELD DEVICE* – An *active field device* that monitors and/or controls other *field devices* on a separate *circuit* and reports the status of the separate *circuit* to a *control unit* and/or *transponder*.

3.77 *TAMPER DEVICE* – A device to detect the removal or opening of a protective cover.

3.78 *TEMPORARY OR INTERMITTENT SOUND SOURCES* – Sound sources which may cause peaks and valleys in sound levels. Refer to Appendix C4, Ambient Noise Level Measurements.

3.79 *TRANSPONDER* – A component in a *distributed type system*, which is capable of receiving inputs and activating outputs, and that communicates the status of such devices to the *fire alarm system*.

3.80 *TROUBLE SIGNAL* – A visual and audible indication of equipment failure, *circuit* failure, fault condition or operational malfunction.

3.81 *VISIBLE SIGNAL DEVICE* – A device which utilizes light to notify occupants of a *building* to an emergency situation in a direct or indirect manner.

NOTE: *Visible signal devices* used to supplement *audible signal devices* are referred to as visual signal devices in the National Building Code of Canada.

3.82 *VOICE COMMUNICATION* – A feature of a *fire alarm system* consisting of *voice paging* and/or *emergency telephone* capability.

3.83 *VOICE PAGING* – A manual or automatic supervised paging system used to transmit voice messages (information, instructions, and directions) on a selective and/or all-call basis.

3.84 *WATER FLOW DEVICE* – A *field device* used to detect the flow of water through some portion of the water based fire protection system.

3.85 *WIRELESS DEVICE* – See definition for *short-range radio frequency device*.

‡ Definition of this term is consistent with that used in the National Building Code of Canada.

4 REQUIREMENTS OF FIRE ALARM SYSTEMS

4.1 GENERAL

4.1.1 A *fire alarm system* shall consist of at least the following interconnected devices: a *control unit*, a *manual station* and an *audible signal device*.

4.1.2 A *fire alarm system* may include additional devices such as, but not limited to, *fire detectors*, *visible signal devices*, *annunciators* and other equipment required to provide *voice communication* capability.

4.1.3 Devices and equipment used in a *fire alarm system*, and the interconnection to the *fire signal receiving centre*, shall comply with the following Standards:

- A CAN/ULC-S525, Audible Signal Devices for Fire Alarm Systems, Including Accessories;
- B CAN/ULC-S526, Visible Signal Devices for Fire Alarm Systems, Including Accessories;
- C CAN/ULC-S527, Standard for Control Units for Fire Alarm Systems;
- D CAN/ULC-S528, Manual Stations for Fire Alarm Systems, Including Accessories;
- E CAN/ULC-S529, Smoke Detectors for Fire Alarm Systems;
- F CAN/ULC-S530, Heat Actuated Fire Detectors for Fire Alarm Systems;
- G CAN/ULC-S533, Standard for Egress Door Securing and Releasing Devices;
- H CAN/ULC-S541, Speakers for Fire Alarm Systems, Including Accessories;
- I CAN/ULC-S548, Standard for Alarm Initiating and Supervisory Devices for Water Type Extinguishing Systems;
- J CAN/ULC-S559, Standard for Equipment for Fire Signal Receiving Centres and Systems; and
- K CAN/ULC-S561, Standard for Installation and Services for Fire Signal Receiving Centres and Systems.

4.1.4 Devices incorporated in a *fire alarm system* shall be *compatible*.

4.1.5 The connection of *ancillary devices* to the *fire alarm system* shall not interfere with the operation of the *fire alarm system*.

4.1.6 Where *ancillary devices* are powered by a *fire alarm system*, the *primary power supply* and *emergency power supply* of the *fire alarm system* shall be of sufficient capacity to operate both the *fire alarm system* and the *ancillary devices*.

4.1.7 *Voice communication* capability, where provided, shall be *compatible* with the *fire alarm system* and shall not impair the *fire alarm system's* ability to warn the *building* occupants of an emergency condition.

4.1.8 In a *fire alarm system* with *voice communication* capability, voice commands, issued by a person using a microphone, shall not be used as the sole *alarm signal* or *alert signal*, but may be used to supplement these signals.

4.1.9 An alarm input normal to off-normal status change shall cause the *fire alarm system* to perform the required functions.

4.1.10 *Control units* and/or *transponders* arranged for single stage operation shall comply with the following, in accordance with the system's designed sequence of operations:

- A *Audible signal devices* and *visible signal devices* in the *building* shall operate as intended within the *response time* as detailed in Table 2; and
- B Other functions, such as interconnection to signal transmitting unit, *releasing device service* start of sequence, annunciation, *central alarm and control facility* annunciation and *ancillary devices* or *ancillary circuit* functions shall perform as intended within the *response time* as detailed in Table 2.

4.1.11 *Control units* and/or *transponders* arranged for two stage operation shall comply with the following, in accordance with the system's designed sequence of operations:

- A Initiation of a first stage signal input normal to off-normal status change shall result in an *alert signal*. Activation of all or selected *alarm signal* devices connected to the system shall operate as intended, and within the *response time* as detailed in Table 2;
- B Initiation of a second stage signal input normal to off-normal status change, either manual or automatic, shall result in an *alarm signal*. Activation of all or selected *alarm signal* devices connected to the system shall operate as intended, and within the *response time* as detailed in Table 2; and
- C Other functions, such as interconnection to signal transmitting unit, *releasing device service* start of sequence, annunciation, *central alarm and control facility* annunciation and *ancillary devices* or *ancillary circuit* functions shall perform during first stage and/or second stage, as intended or required, and within the *response time* as detailed in Table 2.

4.1.12 *Visible signal devices* that supplement *audible signal devices* to advise occupants that a fire emergency exists, shall be turned off automatically when audible signals are silenced and shall be turned on automatically when audible signals are reactivated.

4.1.13 *Visible signal devices* used to advise occupants to not enter an area, to activate a fire suppression system, or for a similar purpose shall remain on until the *fire alarm system* is reset.

4.1.14 Where a *fire alarm system* incorporates a *status change confirmation* (*smoke detector alarm verification*) function, such a function shall only be invoked upon its acceptance by the *authority having jurisdiction*. (Refer to Appendix A (Informative), Explanatory Materials, A4.1.14, Status Change Confirmation (Smoke Detector Alarm Verification)).