

**CAN/ULC-S563:2006-R2016  
(Reaffirmed 2016)**

**STANDARD FOR CATEGORY 3 FILM-FORMING  
FLUOROPROTEIN (FFFP) FOAM LIQUID CONCENTRATES**

Prepared and Published by:



**ULC Standards**  
Normes ULC

Approved by:



**Standards Council of Canada**  
**Conseil canadien des normes**



**Documents**

Document Sharing Hub

Underwriters Laboratories of Canada (ULC) was established in 1920 by letters patent issued by the Canadian Government. It maintains and operates laboratories and certification services for the examination, testing and certification of appliances, equipment, materials, constructions and systems to determine their relation to life, fire and property hazards as well providing inspection services.

Underwriters Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization, a Testing Organization, and an Inspection Body under the National Standards System of Canada.

ULC Standards develops and publishes standards and other related publications for building construction, security and burglar protection, environmental safety, electrical equipment, fire protection equipment, gas and oil equipment, thermal insulation products, materials and systems, energy use in the built environment and electrical utility safety.

ULC Standards is a not-for-profit organization and is accredited by the Standards Council of Canada as a Standards Development Organization.

National Standards of Canada developed by ULC Standards conform to the criteria and procedures established by the Standards Council of Canada. Such standards are prepared using the consensus principle by individuals who provide a balanced representation of interests relevant to the subject area on a national basis.

ULC is represented across Canada as well as many countries worldwide. For further information on ULC services, please contact:

Customer Service: 1-866-937-3852

## National Standard of Canada

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations*, and *Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at [www.scc.ca](http://www.scc.ca).

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at [www.scc.ca](http://www.scc.ca).

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

### CORPORATE HEADQUARTERS

Underwriters Laboratories of Canada  
7 Underwriters Road  
Toronto, Ontario M1R 3A9  
Telephone: (416) 757-3611  
Fax: (416) 757-9540

### REGIONAL OFFICES

#### PACIFIC OFFICE

13775 Commerce Parkway, Suite 130  
Richmond, British Columbia V6V 2V4  
Telephone: (604) 214-9555  
Fax: (604) 214-9550

#### EASTERN OFFICE

6505, Rte Transcanadienne, Suite 330  
St-Laurent, Québec H4T 1S3  
Telephone: (514) 363-5941  
Fax: (514) 363-7014

For further information on ULC standards, please contact:

### ULC STANDARDS

171 Nepean Street, Suite 400  
Ottawa, Ontario K2P 0B4  
Telephone: (613) 755-2729  
Fax: (613) 231-5977  
E-mail: [customerservice@ulc.ca](mailto:customerservice@ulc.ca)  
Web site: [www.ulc.ca](http://www.ulc.ca)

The intended primary application of this standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

Copies of this National Standard of Canada may be ordered from ULC Standards.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

STANDARD FOR CATEGORY 3 FILM-FORMING FLUOROPROTEIN  
(FFFP) FOAM LIQUID CONCENTRATES

ICS 13.220.10; 13.220.99; 71.100.99

Prepared and Published by:



Approved by:



First Edition .....September 1998  
Second Edition .....April 2006  
**REAFFIRMATION .....APRIL 2016**

Copyright © 2016

ULC Standards

All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission.

Document ID: 123456789

# TABLE OF CONTENTS

|                                                                                             |    |
|---------------------------------------------------------------------------------------------|----|
| ULC COMMITTEE ON FIRE FIGHTING FOAMS.....                                                   | i  |
| REFERENCE PUBLICATIONS .....                                                                | ii |
| PREFACE .....                                                                               | 1  |
| 1. SCOPE.....                                                                               | 2  |
| 2. CLASSIFICATION.....                                                                      | 2  |
| 3. GENERAL REQUIREMENTS .....                                                               | 3  |
| 4. DETAILED REQUIREMENTS.....                                                               | 3  |
| 4.1 GENERAL .....                                                                           | 3  |
| 4.2 EXPANSION AND DRAINAGE .....                                                            | 3  |
| 4.3 STABILITY AND STORAGE .....                                                             | 3  |
| 4.3.1 General .....                                                                         | 3  |
| 4.3.2 High and Low Temperature Cycling (Concentrate).....                                   | 3  |
| 4.3.3 High Temperature Stability (Solution).....                                            | 4  |
| 4.4 FIRE PERFORMANCE .....                                                                  | 4  |
| 4.4.1 2.6 m <sup>2</sup> Fire Performance Test (Half-Strength) .....                        | 4  |
| 4.4.2 4.6 m <sup>2</sup> Fire Performance Test.....                                         | 4  |
| 4.5 CORROSION .....                                                                         | 5  |
| 4.6 FILM FORMATION AND SEALABILITY .....                                                    | 5  |
| 4.7 COMPATIBILITY.....                                                                      | 5  |
| 4.7.1 With Dry Chemical Agent.....                                                          | 5  |
| 4.7.2 General Compatibility of FFFP Concentrates .....                                      | 5  |
| 5. TEST METHODS.....                                                                        | 6  |
| 5.1 SEDIMENTATION.....                                                                      | 6  |
| 5.2 PRECIPITATION.....                                                                      | 6  |
| 5.3 SURFACE TENSION .....                                                                   | 6  |
| 5.4 INTERFACIAL PLUS SURFACE TENSION .....                                                  | 6  |
| 5.5 ENVIRONMENTAL IMPACT .....                                                              | 7  |
| 5.5.1 Toxicity .....                                                                        | 7  |
| 5.5.2 Chemical Oxygen Demand (COD).....                                                     | 7  |
| 5.5.3 Biodegradability .....                                                                | 7  |
| 5.6 EXPANSION AND DRAINAGE .....                                                            | 7  |
| 5.7 STABILITY .....                                                                         | 7  |
| 5.7.1 High and Low Temperature Cycling (Concentrate).....                                   | 7  |
| 5.7.2 High Temperature Stability (Solution).....                                            | 8  |
| 5.8 2.6 m <sup>2</sup> FIRE PERFORMANCE TEST (HALF-STRENGTH) .....                          | 8  |
| 5.9 4.6 m <sup>2</sup> FIRE PERFORMANCE TEST .....                                          | 10 |
| 5.10 CORROSION .....                                                                        | 12 |
| 5.10.1 General Corrosion .....                                                              | 12 |
| 5.10.2 Localized Corrosion .....                                                            | 12 |
| 5.11 FILM FORMATION AND SEALABILITY .....                                                   | 13 |
| 5.12 2.6 m <sup>2</sup> FIRE PERFORMANCE FOR COMPATIBILITY WITH<br>DRY CHEMICAL AGENT ..... | 14 |
| 6. CONTAINER REQUIREMENTS .....                                                             | 16 |
| 6.1 GENERAL .....                                                                           | 16 |
| 6.2 DROP TEST .....                                                                         | 16 |
| 6.3 NONMETALLIC CONTAINER TESTS .....                                                       | 17 |

|       |                                              |    |
|-------|----------------------------------------------|----|
| 6.3.1 | Immersion Test for Cracking Resistance ..... | 17 |
| 6.3.2 | Air-Oven Aging Test .....                    | 17 |
| 6.3.3 | Accelerated Storage Test .....               | 17 |
| 6.3.4 | Light And Water Test .....                   | 17 |
| 6.3.5 | Horizontal Burning Test .....                | 18 |
| 7.    | MARKING .....                                | 19 |
|       | TABLES .....                                 | 21 |
|       | FIGURES .....                                | 23 |

**ULC STANDARDS COMMITTEE ON FIRE FIGHTING FOAMS**

| NAME             | AFFILIATION                           | REGION  | CATEGORY                      |
|------------------|---------------------------------------|---------|-------------------------------|
| K. Cookson       | Ontario Ministry of Natural Resources | Ontario | General Interest              |
| J. DiFilippo     | Kidde Canada Inc.                     | Canada  | Producer                      |
| M. Figliola      | Greater Toronto Airports Authority    | Ontario | User                          |
| M. Gravel        | Department of National Defence        | Canada  | User                          |
| M. Hubert        | The Solberg Company                   | USA     | Producer                      |
| A. Kim           | National Research Council Canada      | Canada  | General Interest              |
| B. Rowswell      | National Foam                         | Canada  | Producer                      |
| J. Tardif        | Ministère de la Sécurité publique     | Quebec  | Regulator                     |
| G. Vestergom Jr. | Unifoam Company Ltd.                  | Canada  | Producer                      |
| B. Shugarman     | UL LLC.                               | USA     | Associate Member (Non-Voting) |
| M. Ramlochan     | ULC Standards                         | Canada  | Project Manager (Non-Voting)  |

This list represents the membership at the time the Committee balloted on the final text of this edition. Since that time, changes in the membership may have occurred.

## REFERENCE PUBLICATIONS

The documents shown below are referenced in the text of this Standard. Unless otherwise stated elsewhere in this Standard such reference shall be considered to indicate the edition and/or revisions of the document available at the date on which the Committee approved this ULC Standard.

Document Published by the American Public Health Association (APHA)  
1015 15<sup>th</sup> Street NW, Suite 300, Washington, DC 20005, U.S.A.  
Telephone: (202) 777-2742 Fax: (202) 777-2534  
[www.apha.org](http://www.apha.org)

- Standard Methods for the Exam of Water and Wastewater

---

Documents Published by the American Society for Testing and Materials (ASTM)  
100 Barr Harbour Drive, PO Box C700, West Conshohocken, PA 19428-2959 U.S.A.  
Telephone: (610) 832-9585 Fax: (610) 832-9555  
[www.astm.org](http://www.astm.org)

- ASTM A 240/A 240M-05a, Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications
- ASTM B 466/B 466M-03, Standard Specification for Seamless Copper-Nickel Pipe and Tube
- ASTM D 96-88 (Reapproved 1994), Standard Test Method for Water and Sediment in Crude Oil by Centrifuge Method (Field Procedure)
- ASTM D 445-04, Standard Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and the Calculation of Dynamic Viscosity)
- ASTM D 638-03, Standard Test Method for Tensile Properties of Plastics
- ASTM D 1141-98 (Reapproved 2003), Standard Practice for the Preparation of Substitute Ocean Water
- ASTM D 1177-05, Standard Test Method for Freezing Point of Aqueous Engine Coolants
- ASTM D 1193-99, Standard Specification for Reagent Water
- ASTM D 1298-99 (Reapproved 2005), Standard Test Method for Density, Relative Density (Specific Gravity), or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
- ASTM D 1331-89 (Reapproved 2001), Standard Test Methods for Surface and Interfacial Tension of Solutions of Surface-Active Agents
- ASTM D 1693-05, Standard Test Method for Environmental Stress-Cracking of Ethylene Plastics
- ASTM E 70-97 (Reapproved 2002), Standard Test Method for pH of Aqueous Solutions with the Glass Electrode
- ASTM E 205-96 (Reapproved 2000), Standard Specification for Glass and Oxygen Combustion Flask

- ASTM E 527-83 (Reapproved 2003), Standard Practice for Numbering Metals and Alloys (UNS)
  - ASTM E 729-96 (Reapproved 2002), Standard Guide for Conducting Acute Toxicity Tests on Test Materials with Fishes, Macroinvertebrates, and Amphibians
  - ASTM G 26-96, Standard Practice for Operating Light-Exposure Apparatus (Xenon-Arc Type) With and Without Water for Exposure of Nonmetallic Materials
- 

Documents Published by the Canadian General Standards Board (CGSB)  
Canadian General Standards Board, Gatineau, QC K1A 1G6 Canada  
Telephone: (819) 956-0425 or 1-800-665-2472  
[www.pwgsc.gc.ca/cgsb](http://www.pwgsc.gc.ca/cgsb)

- CAN/CGSB-3.25-2004, Amendment No. 1, Aviation Gasoline (Grades 80 and 100 LL)
- 

Document Published by the National Fire Protection Association (NFPA)  
1 Batterymarch Park, Quincy, MA 02269-9101, U.S.A.  
Telephone: (617) 770-3000 Fax: (617) 770-0700  
[www.nfpa.org](http://www.nfpa.org)

- NFPA 412-2003, Standard for Evaluating Aircraft Rescue and Fire-Fighting Foam Equipment
- 

Document Published by Transport Canada  
330 Sparks Street, Ottawa, ON K1A 0N5 Canada  
Telephone: (613) 990-2309 Fax: (613) 954-4731  
[www.tc.gc.ca](http://www.tc.gc.ca)

- Transportation of Dangerous Goods Regulations
- 

Documents Published by Underwriters' Laboratories of Canada (ULC)  
7 Underwriters Road, Toronto, ON M1R 3B4 Canada  
Telephone: (416) 757-3611 or 1-866-9373-ULC  
[www.ulc.ca](http://www.ulc.ca)

- CAN/ULC-S514-M88, Standard for Dry Chemical for Use in Hand Wheeled Fire Extinguishers
  - CAN/ULC-S560-06, Standard for Category 3 Aqueous Film-Forming Foam (AFFF) Liquid Concentrates
  - ULC-S564-06, Standard for Categories 1 and 2 Foam Liquid Concentrates
-

AVASoft

## STANDARD FOR CATEGORY 3 FILM-FORMING FLUOROPROTEIN (FFFP) FOAM LIQUID CONCENTRATES

### PREFACE

This is the Second Edition of the Standard for Category 3 Film-Forming Fluoroprotein (FFFP) Foam Liquid Concentrates.

This Edition of the Standard has been formally approved by the ULC Standards Committee on Fire Fighting Foams

This Standard has been developed in compliance with the requirements of SCC for accreditation of a Standards Development Organization.

Only metric SI units of measurement are used in this Standard. If a value for measurement is followed by a value in other units in parentheses, the second value may be approximate. The first stated value is the requirement.

In Canada, there are two official languages, English and French. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require additional markings and/or installation instructions to be in both official languages.

This Second Edition National Standard of Canada is based on the First Edition, and now has been reaffirmed.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. ULC Standards shall not be held responsible for identifying any or all such patent rights.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

The review and action to revise or reaffirm this Standard will not exceed 5 years from the date of publication, unless the Standard is identified as fitting within a stabilized category, whereby the review will commence within the appropriate time frame set out by ULC Standards.

This Standard is intended to be used for conformity assessment.

## 1. SCOPE

1.1 The Standards for foam liquid concentrates are divided into three categories.

| Category 1                                             | Category 2                                                                                                      | Category 3                                                                         |
|--------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------|
| Primarily for use on general-purpose hydrocarbon fires | Primarily for use on polar solvents, oxygenated fuels, and water-miscible fuels and all Category 1 applications | Primarily for use on aircraft rescue fire fighting and all Category 1 applications |

This Standard refers to Category 3 Film-Forming Fluoroprotein (FFFP) Foam Liquid Concentrates.

NOTE: The requirements for Category 3 Aqueous Film-Forming Foam (AFFF) Liquid Concentrates are contained in the Standard CAN/ULC-S560.

1.2 The foam liquid concentrate at 3 % or 6 % dilution with fresh or sea water are intended primarily for use in aircraft rescue and firefighting vehicles (ARFF) but are also suitable for use in mobile, portable and fixed airfoam installations, including foam-water sprinkler systems which have been proven suitable to meet the requirements of the Standard for Categories 1 and 2 Foam Liquid Concentrates, ULC-S564, in surface extinguishment of fires involving ordinary hydrocarbon flammable liquids.

1.3 These requirements do not supersede requirements prescribed in legislation or regulation by the authority having jurisdiction.

NOTE: Reference to each applicable Test Method for a requirement is indicated by the letters TM and the appropriate Clause or Section number in parentheses in the right hand margin.

## 2. CLASSIFICATION

2.1 Film-forming fluoroprotein (FFFP) foam liquid concentrate shall be supplied in one of the following types:

- A 3 % foam concentrate (to be diluted 3 parts concentrate, 97 parts water) by volume; or
- B 6 % foam concentrate (to be diluted 6 parts concentrate, 94 parts water) by volume.