

CAN/ULC-S633:2017

STANDARD FOR FLEXIBLE CONNECTOR PIPING FOR FUELS

Prepared and Published by:



Approved by:



Standards Council of Canada
Conseil canadien des normes

Underwriters Laboratories of Canada (ULC) was established in 1920 by letters patent issued by the Canadian Government. It maintains and operates laboratories and certification services for the examination, testing and certification of appliances, equipment, materials, constructions and systems to determine their relation to life, fire and property hazards as well providing inspection services.

Underwriters Laboratories of Canada is accredited by the Standards Council of Canada as a Certification Organization, a Testing Organization, and an Inspection Body under the National Standards System of Canada.

ULC Standards develops and publishes standards and other related publications for building construction, security and burglar protection, environmental safety, electrical equipment, fire protection equipment, gas and oil equipment, thermal insulation products, materials and systems, energy use in the built environment and electrical utility safety.

ULC Standards is a not-for-profit organization and is accredited by the Standards Council of Canada as a Standards Development Organization.

National Standards of Canada developed by ULC Standards conform to the criteria and procedures established by the Standards Council of Canada. Such standards are prepared using the consensus principle by individuals who provide a balanced representation of interests relevant to the subject area on a national basis.

ULC is represented across Canada as well as many countries worldwide. For further information on ULC services, please contact:

Customer Service: 1-866-937-3852

National Standard of Canada

A National Standard of Canada is a standard developed by an SCC-accredited Standards Development Organization (SDO), and approved by the Standards Council of Canada (SCC), in accordance with SCC's: *Requirements and Guidance-Accreditation for Standards Development Organizations*, and *Requirements and Guidance-Approval of National Standards of Canada Designation*. More information on National Standard requirements can be found at www.scc.ca.

An SCC-approved standard reflects the consensus of a number of experts whose collective interests provide, to the greatest practicable extent, a balance of representation of affected stakeholders. National Standards of Canada are intended to make a significant and timely contribution to the Canadian interest.

SCC is a Crown corporation within the portfolio of Industry Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts. Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Users should always obtain the latest edition of a National Standard of Canada from the standards development organization responsible for its publication, as these documents are subject to periodic review.

CORPORATE HEADQUARTERS

Underwriters Laboratories of Canada
7 Underwriters Road
Toronto, Ontario M1R 3A9
Telephone: (416) 757-3611
Fax: (416) 757-9540

REGIONAL OFFICES

PACIFIC OFFICE

13775 Commerce Parkway, Suite 130
Richmond, British Columbia V6V 2V4
Telephone: (604) 214-9555
Fax: (604) 214-9550

EASTERN OFFICE

6505, Rte Transcanadienne, Suite 330
St-Laurent, Québec H4T 1S3
Telephone: (514) 363-5941
Fax: (514) 363-7014

For further information on ULC standards, please contact:

ULC STANDARDS

171 Nepean Street, Suite 400
Ottawa, Ontario K2P 0B4
Telephone: (613) 755-2729

To purchase ULC Standards, visit: www.ulc.ca/ulcstandards

The intended primary application of this standard is stated in its scope. It is important to note that it remains the responsibility of the user of the standard to judge its suitability for this particular application.

Copies of this National Standard of Canada may be ordered from ULC Standards.

CETTE NORME NATIONALE DU CANADA EST DISPONIBLE EN VERSIONS FRANÇAISE ET ANGLAISE

STANDARD FOR FLEXIBLE CONNECTOR PIPING FOR FUELS

ICS 23.040.60, 23.040.70

Prepared and Published by:



Approved by:



First Edition	June 1984
Second Edition.....	June 1990
Third Edition	August 1999
FOURTH EDITION	JUNE 2017

Copyright © 2017

ULC Standards
All rights reserved. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior permission.

TABLE OF CONTENTS

ULC STANDARDS COMMITTEE ON FUELING ACCESSORIES FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS	I
ULC STANDARDS TASK GROUP ON FUELING ACCESSORIES FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS	II
PREFACE	III
1 SCOPE	1
2 REFERENCE PUBLICATIONS	2
3 GLOSSARY	4
4 CONSTRUCTION	5
4.1 GENERAL	5
5 PERFORMANCE	6
5.1 GENERAL	6
5.2 SHORT TERM PRESSURE TESTS	7
5.2.1 General	7
5.2.2 Leakage Test	8
5.2.3 Hydrostatic Test	8
5.2.4 Breakdown Test	8
5.3 VACUUM TESTS	9
5.3.1 General	9
5.3.2 Static Vacuum Test	9
5.3.3 Cyclic Vacuum Test	9
5.4 PHYSICAL ABUSE TESTS	10
5.4.1 General	10
5.4.2 Drop Test	10
5.4.3 Impact Test	10
5.4.4 Puncture Test	10
5.4.5 Fitting Torque Test	11
5.4.6 Pipe Torque Test	11
5.4.7 Tension Test	11
5.4.8 Compression Test	11
5.4.9 Bending Test	12
5.5 CYCLIC USE TEST	12
5.5.1 General	12
5.5.2 Vibration Test	12
5.5.3 Surge Test	13
5.5.4 Flex Test	13
5.5.5 Swivel Joint Test	13
5.6 SHORT TERM COMPATIBILITY TESTS	14
5.6.1 General	14
5.6.2 UV Exposure Test	14
5.6.3 Metallic Stress Crack Test	14

5.6.4 Nonmetallic Stress Crack Test	15
5.7 LONG TERM COMPATIBILITY TESTS	15
5.8 FIRE TEST	16
5.9 INTERSTITIAL COMMUNICATION TEST	17
6 MANUFACTURING AND PRODUCTION TESTS	17
6.1 GENERAL	17
6.2 DIMENSIONAL MEASUREMENTS	17
6.3 LEAKAGE TESTS	17
7 MARKINGS	18
7.1 GENERAL	18
8 INSTALLATION INSTRUCTIONS	19
8.1 GENERAL	19
TABLES	21
APPENDIX A (NORMATIVE) – TEST FUEL FORMULATIONS	23
APPENDIX B (INFORMATIVE) – LIST OF STANDARDS ON FUELS	25

ULC STANDARDS COMMITTEE ON FUELING ACCESSORIES FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS

NAME	AFFILIATION	REGION	CATEGORY
M. Mailvaganam (Chair)	M. Mailvaganam -Consultant	Ontario	General Interest
B. Andrew	Veeder-Root	U.S.A.	Producer
A. Barker	Technical Standards & Safety Authority	Ontario	Regulator
M. Bishoff	Lorax Systems, Inc.	Canada	Producer
W. Boyd	Emco Wheaton Retail Corp.	U.S.A.	Producer
K. Crellin	Brugg Pipesystems LLC	USA	Producer
A. Dornan	Environment Canada, Environmental Stewardship Branch	Canada	Regulator
J. Duarte	Chemtura Canada Co./Cie	Canada	User
J. Dutton	Consultant	Newfoundland and Labrador	General Interest
D. Edgecombe	Petroleum Tank Management Association of Alberta	Alberta	Regulator
E. Fernandes	Ontario Petroleum Contractors Association	Ontario	User
S. Hyde-Clarke	National Research Council of Canada	Canada	General Interest
S. Jones	SDJ Associates blueprint2build Inc.	Canada	General Interest
P. Legault	Consultant	Canada	Regulator
B. Nelson	Franklin Fueling Systems, Inc.	U.S.A.	Producer
G. Nikolic	MHCC Consultants, Inc.	Ontario	General Interest
D. Northcotte	North Waterloo Farmers Mutual Insurance	Ontario	General Interest
R. Stephenson	Chevron	Canada	User
W. Trussler	Ship's Point Consulting	Canada	User
C. Vassos	Waleco, Inc.	Canada	Producer
S. Villeneuve	Vilco, Ltd.	Nova Scotia	User
K. Webster	OPW Fueling Containment Systems, Inc.	U.S.A.	Producer
M. Modéry (Non-voting)	Environment Canada, Environmental Stewardship Branch	Canada	Associate Member
P. Neil (Non-voting)	OPW Fueling Containment Systems, Inc.	U.S.A.	Associate Member
R. Riegel (Non-voting)	Underwriters Laboratories Inc.	U.S.A.	Associate Member
J. Wade (Non-Voting)	ULC Standards	Canada	Associate Member
C. D'Onofrio (Non-voting)	ULC Standards	Canada	Project Manager

This list represents the membership at the time the Committee balloted on the final text of this edition. Since that time, changes in the membership may have occurred.

ULC STANDARDS TASK GROUP ON FUELING ACCESSORIES FOR FLAMMABLE AND COMBUSTIBLE LIQUIDS

MEMBER

REPRESENTING

J. Wade (Chair)	ULC Standards, Canada
A. Barker	Technical Standards & Safety Authority, Ontario
J. Dutton	Consultant, Canada
D. Edgecombe	Petroleum Tank Management Association of Alberta, Canada
P. Long	Hose Master, U.S.A.
M. Mailvaganam	M. Mailvaganam Consultant, Ontario
W. Trussler	Ship's Point Consulting, Canada
R. Riegel	Underwriters Laboratories Inc., U.S.A.
K. O'Donnell (Project Manager)	ULC Standards, Canada

Copyright Underwriters' Laboratories of Canada

STANDARD FOR FLEXIBLE CONNECTOR PIPING FOR FUELS

PREFACE

This is the Fourth Edition of the Standard for Flexible Connector Piping for Fuels, CAN/ULC-S633.

This Edition of the Standard has been formally approved by the ULC Standards Committee on Fueling Accessories for Flammable and Combustible Liquids.

This Standard has been developed in compliance with the requirements of SCC for accreditation of a Standards Development Organization.

Only metric SI units of measurement are used in this Standard. If a value for measurement is followed by a value in other units in parentheses, the second value may be approximate. The first stated value is the requirement.

Appendix A, identified as Normative, forms a mandatory part of this Standard.

Appendix B, identified as Informative, is for guidance and information purposes only.

In Canada, there are two official languages, English and French. All safety warnings must be in French and English. Attention is drawn to the possibility that some Canadian authorities may require additional markings and/or installation instructions to be in both official languages.

This Fourth Edition National Standard of Canada is based on, and now supersedes, the Third Edition.

Attention is drawn to the possibility that some of the elements of this Canadian standard may be the subject of patent rights. ULC Standards shall not be held responsible for identifying any or all such patent rights.

Requests for interpretation of this Standard should be sent to ULC Standards. The requests should be worded in such a manner as to permit a “yes” or “no” answer based on the literal text of the requirement concerned.

The review and action to revise or reaffirm this Standard will not exceed 5 years from the date of publication, unless the Standard is identified as fitting within a stabilized category, whereby the review will commence within the appropriate time frame set out by ULC Standards.

This Standard is intended to be used for conformity assessment.

1 SCOPE

1.1 This Standard sets forth the minimum requirements for *primary*, *secondary*, and *coaxial* types of *flexible connector pipes* intended for short length transfer and containment of the specific liquid *fuels* (or vapours thereof) identified in this Standard, at commercial (public) or fleet (private) automotive motor vehicle fueling stations or similar *fuel* dispensing applications, and piping systems for *fuel* supply of generators, burners or similar equipment.

1.2 *Flexible connector pipes* may be metallic, nonmetallic, or composite, but are limited to maximum 3.65 m (12 ft) lengths in nominal *sizes* up to 102 mm (4 in) as flexible transition components within *fuel* dispensing and/or vapour recovery piping systems, typically intended for use in the following automotive fueling station applications:

- A *Underground* use (below surface but accessible such as within chase piping) when connected to *underground* tanks or *underground* pipes with expected exposures to soil, water, and soil fluids;
- B *Sump* use (enclosed tank, transition or dispenser types) when connected to pumps, valves, monitors, or dispensing devices with expected exposures to soil, water, soil fluids, and occasional sunlight;
- C *Aboveground* use (above surface but with additional physical protection, as applicable) when connected to *aboveground* tanks or *aboveground* pipes with expected exposures to soil, water, soil fluids, and sunlight.

1.3 *Flexible connector pipes* are intended for containment of automotive *fuels* and similar *fuels* or liquids under the expected use conditions, and exposures that have similar chemical, physical and material compatibility properties as represented in these requirements. Refer to Appendix B (Informative) for a list of Standards on *fuels* and other liquids.

1.4 Products covered by this Standard are intended to be installed and used in accordance with:

- A National Fire Code of Canada, Part 4;
- B CSA B139, Installation code for oil-burning equipment; and
- C CCME PN 1326, Environmental Code of Practice for Aboveground and Underground Storage Tank Systems Containing Petroleum and Allied Petroleum Products.

1.5 These products are factory manufactured and intended for on-site field assembly, inspection, and leak testing for the specified applications and use conditions by *qualified persons* in accordance with the manufacturer's instructions and local requirements.

1.6 These products are intended to be periodically inspected and maintained for continued service, or taken out of service if necessary, by *qualified persons* in accordance with industry recommended practices and/or the manufacturer's instructions.

1.7 These products have not been evaluated for use after natural disasters, fires or exposures to chemicals not representative of the test liquids or excessive physical damage beyond the expected assembly, installation and uses as identified in these requirements.

1.8 These products have not been evaluated for special use piping applications where exposed to heavy or continuous physical abuses, excessive mechanical stresses; or environments that are highly corrosive; or operate outside of the expected ambient use temperature range for significant times.

1.9 These requirements do not cover *underground* piping products for liquid *fuels*, which are found in CAN/ULC-S667, Standard for Metallic Underground Piping for Flammable and Combustible Liquids.

1.10 These requirements do not cover *aboveground* piping products for gaseous *fuels* (such as natural gas, liquefied petroleum gas, propane, butane, etc.), which are found in ULC/ORD-C536, Flexible Metallic Hose.

1.11 These requirements do not cover *fuel* dispensing and vapour recovery hose, which are found in CAN/ULC-S612, Standard for Hose and Hose Assemblies for Flammable and Combustible Liquids.

2 REFERENCE PUBLICATIONS

2.1 The documents shown below are referenced in the text of this Standard. Unless otherwise stated elsewhere in this Standard such reference shall be considered to indicate the edition and/or revisions of the document available at the date on which the Committee approved this ULC Standard.

Documents Published by the American Society for Testing and Materials (ASTM)
100 Barr Harbour Drive, PO Box C700, West Conshohocken, PA 19428-2959 U.S.A.
Telephone: (610) 832-9585
www.astm.org

- ASTM A653/A653M-15 (E 2016), Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot Dip Process
- ASTM D471-16, Standard Test Method for Rubber Property—Effect of Liquids
- ASTM D664-11 REV A, Standard Test Method for Acid Number of Petroleum Products by Potentiometric Titration
- ASTM D975-15, Standard Specification for Diesel Fuel Oils
- ASTM D1193-06 (R 2011), Standard Specification for Reagent Water
- ASTM D4814-16 REV A, Standard Specification for Automotive Spark-Ignition Engine Fuel
- ANSI/ASTM D5798-15, Standard Specification for Fuel Ethanol (Ed75–Ed85) for Automotive Spark-Ignition Engines
- ASTM D6751-15 REV C (E 2016), Standard Specification for Biodiesel Fuel Blend Stock (B100) for Middle Distillate Fuels
- ASTM D7467-15 REV C (E 2016), Standard Specification for Diesel Fuel Oil, Biodiesel Blends (B6 to B20)
- ASTM G153-13, Standard Practice for Operating Enclosed Carbon Arc Light Apparatus for Exposure of Nonmetallic Materials
- ASTM G155-13, Standard Practice for Operating Xenon Arc Light Apparatus for Exposure of Nonmetallic Materials

Documents Published by the CSA Group
178 Rexdale Boulevard, Toronto, ON M9W 1R3 Canada
Telephone: (416) 747-4000 or 1-800-463-6727